

MONITORING PROGRAM ANNUAL REPORT

JANUARY - DECEMBER 2009

ANCHORAGE WATER AND WASTEWATER UTILITY JOHN M. ASPLUND WATER POLLUTION CONTROL FACILITY AT POINT WORONZOF



Prepared for:



MUNICIPALITY OF ANCHORAGE
Anchorage Water & Wastewater Utility
Anchorage, Alaska

Prepared by:



**KINETIC
LABORATORIES
INCORPORATED**

1102 WEST 7th AVE., ANCHORAGE, AK 99501
(907) 276-6178

February 2010

MONITORING PROGRAM ANNUAL REPORT

JANUARY - DECEMBER 2009

ANCHORAGE WATER AND WASTEWATER UTILITY JOHN M. ASPLUND WATER POLLUTION CONTROL FACILITY AT POINT WORONZOF

NPDES Permit AK-002255-1

Prepared for:



Prepared by:



**KINETIC
LABORATORIES
INCORPORATED**

1102 WEST 7TH AVE., ANCHORAGE, AK 99501
(907) 276-6178

February 2010

PREFACE

This document is the Monitoring Program Annual Report required for submittal to the U.S. Environmental Protection Agency (EPA) by National Pollutant Discharge Elimination System (NPDES) Permit AK-002255-1 for discharge from the John M. Asplund Water Pollution Control Facility (WPCF), operated by the Anchorage Water and Wastewater Utility (AWWU) at Point Woronzof under authority of the Municipality of Anchorage (MOA). The NPDES permit incorporates provisions necessitated by the Clean Water Act (CWA) Section 301(h) variance from the requirements of secondary treatment.

The elements of the monitoring program are:

- Influent, Effluent, and Sludge Monitoring
 - In-Plant Sampling
 - Toxic Pollutant and Pesticide Sampling
 - Pretreatment Monitoring
 - Whole Effluent Toxicity Monitoring
- Receiving Water Quality Monitoring
 - Plume Dispersion
 - Intertidal Zone Bacteria
- Sediment and Bioaccumulation Monitoring
 - Sediment Analyses
 - Bioaccumulation Analyses

During 2009, the monitoring program consisted of sampling and analysis of the influent, effluent, and sludge twice for toxic pollutants and pesticides, one receiving water quality sampling and analysis effort, and quarterly whole effluent toxicity (WET) testing. In addition, AWWU conducted the required self-monitoring program for the influent, effluent, and sludge. The sediment and bioaccumulation components of the program were conducted during 2003 and 2004 and were required to be performed only once by the current NPDES permit.

This annual report provides information and data pertaining to the monitoring program performed to meet the requirements as set forth in the NPDES permit that became effective on 2 August 2000. The report covers the period of 1 January through 31 December 2009.

TABLE OF CONTENTS

PREFACE	i
TABLE OF CONTENTS.....	iii
LIST OF FIGURES	v
LIST OF TABLES.....	vi
APPENDICES (Bound Separately)	vii
SUMMARY	1
1.0 INTRODUCTION	5
1.1 REGULATORY/ENVIRONMENTAL BACKGROUND	5
1.1.1 Regulatory Background	5
1.1.2 Environmental Background	8
1.2 STUDY DESIGN.....	10
1.2.1 Monitoring Objectives	10
1.2.2 Program Description	10
1.2.3 Hypotheses	11
1.3 CONTRACTOR	11
1.4 PERIOD OF REPORT	11
2.0 METHODS	13
2.1 INFLUENT, EFFLUENT, AND SLUDGE MONITORING.....	13
2.1.1 In-Plant Monitoring	13
2.1.2 Toxic Pollutant and Pesticide Monitoring	13
2.1.3 Pretreatment Monitoring	15
2.1.4 Whole Effluent Toxicity Testing	15
2.1.5 Part 503 Sludge Monitoring.....	20
2.2 RECEIVING WATER QUALITY MONITORING	20
2.2.1 Water Quality Sampling	20
2.2.2 Intertidal Bacterial Sampling	21
2.2.3 Vessel Support	26
2.3 SEDIMENT AND BIOACCUMULATION MONITORING.....	27
2.4 LABORATORY ANALYSIS	27
2.5 DOCUMENTATION PROCEDURES	27
3.0 RESULTS	29
3.1 INFLUENT, EFFLUENT, AND SLUDGE MONITORING.....	29
3.1.1 Monthly Discharge Monitoring Data.....	29
3.1.2 Toxic Pollutants and Pesticides Analyses.....	31
3.1.3 Pretreatment Monitoring Data	39
3.1.4 Whole Effluent Toxicity Testing Results	39
3.1.5 Part 503 Sludge Monitoring Data	42

TABLE OF CONTENTS, CONTINUED

3.2	RECEIVING WATER QUALITY MONITORING RESULTS	44
3.2.1	Plume Dispersion Sampling.....	44
3.2.2	Intertidal Zone and Stream Bacterial Sampling.....	61
4.0	QUALITY ASSURANCE/QUALITY CONTROL	65
4.1	OBJECTIVES	65
4.2	FIELD QUALITY CONTROL.....	66
4.2.1	Documentation.....	66
4.2.2	Sample Handling.....	66
4.2.3	Navigation.....	67
4.2.4	Field Instrumentation	67
4.2.5	Sampling Variability	67
4.2.6	Field Check Samples.....	67
4.3	LABORATORY QUALITY CONTROL.....	68
4.3.1	Documentation.....	68
4.3.2	Calibration.....	68
4.3.3	Quality Control Procedures.....	68
4.3.4	Method Detection Limits	70
4.4	DATA REVIEW AND VALIDATION	70
4.5	QUALITY ASSURANCE/QUALITY CONTROL RESULTS.....	71
4.5.1	Field Instrumentation and Sampling Quality Control Results.....	71
4.5.2	Laboratory Quality Control Results.....	74
5.0	DISCUSSION	77
5.1	INFLUENT, EFFLUENT, AND SLUDGE MONITORING.....	77
5.1.1	Influent and Effluent Monitoring.....	77
5.1.2	Sludge Monitoring	91
5.2	WATER QUALITY MONITORING.....	93
5.2.1	Plume Dispersion Sampling.....	93
5.2.2	Fecal Coliform Bacteria.....	98
6.0	CONCLUSIONS.....	101
7.0	REFERENCES	103

LIST OF FIGURES

Figure 1.	General Study Area.....	6
Figure 2.	Asplund WPCF Outfall and Control Station Location.	9
Figure 3.	Asplund WPCF Outfall, ZID, and Locations of Intertidal Bacteriological Sampling	22
Figure 4.	Holey-Sock Drogue, Flotation, and Marker Buoy.....	23
Figure 5.	Tidal Information for Receiving Water Sampling, Ebb and Flood Tides	45
Figure 6.	Summary of Ebb Drogue Tracks and Receiving Water Sampling Locations at Point Woronzof, 23 June 2009	47
Figure 7.	Summary of Flood Drogue Tracks and Receiving Water Sampling Locations at Point Woronzof, 23 June 2009	48
Figure 8.	Tidal Information for Receiving Water Sampling, Control Tide	50
Figure 9.	Summary of Control Drogue Tracks and Receiving Water Sampling Locations at Point MacKenzie, 24 June 2009	51
Figure 10.	Sample Hydrographic Profiles from Outfall and Control Stations, June 2008	58
Figure 11.	Stream and Intertidal Station Locations for Fecal Coliform Bacteria Sampling	63

LIST OF TABLES

Table 1.	Overall Monitoring Requirements	12
Table 2.	Influent, Effluent, and Sludge Monitoring Requirements.	14
Table 3.	Methods for the Analysis of Toxic Pollutants and Pesticides for Influent, Effluent, and Sludge Monitoring	16
Table 4.	Preservation and Analytical Procedures for Influent, Effluent, and Sludge.	17
Table 5.	Receiving Water Quality Monitoring Requirements	24
Table 6.	Methods, Preservation, and Maximum Holding Times for the Analysis of Receiving Water Quality Samples	25
Table 7.	Approximate Locations of Intertidal Bacteria Sampling Stations.	26
Table 8.	Discharge Monitoring Data for Influent and Effluent Non-Metals	30
Table 9.	Toxic Pollutants and Pesticides in the Influent, Effluent, and Sludge, Sampled 23 and 24 June 2009	32
Table 10.	Toxic Pollutants and Pesticides in the Influent, Effluent, and Sludge, Sampled 28 and 29 July 2009	35
Table 11.	Pretreatment Monitoring Data for Influent and Effluent Metals and Cyanide	40
Table 12.	Summary of WET Test Data from 2009	41
Table 13.	Part 503 Discharge Monitoring Data for Sludge Metals	43
Table 14.	2009 Drogue Tracking Information	46
Table 15.	Hydrographic and Water Quality Data, 23 and 24 June 2009	53
Table 16.	Concentrations of Dissolved Metals, Total Recoverable Metals, Cyanide, and Total Suspended Solids in Receiving Water and Effluent Samples	60
Table 17.	Supplemental Receiving Water and Effluent Hydrocarbon Analyses	61
Table 18.	Summary of Bacterial Analyses, 23 June 2009	62
Table 19.	Sampling and Laboratory Variability for Water Quality Samples, 23 and 24 June 2009	72
Table 20.	Seabird SEACAT SBE-19 CTD Probe Variability Check, 24 June 2009	75
Table 21.	NPDES Requirements, State of Alaska Water Quality Standards, and AWWU 2009 Maximum Concentrations for Effluent Comparisons	78
Table 22.	Comparison Between Influent/Effluent Analysis Results for Anchorage and 40 POTWs	82
Table 23.	Comparison of Toxic Pollutants and Pesticides in Anchorage's Final Effluent to the Previous Five Years	83
Table 24.	Historical Discharge Monitoring Data (1986 - Present) for Influent and Effluent Total Metals and Cyanide	87
Table 25.	Historical Mean Monthly Discharge Monitoring Data (1986 - Present) for Influent and Effluent Non-Metals	90
Table 26.	Comparison Between Sludge Analysis Results for Anchorage and Typical and Worse Case Concentrations Used by EPA in Developing Median or Mean Environmental Profiles	92
Table 27.	Historical Discharge Monitoring Data (1986 - Present) for Metals in Sludge.	94
Table 28.	2009 Station Group Differences at the 5 Percent Significance Level as Determined by the Nonparametric Kruskal-Wallis and Dunn's Statistical Analysis Tests	95
Table 29.	State of Alaska Water Quality Standards for Receiving Water	97

APPENDICES (BOUND SEPARATELY)

APPENDIX A Toxic Pollutant and Pesticide Monitoring, June Sampling

- A1 Oil & Grease, Cyanide, Metals, Priority Pollutants, Dioxin,
Pesticides, and Hydrocarbons
SGS North America, Inc.
- A2 Asbestos
Lab/Cor, Inc.
- A3 Enterococci
Spectra Laboratories

APPENDIX B Toxic Pollutant and Pesticide Monitoring, July Sampling

- B1 Oil & Grease, Cyanide, Metals, Priority Pollutants, Dioxin,
Pesticides, and Hydrocarbons
SGS North America, Inc.
- B2 Asbestos
Solar Environmental Services, Inc. and IATL
- B3 Enterococci
Spectra Laboratories

APPENDIX C Receiving Water Quality Monitoring

- C1 Total Suspended Solids and Cyanide
Soil Control Lab
- C2 Aromatic Hydrocarbons and Color
SGS North America, Inc.
- C3 Polycyclic Aromatic Hydrocarbons
Texas A&M GERG
- C4 Trace Metals
Battelle
- C5 Intertidal Bacteria
Spectra Laboratories
- C6 Total Residual Chlorine and Turbidity
Kinnetic Laboratories, Inc.
- C7 Hydrographic Data Profiles
Kinnetic Laboratories, Inc.
- C8 Field Data Sheets
Kinnetic Laboratories, Inc.

SUMMARY

PURPOSE

This report is submitted to meet the requirements of the U.S. Environmental Protection Agency (EPA) and the Alaska Department of Environmental Conservation (ADEC) as outlined in the National Pollutant Discharge Elimination System (NPDES) Permit AK-002255-1 that was signed on 30 June 2000 and became effective on 2 August 2000. This permit authorizes discharge of effluent from the John M. Asplund Water Pollution Control Facility (Asplund WPCF). Wastewater from the Municipality of Anchorage is treated at this facility before discharge to the receiving waters of Knik Arm in Cook Inlet, Alaska. The NPDES permit incorporates the requirements necessitated by the Clean Water Act (CWA) 301(h) variance from secondary treatment and is in compliance with provisions of the Federal Water Pollution Control Act as amended by the CWA (33 U.S.C. §1251 et seq.) and the Water Quality Act of 1987.

HISTORY

In September 1979, the AWWU submitted to the EPA a 301(h) secondary treatment variance application proposing an improved discharge which eliminated chlorination and required the addition of both a 610-meter (m) extension and a 305-m diffuser to the Asplund WPCF outfall. The outfall extension was intended to move the point of discharge beyond the negative influence of a gyre that was reported to exist off Point Woronzof on a flood tide and was presumed to carry effluent toward shore, causing bacterial contamination of the shoreline.

Further studies were subsequently undertaken to derive design criteria for the outfall improvements. The central issue was to evaluate outfall design alternatives and the chlorination/no chlorination option in relation to a system of eddies that occur on the flood tide. These studies were completed as an Amendment to the Wastewater Facilities Plan for Anchorage, Alaska (CH2M Hill et al., 1985). This amended plan recommended the use of the existing 245-m outfall with the addition of a three-nozzle diffuser. It was shown that chlorination would still be required to meet bacterial standards even with an extended outfall and diffuser. Because the same water quality standards could be met by chlorinating and installing an improved diffuser at the end of the existing outfall, there was no need to extend the outfall.

Concurrent with the studies to amend the facilities plan, a revised CWA 301(h) variance application was submitted to the EPA. After extensive EPA review, public comment, and hearings, the Final Permit Decision was issued by EPA and the five-year NPDES permit became effective 16 October 1985 (EPA, 1985a). As required by this permit, a multi-port diffuser was installed in August 1987 prior to the second year of receiving water sampling. Fourteen years of monitoring were performed under the initial NPDES permit.

The AWWU submitted an application to renew the CWA 301(h) variance from secondary treatment in 1990. A more recent application was submitted in 1998 with additional information provided to EPA in 1999. A draft NPDES permit that incorporated the 301(h) variance was issued in 1999 for public comment. The renewed permit was signed by EPA on 30 June 2000 to become effective on 2 August 2000 for five years. The permit was administratively extended in August 2005 pending a permit renewal decision from EPA. The most recent application for a reauthorization of the NPDES permit and CWA 301(h) variance was submitted in January 2005 and is currently being reviewed by EPA.

RECEIVING WATER ENVIRONMENT

The Asplund WPCF discharges into the Knik Arm of Cook Inlet, a unique body of estuarine water with extremely high tidal fluctuations (over 39 feet [12 meters] with a mean range of 7.98 meters [m] at Anchorage; NOAA/NOS, 2009). These fluctuations produce extensive tidal flats, swift tidal currents of 4 - 6 knots, and intense mixing within Cook Inlet. The continual input of sediments, combined with the re-suspension of bottom sediments due to high bottom shear stress with each tidal cycle, results in naturally high suspended sediment concentrations of up to 2500 milligrams/liter (mg/L) in Knik Arm. This sediment originates from riverine and glacial melt waters flowing into Cook Inlet and Knik Arm from the Knik, Matanuska, and Susitna Rivers.

Large temperature extremes occur between summer and winter. In the winter, ice can reach thicknesses of 1 - 2 m and consists of broken pieces due to the large tides and currents. An important consideration to this study is the large volume of saline water that enters Cook Inlet that is completely vertically mixed with the riverine and glacial inputs by tidal turbulence which allows this water body to be very effective in wastewater dilution and assimilation.

MONITORING OBJECTIVES

The monitoring that was conducted during 2009 consisted of two main components: (1) in-plant monitoring of influent, effluent, and sludge, including whole effluent toxicity testing; and (2) receiving water quality monitoring in the vicinity of the discharge and mixing zone, and at a control site across Knik Arm. Objectives of the 2009 program as outlined in the permit are:

2009 MONITORING OBJECTIVES

Influent, Effluent, and Sludge Monitoring

- Determine compliance with the NPDES permit and State of Alaska water quality criteria
- Determine effectiveness of the industrial pretreatment program
- Aid in assessing the water quality at discharge point
- Characterize toxic substances
- Monitor plant performance
- Determine compliance with the regulatory criteria of Section 301(h) of the CWA
- Provide data for evaluating re-issuance of the NPDES permit

Receiving Water Quality Monitoring

- Determine compliance with the NPDES permit and State of Alaska water quality criteria
- Aid in assessing the water quality of the receiving water
- Determine compliance with the regulatory criteria of Section 301(h) of the CWA
- Determine the level of bacterial concentrations in nearshore waters
- Provide data for evaluating re-issuance of the NPDES permit

MONITORING RESULTS

As part of its self-monitoring program, AWWU conducted daily, weekly, and monthly sampling of influent, effluent, and sludge, depending on the parameter measured. In addition, monitoring for toxic pollutants and pesticides was conducted twice during 2009, once in June and once in

July. Whole effluent toxicity testing was conducted quarterly, while receiving water quality monitoring was performed once in June. The following summarizes results of this year's monitoring based on the permit requirements:

2009 MONITORING RESULTS

Influent, Effluent, and Sludge

- The influent, effluent, and sludge monitoring showed, that with no exceptions, the Asplund WPCF met the NPDES permit requirements and complied with all applicable State of Alaska water quality standards (AWQS). AWWU's self-monitoring of total residual chlorine (TRC), pH, fecal coliform bacteria, 5-day biological oxygen demand (BOD₅), and total suspended solids (TSS) showed compliance with all permit effluent limitations throughout 2009.
- AWWU's self-monitoring of TRC and pH showed that the permit limit for daily maximum TRC levels in the effluent was never exceeded and pH was within permit limits throughout 2009.
- The permit limit for the monthly maximum geometric mean of 850 fecal coliform colonies per 100 mL by most probable number (FC MPN/100 mL) technique was not exceeded in 2009. The fecal coliform monthly criteria "that not more than 10 % of the effluent samples shall exceed 2600 FC MPN/100 mL" was also not exceeded in any month during 2009.
- AWWU's self-monitoring of TSS and BOD₅ showed compliance with both regulatory and permit effluent limitations. TSS and BOD₅ were well within the daily, weekly, and monthly criteria for the entire year. Average monthly removals for BOD₅ and TSS of greater than 30 percent (%) are required by the amendment to the CWA (40 CFR Part 125; Final Rule, 8/9/94). The removal rate for both TSS and BOD₅ met the 30 % minimum removal requirement for all months during 2009. Annual removals were 76 % for TSS and 47 % for BOD₅ which indicate an exceptional level of primary treatment.
- Total aromatic hydrocarbons (TAH), total aqueous hydrocarbons (TAqH), and total ammonia concentrations in the effluent were all found to be below their maximum allowable effluent concentrations (MAECs) throughout 2009.
- Concentrations of metals and cyanide in the effluent never exceeded their MAECs at any time during any of the 2009 monitoring events.
- Concentrations of toxic pollutants and pesticides, including metals and cyanide, in the influent and effluent were all within the established range or lower than values from a national study of secondary treatment plants (EPA 1982a).
- Toxic pollutant sludge concentrations were found to be very low compared to the limits established under 40 CFR Part 503 and most were either not-detected or within the established range or lower than values from a national study of secondary treatment plants. Most metals fell at or below the typical concentrations and all metals, except one beryllium sample, were below 95th percentile worst case values (EPA 1985c).
- Whole effluent toxicity testing conducted quarterly met all permit limitations for toxicity for all tested species and all monitoring events in 2009.

Water Quality

- Little variation among stations was observed for most hydrographic parameters indicating that the receiving water environment is uniform and well mixed near the outfall.
- To test the hypothesis that the water quality at the zone of initial dilution (ZID) boundary was not degraded with respect to the water quality at the nearfield and control stations, statistical comparisons were employed. Conventional parameters such as dissolved oxygen, pH, salinity, and turbidity did show significant differences between sites, however, these were not ascribed to the outfall but rather to the different water mass properties at the control stations. No statistically significant differences were seen for temperature, TRC, TSS, color, or fecal coliform at the ZID boundary when compared to nearfield and control stations.
- Fecal coliform concentrations in receiving water and intertidal samples were found to be very low at all stations. AWQS criteria of a median of not more than 14 FC MPN/100 mL, a geometric mean of not more than 20 FC MPN/100 mL, and of not more than 10 % of the samples exceeding 40 FC MPN/100 mL were met at all receiving water locations.
- Supplemental receiving water quality samples obtained as part of the plume dispersion monitoring indicated that dissolved metals were all below the AWQS at all locations on the ZID boundary and outside of the ZID including the control stations. Statistically significant differences between the outfall and control station groupings were seen for dissolved chromium and nickel but all concentrations were well within AWQS. Total metals were elevated compared to the dissolved as a result of the naturally high suspended sediment load. No statistically significant differences were seen between the outfall and control stations for any of the total recoverable metals.
- All cyanide concentrations in the receiving waters (outfall and control stations) were found to be below the receiving water quality criterion limit of 1.0 µg/L and no statistically significant differences were detected between concentrations at the control and outfall stations.
- Supplemental receiving water samples also demonstrated that TAH and TAqH met the AWQS at all locations. No statistically significant differences were detected between the control and outfall stations for either TAH or TAqH.
- Turbidity and color met the AWQS at all stations. TRC was at or below the detection limit of 10 µg/L at all locations except for three samples taken from within the ZID, as compared to the AWQS of 7.5 µg/L for chronic and 13.0 µg/L for acute marine water use. Based on the highest maximum daily effluent TRC concentration of 1050 µg/L seen during 2009 and a 180:1 effluent dilution credit, it is expected that TRC in the receiving water would be <6 µg/L before reaching the ZID boundary and would meet all AWQS for TRC.

CONCLUSIONS

Results from the past year of the monitoring program confirm previous studies, data in the 301(h) variance renewal application, and the decision by the EPA to reissue the NPDES permit with 301(h) variance. The Asplund WPCF is operating within regulatory requirements with no exceptions seen in 2009 and is showing no measurable impacts to the marine environment.

1.0 INTRODUCTION

1.1 REGULATORY/ENVIRONMENTAL BACKGROUND

The monitoring program is designed to meet the requirements of the NPDES Permit AK-002255-1 which authorizes discharge of municipal effluent into the Knik Arm of Cook Inlet receiving waters from the John M. Asplund WPCF, operated by the AWWU under authority of MOA (Figure 1). The NPDES permit, which became effective on 2 August 2000, incorporates the requirements necessitated by the CWA 301(h) secondary treatment variance and is in compliance with provisions of the Federal Water Pollution Control Act as amended by the Clean Water Act (CWA 33 U.S.C. §1251 et seq.) and the Water Quality Act of 1987, P.L. 100-4.

1.1.1 Regulatory Background

In 1972, while the Asplund WPCF and outfall were being built for the MOA, the Federal Water Pollution Control Act (FWPCA) was amended to establish two phases of effluent limitations applicable to all Publicly Owned Treatment Works (POTWs). Under Section 301(b), POTWs were required to achieve secondary treatment of effluent by 1 July 1977 and the "best practicable waste treatment technology" by July 1983.

Congress again amended the FWPCA in 1977. Section 301(h) was added, providing that the Administrator of the EPA, upon application from a POTW and with the concurrence of the State, might issue an NPDES permit modifying the requirements of Section 301(b). On 15 June 1979, EPA promulgated the regulations regarding the issuance of this variance of secondary treatment to an applicant discharging into certain ocean and estuarine waters and demonstrating compliance with the 301(h) criteria.

In September 1979, the AWWU submitted to the EPA a 301(h) variance application proposing an improved discharge which eliminated chlorination and required the addition of both an extension and diffuser to the Asplund WPCF outfall. Earlier studies had recommended the construction of a 610-m outfall extension and a 305-m diffuser. The proposed extension/diffuser reportedly could meet fecal coliform receiving water standards without chlorination and prevent shore contact of the wastewater plume.

As a parallel program, the AWWU undertook preparation of a wastewater master plan for the Anchorage area. The resultant Wastewater Facilities Plan for Anchorage, (Ott Water Engineers, Inc. et al., 1982) and the Environmental Impact Statement, City of Anchorage, Alaska, Wastewater Facilities (EPA and Jones & Stokes, 1982) were accepted by the EPA and ADEC.

Further studies were subsequently undertaken to derive design criteria for the outfall improvements. Significant efforts were included in this study to improve the reconnaissance level data upon which the outfall length and diffuser design were to be based and to evaluate bacterial standards applicable to Knik Arm. The central issue was to evaluate outfall design alternatives and the chlorination or no-chlorination option in relation to the presence of a system of eddies that occur to the east of Point Woronzof on the flood tide which might be capable of transporting the effluent shoreward. These latter studies were completed as an Amendment to the Wastewater Facilities Plan for Anchorage, Alaska (CH2M Hill et al., 1985). This amended plan recommended use of the existing 245-m outfall with the addition of a three-nozzle diffuser. It was shown that chlorination would be required to meet bacterial standards even with an




Figure 1. General Study Area.

extended outfall and diffuser. Because the same standards could be met by use of chlorination and the existing outfall, there was no need to extend the outfall. With continued chlorination, all water quality standards were predicted to be met by the amended facilities plan.

Concurrent with the studies to amend the facilities plan, a revised application entitled Application for Modification of Secondary Treatment Requirements, Section 301(h), Clean Water Act was submitted to the EPA (CH2M Hill et al., 1984). The EPA Region 10 301(h) Review Team's Tentative Decision Document, entitled Analysis of the Section 301(h), Secondary Treatment Variance Application for the Asplund WPCF (EPA, 1985b), and a draft NPDES permit were made available for public comment on 17 January 1985. After comments and appropriate hearings, the Final Permit Decision (EPA, 1985a) was issued 13 September 1985, and the start date of the five-year NPDES Permit AK-002255-1 was listed as 16 October 1985. As required by this permit, a multi-port diffuser was installed at the Asplund WPCF outfall in the beginning of August 1987. This occurred prior to the 1987 summer water quality monitoring program. This original NPDES permit expired on 15 October 1990.

The AWWU submitted a renewal application for the permit in April 1990 which addressed amendments made to the 301(h) provisions by the Water Quality Act. That renewal application was not acted upon by EPA and the facility continued to operate under an administrative extension of the 1985 permit until August 2000. In 1998 it was projected that the growth of Anchorage would result in the discharge limits contained in the 1985 permit being exceeded within a few years. Therefore, the AWWU prepared and submitted another renewal application which replaced the 1990 application in October 1998 (CH2M Hill, 1998).

In tandem with the renewal application, the AWWU conducted special studies and submitted a request for site-specific water quality criteria (SSWQC) to the ADEC for the Point Woronzof area of Cook Inlet in December 1998. This request for SSWQC was for turbidity and a suite of metals and was necessitated because the Alaska Water Quality Standards (AWQS) for marine waters could not be achieved for these waters as a result of the naturally high suspended sediment loads in Cook Inlet due to glacial inputs. The approach to the request was based on the EPA's Metals Policy that had been recently promulgated which recommends the use of only the dissolved fraction of metals as bioavailable and appropriate for the protection of aquatic life and associated beneficial uses of the water body. Following both agency and public review and comments, the SSWQC were incorporated into the AWQS as amended on 27 May 1999. The SSWQC for the Point Woronzof area included turbidity and the dissolved fraction of arsenic, cadmium, hexavalent chromium, copper, lead, mercury, nickel, selenium, silver, and zinc.

Following the promulgation of these new AWQS, a tentative decision to grant the AWWU its 301(h) variance was made by EPA on 4 November 1999. The tentative decision, draft NPDES permit, and permit fact sheet were then made available for public review and comments. The State of Alaska's Division of Government Coordination issued its Final Consistency Determination for the action in February 2000. The current NPDES permit for the Asplund WPCF was signed by EPA and went into effect 2 August 2000 for five years, and was then administratively extended in August 2005 pending permit renewal. The most recent application for a reauthorization of the NPDES permit with 301(h) variance was submitted in January 2005 and is still under review by the EPA.

The NPDES permit specifies the required monitoring program. The Monitoring Program Plan (Kinnetic Laboratories, Inc., 2000a), submitted to the EPA in October 2000, identified how the

AWWU plans to fulfill the requirements of this monitoring program. This annual report documents the progress and results of the monitoring program that were performed in 2009.

Since the issuance of the current NPDES permit, EPA has approved ADEC's proposed use of dissolved metals for the AWQS, approved all of the proposed SSWQC for Upper Cook Inlet in the vicinity of Pt. Woronzof, and removed Alaska from the National Toxic Rule (EPA, 2006). In September of 2009 EPA approved the 2009 revisions to the AWQS and the December 2008 State of Alaska Toxics Manual which lists numerical limits. Except for cadmium and mercury where the dissolved cadmium standard changed from 9.3 µg/L in the SSWQC to 8.8 µg/L in the AWQS and mercury which changed from 0.025 µg/L in the SSWQC to 0.94 µg/L in the AWQS, all other dissolved metals criteria are the same between the two standards.

1.1.2 Environmental Background

The Asplund WPCF discharges to the receiving waters of Cook Inlet, Alaska. The discharge is located off Point Woronzof in Knik Arm of Upper Cook Inlet.

Cook Inlet is a major tidal estuary that is approximately 333 kilometers (km; 180 nautical miles) long and 93 - 148 km (50 - 80 nautical miles) wide at its lower end with a large assimilative capacity. Bathymetry indicates the Inlet is deep, generally 36.6 m (20 fathoms) north of the Forelands and about 164.6 m (90 fathoms) at the mouth. Numerous rivers, including the major Susitna River drainage, discharge into the Inlet. A detailed map of the Point Woronzof region indicates deep water (9.1 - 51.8 m) extending well past Anchorage up the Knik Arm (Figure 2).

Cook Inlet is a unique estuary, with perhaps the closest parallel being the Bay of Fundy between New Brunswick and Nova Scotia, Canada. The occurrence of tidal bores at the head, currents of 4 - 6 knots, suspended loads of up to 2500 mg/L, large temperature extremes, and moving pancake ice of up to one meter (m) thick make Cook Inlet unique. The high tidal ranges result from the geometry of the Inlet which has a natural resonance period close to the semi-diurnal tidal period. The resulting large tidal fluctuations and fast currents cause complete vertical mixing of the Inlet waters including any discharges into those waters.

Other important factors to this study are the large volume of saline water that enters Cook Inlet that is completely vertically mixed with the riverine inputs by tidal turbulence. This allows the water body to be very effective in wastewater dilution and assimilation.

The particle size distributions of the natural suspended sediments near Point Woronzof show that very large particles are suspended by the current-generated turbulence, with 50 percent of the load being in the size range of 65 - 250 microns. The settling of large particles is seen at slack tide, but due to the shifting currents, never settle completely. Settling rate tests of the suspended material show that 93% of the solids in an ambient water sample settle in twenty minutes,

Previous work has indicated that due to the extremely swift currents, no seabed accumulation of suspended sediments, either natural or from the discharge, occur in the vicinity of the outfall. In this location, the bottom is strictly coarse gravel and cobble because of these currents. However, areas of deposition do exist, such as to the east of Point Woronzof, where mudflats and beaches are found, and to the southwest of the Point. The area between Fire Island and the mainland is hard-packed sand with no deposition of silt or finer materials as a result of the high current energy. Of course, any suspended solids in these materials of effluent origin would actually




Figure 2. Asplund WPCF Outfall and Control Station Location.

dilute the much larger natural load in the receiving water (400 - 2,500 mg/L versus approximately 50 mg/L effluent). Studies have also shown that essentially no benthic biota are found on the scoured cobble/gravel bottom or on the rock beaches at both Point Woronzof and the control area. Similar sampling of soft bottom beaches and tidal flats showed very sparse abundances and very low diversities. Benthic and intertidal marine fauna populations are limited by the harsh physical environment of mud and silt, high turbulence and bottom scouring, large tide and strong currents, and extreme ice conditions.

Current trajectories in the immediate vicinity of the outfall are of concern because of flow separation zones on either side of Point Woronzof. Previous work has indicated that, on a flood tide, a clockwise eddy sometimes exists east of Point Woronzof. This eddy may result in the shoreward transport of wastes at certain stages of tide. A flow separation also exists to the west of Point Woronzof during ebb flow; however the effluent is not entrained shoreward in this area.

1.2 STUDY DESIGN

1.2.1 Monitoring Objectives

The monitoring program as described by NPDES Permit No. AK-002255-1 includes influent, effluent, and sludge monitoring at the Asplund WPCF; receiving water and sediment quality monitoring; biological and toxicological monitoring; and a toxics control program. The objectives of the overall monitoring program as outlined in the NPDES permit are to:

- Determine compliance with the NPDES permit
- Determine compliance with State water quality criteria
- Determine effectiveness of the industrial pretreatment program
- Aid in assessing the water quality at the discharge point
- Characterize toxic substances
- Monitor plant performance
- Determine compliance with the regulatory criteria of Section 301(h) of the CWA
- Determine the level of bacterial concentrations in nearshore waters
- Monitor for changes in sediment quality (organic enrichment, alteration of grain size distribution, and pollutant contamination) (note: not required or performed in 2009)
- Determine if pollutants from the discharge are accumulating in exposed biological organisms (note: not required or performed in 2009)
- Provide data for evaluating re-issuance of the NPDES permit

1.2.2 Program Description

The elements of the monitoring program for the Asplund WPCF are:

- Influent, Effluent, and Sludge Monitoring, including
 - In-Plant Sampling
 - Toxic Pollutants and Pesticides (including Metals and Cyanide)
 - Pretreatment Monitoring
 - Whole Effluent Toxicity (WET) Testing
- Receiving Water Quality Monitoring, including
 - Plume Dispersion and Water Quality

- Intertidal Bacteria
- Biological and Sediment Monitoring, including
 - Sediment Quality
 - Bioaccumulation

Table 1 provides an overview of the monitoring requirements as described by the permit. Detailed information regarding each program component is provided in Section 2.0, Methods.

1.2.3 Hypotheses

Hypotheses were formulated for the monitoring program as an unbiased approach in determining whether the Asplund WPCF was affecting the marine receiving water environment. The null (no effect) hypotheses tested for this year of monitoring are as follows:

H₀₁: Applicable State and Federal effluent and receiving water standards were met by the Asplund WPCF discharge.

H₀₂: Water quality at the boundary of the ZID was not significantly changed with respect to nearfield or control stations.

1.3 CONTRACTOR

The AWWU's designated contractor for the 2009 Asplund WPCF Monitoring Program was Kinnetic Laboratories, Inc. (KLI) of Anchorage, Alaska.

For influent, effluent, and sludge monitoring, aromatic hydrocarbon, pesticide, and volatile and semi-volatile priority pollutant analyses (gas chromatography/mass spectrometry scans), trace metals (total and dissolved) for the toxic pollutant, pesticide, and pretreatment monitoring were performed by SGS North America, Inc. of Anchorage, Alaska. WET testing was performed by ToxScan, Inc. of Watsonville, California. Asbestos analyses were performed by Solar Environmental Services, Inc. of Anchorage, Alaska, Lab/Cor, Inc. and IATL, Inc. In addition, the Municipality's Asplund WPCF Laboratory performed the monthly in-plant analyses as part of its self-monitoring program and contracted the Part 503 sludge analyses to SGS North America, Inc. of Anchorage, Alaska.

KLI performed the receiving water sampling and analyses for turbidity and total residual chlorine (TRC). Analytical support for the receiving water sampling included: Battelle (Sequim, Washington) for trace metals; Soil Control Lab (Watsonville, California) for total suspended solids (TSS) and cyanide; SGS North America, Inc. for aromatic hydrocarbons and color; Spectra Laboratories in (Tacoma, Washington) for bacteriology; and Texas A&M University's Geochemical and Environmental Research Group (GERG) (Texas) for polycyclic aromatic hydrocarbons (PAHs) analyses.

1.4 PERIOD OF REPORT

This report documents the progress and results of the monitoring program from 1 January through 31 December 2009 under the current NPDES permit.

Table 1. Overall Monitoring Requirements.

Parameter	Frequency	Sample Type	Remarks
In-Plant Sampling	See Table 2	See Table 2	See Table 2 - includes flow, TRC, DO, BOD ₅ , TSS, temperature, pH, fecal coliform, total ammonia as nitrogen, enterococci bacteria, and oil and grease
Toxic Pollutants and Pesticides (including Metals and Cyanide)	2/year ^a	influent, 24-hr composite effluent, 24-hr composite sludge, 24-hr composite	See Table 2
Pretreatment Program	2/year ^{a,b}	influent, three 24-hr composite effluent, three 24-hr composite sludge, 24-hr composite (8 grabs/day)	Includes metals and cyanide plus percent solids for sludge
Whole Effluent Toxicity (WET) Testing	4/year ^c	effluent, 24-hr composite	See Table 2
Receiving Water Quality	1/year ^d	receiving water	See Table 5
Intertidal Bacteria	1/year ^e	intertidal receiving water	Fecal coliform sampling at 8 intertidal stations
Sediment	Once during the fourth year of the permit ^e	grab samples of surficial (0-2 cm) sediment collected at intertidal and subtidal stations ^f	Includes total volatile solids (TVS), toxic pollutants and pesticides (including metals and cyanide), and sediment grain size distribution
Bioaccumulation	Once during the fourth year of the permit	grab samples of intertidal macroalgae (<i>Vaucheria</i> spp.) Note: Macroalgae was not available during 2003 or 2004. Therefore, in consultation with EPA and AWWU pacific cod (<i>Gasdus macrocephalus</i>) were collected and analyzed for this permit component in October 2004 ^g	Includes toxic pollutants and pesticides (including metals and cyanide)

^a Sampling will be conducted twice per year: once in summer dry conditions and once in summer wet conditions.

^b The first day of three consecutive days of sampling will be part of the Toxic Pollutant and Pesticides (metals and cyanide) sampling performed twice each year.

^c WET testing will be performed on a quarterly basis.

^d Sampling will be conducted once per year in summer dry conditions.

^e Sampling will be conducted in conjunction with the receiving water sampling.

^f Sampling will be performed at Intertidal Stations 1, 2, and Control (IT-1, IT-2, and IT-C); a subtidal station located at the ZID boundary, and a subtidal control station near Point MacKenzie (in a similar water depth as the ZID boundary).

^g Sampling was to be performed in conjunction with the sediment analyses however algae was not available in sufficient quantities for sampling in 2003 or 2004. Pacific cod were collected and analyzed for this permit component in October 2004.

2.0 METHODS

2.1 INFLUENT, EFFLUENT, AND SLUDGE MONITORING

Influent, effluent, and sludge monitoring is outlined in Table 2. Routine daily, weekly, and monthly sampling of conventional pollutant parameters and flow rate were performed by AWWU. The less-frequently monitored parameters of enterococci bacteria, oil and grease, toxic pollutants and pesticides (including metals and cyanide), and Whole Effluent Toxicity (WET) testing were handled by KLI.

- ✓ determine compliance with the NPDES permit and State of Alaska water quality criteria
- ✓ determine effectiveness of the industrial pretreatment program
- ✓ aid in assessing the water quality at the discharge point
- ✓ characterize toxic substances
- ✓ help monitor plant performance
- ✓ determine compliance with the regulatory criteria of Section 301(h) of the CWA
- ✓ provide data for evaluating re-issuance of this permit

2.1.1 In-Plant Monitoring

In-plant influent, effluent, and sludge sampling was performed by AWWU personnel as described in Table 2 and in a separate monitoring program plan prepared by AWWU (AWWU, 2000). Samples were obtained following the schedule of frequency required by the permit. Influent was sampled at a representative location in the influent headworks, upstream from the recycle streams. Effluent was sampled at a well-mixed point downstream from the chlorination input point in the final effluent line. Composite sludge samples were obtained from the sludge feed screw auger downstream of the addition of primary scum. Grab samples were obtained for total residual chlorine (TRC), dissolved oxygen (DO), temperature, pH, and fecal coliform. Composite samples were obtained for analysis of biochemical oxygen demand (BOD₅), total suspended solids (TSS), and total ammonia as nitrogen.

2.1.2 Toxic Pollutant and Pesticide Monitoring

As outlined in the permit, toxic pollutant and pesticide sampling was conducted twice this year, once during June 2009 (summer dry) and once during July 2009 (summer wet). Samples were collected as required by the permit and either analyzed by AWWU laboratory personnel or provided to KLI for shipment to the appropriate analytical laboratory. Plant influent was sampled as discrete grabs or by flow-proportional composite samplers (depending on the analysis method) at a representative location in the influent headworks upstream from the recycle streams. Effluent was sampled as discrete grabs or using flow-proportional samplers at a well-mixed point downstream from the chlorination injection point in the final effluent line. Influent and effluent samples were chilled as required during composite sampling. Composite sludge samples were obtained from the sludge feed screw auger.

Samples were composited for the analysis of pesticides, semi-volatile organics, metals, asbestos, and cyanide. Samples consisted of composites of flow-proportioned samples collected over a 24-hour (hr) period using two ISCO Model 3700 Refrigerated Autosamplers. Grab samples for volatile organics analysis were collected every three hours during the 24-hr sampling period and composited by the laboratory prior to analysis. Grab samples were collected for analysis of total

Table 2. Influent, Effluent, and Sludge Monitoring Requirements.

Parameter	Sample Point ^a	Sample Frequency	Sample Type
Flow ^b	effluent	continuous	continuous
Total Residual Chlorine (TRC) ^b	effluent	continuous <u>or</u> every 2-4 hrs	grab
Dissolved Oxygen (DO) ^b	effluent	4/week	grab
Biochemical Oxygen Demand (BOD ₅) ^b	influent and effluent	4/week	24-hr composite
Total Suspended Solids (TSS) ^b	influent and effluent	4/week	24-hr composite
Temperature ^b	influent and effluent	4/week	grab
pH ^b	influent and effluent	4/week	grab
Fecal Coliform Bacteria ^b	effluent	3/week	grab
Total Ammonia as N ^b	effluent	1/month	24-hr composite
Enterococci Bacteria ^c	effluent	2/year ^d	grab
Oil and Grease ^c	effluent	2/year ^d	grab
Toxic Pollutants and Pesticides (including Metals and Cyanide) ^e	influent, effluent, and sludge	2/year ^d	24-hr composite
WET ^f	effluent	4/year ^f	24-hr composite

^a When both influent and effluent samples are required, samples will be collected during the same 24-hr period.

^b AWWU will perform this monitoring component.

^c KLI will perform this monitoring component.

^d Twice per year sampling: once during summer in dry conditions and once in wet conditions.

^e As part of the pretreatment program sampling requirements, arsenic, cadmium, chromium, copper, cyanide, lead, mercury, molybdenum, nickel, silver, and zinc in influent, effluent, and sludge will be sampled, along with percent solids (in sludge only). In 2009, these metals were analyzed and reported by as total recoverable metals and dissolved metals for influent and effluent and as total metals in mg/kg dry weight for sludge. Sampling will be as follows: Influent and effluent as three separate 24-hr composite samples taken on 3 consecutive days (Mon - Fri), the first day of which coincides with the twice yearly sampling (summer-dry and-wet conditions); sludge as one composite of eight grabs/day when influent and effluent samples are being taken. In addition, the other four metals from the toxic pollutant list will be analyzed in the summer wet/summer dry samples: beryllium, antimony, thallium, and selenium.

^f WET requirements are summarized in the text (Section 2.1.4). Initial testing will be a screening period performed during three quarters, during which three species will be tested to determine the most sensitive species. Re-screening will be performed each year during one quarter (different than the previous year) to determine the species to use for continued testing. Accelerated testing requirements will be triggered if chronic toxicity is greater than 143 TUc (chronic toxicity units, TUc=100/NOEC).

hydrocarbons as oil and grease and purgeable aromatic compounds. Sludge samples were collected from the sludge feed screw auger every three hours over a 24-hr period and the eight samples representatively composited prior to analysis.

At time of collection, all samples were appropriately labeled using pre-prepared, project-specific sample labels as described in Section 2.5. Sample collection and shipment was documented using project-specific chain of custody forms as described in Section 2.5.

Toxic pollutants as defined by the permit are those substances listed in 40 Code of Federal Regulations (CFR) 401.15 (Table 3). This list involves 65 categories of pollutants, including asbestos, aromatic hydrocarbons, pesticides, metals, and polychlorinated biphenyls (PCBs). Pesticides as defined in the permit are demeton, guthion, malathion, mirex, methoxychlor, and parathion as listed in 40 CFR 125.58. Other pesticides which were tested for are included on the toxic pollutants list (40 CFR 401.15). The methods that were used to analyze these constituents for the program and for which KLI was responsible, as well as those performed by AWWU, are also provided in Table 3. Preservation and maximum holding time information for each of these methods is provided in Table 4. All samples were collected in the appropriate precleaned sample containers and preserved, if necessary, as described by the EPA or equivalent method. All sample containers were immediately placed on gel ice after sampling. Samples remained chilled as required during shipment to the analytical laboratory.

2.1.3 Pretreatment Monitoring

The pretreatment monitoring program as outlined in Table 1 and Table 2 was performed by the AWWU. This monitoring was performed twice in 2009 in conjunction with the summer dry and wet sampling. As part of the pretreatment program sampling requirements, arsenic, cadmium, chromium, copper, cyanide, lead, mercury, nickel, silver, and zinc in influent, effluent, and sludge were sampled, along with percent solids (in sludge only). These samples were analyzed by SGS North America Inc. as total recoverable metals and dissolved metals for influent and effluent and as total recoverable metals in dry weight for sludge. Sampling was conducted as follows: Influent and effluent as three separate 24-hr composite samples taken on 3 consecutive days (Monday - Thursday), the first day of which coincided with the twice-yearly toxic pollutant and pesticide sampling (summer dry and summer wet, respectively). The sludge sampling consisted of a single composite of eight grabs/day when influent and effluent samples were being taken. A detailed study plan describing this monitoring was provided previously (AWWU, 2000).

2.1.4 Whole Effluent Toxicity Testing

As outlined in the permit, the WET testing must be performed on a quarterly basis on 24-hr flow-composited effluent samples. Effluent was sampled by discrete flow-proportional samplers at a well-mixed point downstream from the chlorination injection point in the final effluent line. Effluent samples were collected in the appropriate precleaned sample containers as described in the bioassay method, chilled, and shipped immediately to the toxicity laboratory for testing. Samples were appropriately labeled at the time of collection using pre-prepared, project-specific sample labels as described in Section 2.5. Sample collection and shipment were documented using project-specific chain of custody forms. Sample containers were immediately placed on gel ice after sampling and remained chilled during shipment to the toxicity laboratory.

Table 3. Methods^a for the Analysis of Toxic Pollutants and Pesticides for Influent, Effluent, and Sludge Monitoring.

Volatile Organic Compounds	Semi-Volatile Organic Compounds	Pesticides and PCBs	Inorganic Compounds
EPA 624 (Inf/Eff) SW 8260B (Sludge) Benzene Chlorinated benzenes Dichlorobenzenes Ethylbenzene Toluene Xylenes ^b	EPA 625 (Inf/Eff) SW 8270C (Sludge) Acenaphthene Benzidine Chloralkyl ethers Chlorinated ethanes Chlorinated naphthalenes Chlorinated phenols 2-chlorophenol DDT & metabolites Dichlorobenzenes Dichlorobenzidine 2,4-dichlorophenol 2,4-dimethylphenol Dinitrotoluene Diphenylhydrazine Fluoranthene Haloethers Heptachlor & metabolites Hexachlorobutadiene Hexachlorocyclopentadiene Hexachloroethane Isophorone Naphthalene Nitrobenzene Nitrophenols Nitrosamines Polycyclic aromatic hydrocarbons (PAHs) Pentachlorophenol Phenol Phthalate esters	EPA 614 (Inf/Eff) SW 8141A (Sludge) Demeton Malathion Parathion Guthion ^b	EPA 100.1/EPA 100.2 (Inf/Eff) Polarized Light Microscopy (PLM; Sludge) Asbestos
EPA 624 (Inf/Eff) SW 8260B (Sludge) Acrolein ^b Acrylonitrile ^b Benzene Carbon tetrachloride Chloralkyl ethers Chloroform Chlorinated benzenes Chlorinated ethanes 1,2-dichloroethane Dichloroethylenes Dichloropropane Dichloropropene 1,1,1-trichloroethane Ethylbenzene Halomethanes Methylene chloride Bromoform Dichlorobromomethane Toluene Tetrachloroethylene Trichloroethylene Vinyl chloride	SW 8280A (Inf/Eff/Sludge) 2,3,7,8-tetrachlorodibenzo-p-dioxin (TCDD)	EPA 608 (Inf/Eff) SW 8081A Pesticides and SW 8082 PCBs (Sludge) Aldrin/Dieldrin Chlordane (technical Mixture & metabolites) DDT & metabolites Endosulfan & metabolites Endrin & metabolites Heptachlor metabolites Hexachlorocyclohexane Polychlorinated biphenyls (PCBs) Toxaphene Mirex ^b Methoxychlor ^b	EPA 200.8 (Inf/Eff) SW 6020 (Sludge) Antimony Arsenic Beryllium Cadmium Chromium Copper Lead Molybdenum Nickel Silver Selenium Thallium Zinc EPA 245.1 (Inf/Eff) SW7471A/B (Sludge) Mercury SM 4500-CN-E (Inf/Eff) EPA 9010B Mod (Sludge) Cyanide

Inf Influent

Eff Effluent

^a "EPA" refers to the EPA document *Methods for Chemical Analysis of Water and Wastes*, revised March 1983, Document No. EPA-600/4-79-020 or 40 CFR 136; "SW" refers to the EPA Manual SW 846, *Test Methods for Evaluating Solid Waste*. 3rd Ed., 1986.

^b Included with expanded method analyte list.

Table 4. Preservation and Analytical Procedures for Influent, Effluent, and Sludge.

Parameter	Sample Type	Preservation	Maximum Holding Time	Method ^a
Temperature	Inf/Eff	None required	Analyze immediately	SM 2550B
pH	Inf/Eff	None required	Analyze immediately	SM 4500-H ⁺ B
BOD ₅	Inf/Eff	Cool, ≤6°C	48 hours	SM 5210B
Total Residual Chlorine	Eff	Fill completely	Analyze immediately	Hach 8167
DO Electrode	Eff	None required	Analyze immediately	SM 4500-O G
Suspended solids	Inf/Eff	Cool, ≤6°C	7 days	EPA 160.2
Total solids	Sludge	Cool, ≤6°C	7 days	SM 2540G
Enterococci	Inf/Eff	Cool, ≤6°C, Na ₂ S ₂ O ₃ in effluent	24 hours	SM 9230C
Asbestos	Inf/Eff	Cool, ≤6°C, dark	Filter within 48 hours of receipt at lab	EPA 100.1/100.2
	Sludge	Cool, ≤6°C	28 days	Polarized Light Microscopy (PLM)
Fecal Coliform Bacteria	Eff	Cool, ≤6°C 0.008% Na ₂ S ₂ O ₃	6 hours	SM 9221E
Total Ammonia as N	Eff	Cool, ≤6°C, H ₂ SO ₄ to pH <2	28 days	Hach 8038
Total Hydrocarbons as Oil and Grease	Inf/Eff	Cool, ≤6°C 4EC, dark HCl to pH<2	28 days	EPA 1664 HEM ^b
Volatile Organics	Inf/Eff	Cool, ≤6°C, dark, HCL to pH<2 L- Ascorbic Acid in effluent	14 days	EPA 624
	Sludge	Cool, ≤6°C	14 days	SW 8260B
Dioxins	Inf/Eff	Cool, ≤6°C	30 days until extraction/45 days after extraction	SW 8280A
	Sludge	Cool, ≤6°C	30 days until extraction/45 days after extraction	SW 8280A
Semi-Volatile Organics	Inf/Eff	Cool, ≤6°C, dark L- Ascorbic Acid in effluent	7 days until extraction/40 days after extraction	EPA 625
	Sludge	Cool, ≤6°C	14 days until extraction/40 days after extraction	SW 8270C
Pesticides & PCBs	Inf/Eff	Cool, ≤6°C, L- Ascorbic Acid in effluent	7 days until extraction/40 days after extraction	EPA 614 and EPA 608
	Sludge	Cool, ≤6°C	14 days until extraction/40 days after extraction	SW 8141A/8081A SW 8082

Table 4. Preservation and Analytical Procedures for Influent, Effluent, and Sludge.
(continued)

Parameter	Sample Type	Preservation	Maximum Holding Time	Method ^a
Cyanide (total)	Inf/Eff	Cool, ≤6°C, NaOH to pH>12, 0.6 g L- Ascorbic acid (in effluent)	14 days	SM 4500 CN,E Mod
	Sludge	Cool, ≤6°C	14 days	EPA 9010B Mod
Antimony	Inf/Eff	Cool, ≤6°C, HNO ₃ to pH<2	6 months	EPA 200.8
	Sludge	Cool, ≤6°C	6 months	EPA 6020
Arsenic	Inf/Eff	Cool, ≤6°C, HNO ₃ to pH<2	6 months	EPA 200.8
	Sludge	Cool, ≤6°C	6 months	EPA 6020
Beryllium	Inf/Eff	Cool, ≤6°C, HNO ₃ to pH<2	6 months	EPA 200.8
	Sludge	Cool, ≤6°C	6 months	EPA 6020
Cadmium	Inf/Eff	Cool, ≤6°C, HNO ₃ to pH<2	6 months	EPA 200.8
	Sludge	Cool, ≤6°C	6 months	EPA 6020
Chromium	Inf/Eff	Cool, ≤6°C, HNO ₃ to pH<2	6 months	EPA 200.8
	Sludge	Cool, ≤6°C	6 months	EPA 6020
Copper	Inf/Eff	Cool, ≤6°C, HNO ₃ to pH<2	6 months	EPA 200.8
	Sludge	Cool, ≤6°C	6 months	EPA 6020
Lead	Inf/Eff	Cool, ≤6°C, HNO ₃ to pH<2	6 months	EPA 200.8
	Sludge	Cool, ≤6°C	6 months	EPA 6020
Mercury	Inf/Eff	Cool, ≤6°C, HNO ₃ to pH<2	28 days	EPA 245.1
	Sludge	Cool, ≤6°C	28 days	SW 7471A/B
Molybdenum	Inf/Eff	Cool, ≤6°C, HNO ₃ to pH<2	6 months	EPA 200.8
	Sludge	Cool, ≤6°C	6 months	EPA 6020
Nickel	Inf/Eff	Cool, ≤6°C, HNO ₃ to pH<2	6 months	EPA 200.8
	Sludge	Cool, ≤6°C	6 months	EPA 6020
Selenium	Inf/Eff	Cool, ≤6°C, HNO ₃ to pH<2	6 months	EPA 200.8
	Sludge	Cool, ≤6°C	6 months	EPA 6020
Silver	Inf/Eff	Cool, ≤6°C, HNO ₃ to pH<2	6 months	EPA 200.8
	Sludge	Cool, ≤6°C	6 months	EPA 6020
Thallium	Inf/Eff	Cool, ≤6°C, HNO ₃ to pH<2	6 months	EPA 200.8
	Sludge	Cool, ≤6°C	6 months	EPA 6020
Zinc	Inf/Eff	Cool, ≤6°C, HNO ₃ to pH <2	6 months	EPA 200.8
	Sludge	Cool, ≤6°C	6 months	EPA 6020

^a Unless noted, "EPA" refers to *Methods for Chemical Analysis of Water and Wastes*, 1983, EPA-600/4-79-020 or 40 CFR 136; "SM" refers to *Standard Methods for the Examination of Water and Wastewater*, 20th Ed., 1998. "SW" refers to SW 846, *Test Methods for Evaluating Solid Waste*. 3rd Ed., 1986.

^b EPA, 1999a. Document No. EPA-821-R-98-002.

Initial WET testing was performed as a screening period over the course of three quarters during each of which three toxicity tests were performed; each with one vertebrate and two invertebrate species. These screening tests were performed during the third and fourth quarters of 2000 and the first quarter of 2001. Screening included the vertebrate *Atherinops affinis* (topsmelt) for survival and growth; an invertebrate bivalve species (either *Mytilus* spp. [mussel; survival and growth] or *Crassostrea gigas* [oyster; larval development]; and an invertebrate echinoderm species fertilization test (*Strongylocentrotus purpuratus* [purple urchin] or *Dendraster excentricus* [sand dollar]). Once the initial screening period was completed, the single most sensitive species (bivalve) was used for subsequent toxicity testing until re-screening was performed again. As required by the permit, re-screening must be performed each year during one quarter (different than the previous year) to determine the most sensitive species to use for continued testing. Re-screening was performed in the second quarter of 2002 and the third quarter of 2003, with bivalves again found to be the most sensitive species. Re-screening that was performed from 2004 through 2009 found the purple sea urchin to be the most sensitive species.

Accelerated testing requirements will be triggered if chronic toxicity is greater than 143 TUC (chronic toxicity units, $TUC = 100 / \text{No Observed Effect Concentration [NOEC]}$). Accelerated testing will include the implementation of the initial investigation Toxicity Reduction Evaluation (TRE) workplan along with at least one additional toxicity test. If the investigation indicates the source of toxicity (e.g., a plant upset), and no toxicity greater than 143 TUC is observed in this test, the normal schedule of testing will be re-instated. If toxicity greater than 143 TUC is observed, then accelerated testing will continue with six more tests performed on a biweekly basis over a 12-week period. Testing will commence within two weeks of receipt of the sample results of the exceedance. If no toxicity greater than 143 TUC is observed in these tests, then the normal schedule of testing will be re-instated. If toxicity greater than 143 TUC is observed in any of the six tests, then a TRE will be initiated within 15 days of receipt of the sample results of the exceedance. A Toxicity Identification Evaluation (TIE) may also be initiated as part of the overall TRE process, and if this is initiated during the accelerated testing period, the accelerated testing schedule may be terminated or used as necessary in performing the TIE.

Toxicity testing was performed as described in Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms (EPA, 1988) and the 'West Coast Marine Methods Manual', First Edition (EPA, 1995) as required by the permit. The presence of chronic toxicity was estimated as described by these references. Quality assurance for the toxicity testing included the testing of a series of five dilutions and a control, including the concentration of the effluent at the edge of the ZID (0.70 %) as well as two dilutions above and two dilutions below 0.70 %. Reference toxicants were tested concurrently with the effluent testing, using the same procedures. If the effluent tests did not meet all the acceptability criteria as specified in the referenced methods, then the effluent was re-sampled and re-tested as soon as possible. Control and dilution water was natural or synthetic seawater as called for by the referenced methods. If the dilution water was different from the culture water, a second control using culture water will be run. Dilution water met test acceptability criteria.

As part of the WET testing, an initial investigation TRE plan was prepared and submitted to EPA under separate cover (Kinnetic Laboratories, Inc., 2000b). This plan describes the events that will occur should chronic toxicity be detected. As required by the permit and the manual Toxicity Reduction Evaluation Guidance for Municipal Wastewater Treatment Plants (EPA, 1999b), a preliminary TRE will be initiated within 15 days of the receipt of sample results of the

permit exceedance. A more detailed TRE workplan will subsequently be developed to more fully investigate and identify the cause of the toxicity, identify and provide a schedule of the actions that AWWU will use to mitigate the impact of the discharge, and to prevent the recurrence of the toxicity. As noted above, the TIE may be initiated as part of the overall TRE process during the accelerated testing schedule.

2.1.5 Part 503 Sludge Monitoring

Operations at the Asplund WPCF include a sludge incinerator that is subject to regulation under 40 CFR Part 503 - Standards for the Use or Disposal of Sewage Sludge. The current NPDES permit requires sludge monitoring twice per year, once during summer dry conditions and once during summer wet conditions as noted earlier. There are no Part 503 monitoring requirements included in the reissued NPDES permit because EPA Region 10's current policy is to remove these requirements from NPDES permits with the intention of writing "sludge only" permits in the future. However, the Part 503 regulations are "self-implementing" in that the facility is required to meet the monitoring requirements in the regulation whether they are specifically included in a permit or not. Therefore, monitoring at the Asplund WPCF includes Part 503 monitoring of sludge. Monitoring frequencies required by 40 CFR Part 503 for incineration are once per 60 days for arsenic, cadmium, chromium, lead, and nickel. Frequency required for mercury is at least once per year. Frequency for beryllium is not specified. AWWU has chosen to also test for mercury and beryllium once per 60 days, more frequently than required, so as to be consistent with the testing frequency for the other metals. Allowable limits are site-specific and were re-calculated per Part 503 regulation in May 2008 by CH2M Hill based on 2007 data (CH2M Hill, 2008). While methods for this monitoring component have been described elsewhere (AWWU, 2000) and results of the monitoring have been provided under separate reporting requirements to EPA, the data are also included in this report.

2.2 RECEIVING WATER QUALITY MONITORING

2.2.1 Water Quality Sampling

As required by the permit, water quality must be monitored annually during the summer in dry weather conditions (Table 1). Sampling was performed at non-fixed stations made during consecutive ebb and flood tides at the outfall station and a single flood tide at the control station. Station locations were determined by following the

- | | |
|---|---|
| ✓ | determine compliance with the NPDES permit and State of Alaska water quality criteria |
| ✓ | aid in assessing the water quality at the discharge point |
| ✓ | determine compliance with the regulatory criteria of Section 301(h) for the CWA |
| ✓ | determine the level of bacterial contamination in nearshore waters |
| ✓ | provide data for evaluation of permit re-issuance |

track of drogues released above the diffuser at the outfall station and at the control station located north across Knik Arm from Point Woronzof, directly off Point MacKenzie in a similar water depth as the outfall. Three drogue tracks on each tide were performed at each location. Four stations were sampled on each drogue track released at the outfall as follows:

- above the diffuser
- as close to the ZID boundary as practicable
- at least one nearfield station along the drogues path near the ZID
- in the shallow subtidal area before the drogue grounds or along the drogues path at a farfield location.

As noted in the permit, the ZID is defined as the water column above the area delineated by the sector of a circle with the center located over the outfall, 30 meters (m) shoreward of the diffuser, 650 m in radius, and with a 220° angle (Figure 3).

The plume location was determined by following a holey-sock current drogue (Figure 4). The drogue consisted of a six-foot cylindrical nylon tube ballasted at the bottom with a two-pound weight and attached at the top with a bridle to a spherical float. This float was attached to the tracking spar via a connecting line. These cylindrical or spherical designs that enclose a parcel of water have been found to more accurately follow the ambient current patterns than other drogue designs such as the window shade design (Sombardier and Niiler, 1994).

Sampling was performed by positioning the vessel over the diffuser (or control station) for the first sampling station of the drogue track. The drogue was released at approximately the same time and followed until navigation information indicated that the ZID had been reached, at approximately 650 m from the outfall, at which time the ZID boundary station was sampled. The third and fourth stations along each drogue track were sampled as the drogue traveled through the channel in Knik Arm or as it slowed in shallow water prior to grounding. Navigation was accomplished using a differential global positioning system (DGPS). If DGPS coordinates were unavailable, standard GPS coordinates were recorded and noted on the appropriate log.

Samples were collected for the parameters outlined in Table 5. The surface waters of all stations were sampled for fecal coliform, color, turbidity, and TRC. Surface samples were collected by grabbing directly into the appropriate sample bottles at sample depth (15 - 30 centimeters [cm]). Mid- and bottom depth turbidity samples were collected at all stations using Niskin[®] bottles. Mid- and bottom depths were determined at each station using the survey vessel's fathometer. Samples were collected as simultaneously as possible at all three target depths. Hydrographic profiles of temperature, salinity, DO, and pH were collected at all stations using a Seabird SEACAT[®] SBE-19 CTD (conductivity, temperature, and depth) recorder. This instrument was also equipped with a DO, pH, and optical backscatter (turbidity) sensors to allow profiles of these parameters to be recorded. Samples for the analysis of total and dissolved metals, TSS, hydrocarbons (PAH), and total volatile aromatic hydrocarbons (TAH) were collected from surface waters at the first three stations (diffuser, ZID boundary, and channel) along the first flood drogue track at both the outfall and control stations. These samples were collected directly into the appropriate sample containers. A single replicate sample for each parameter or a single profile was collected at each station except for quality control samples, which are described in Section 4.2.

Samples were analyzed following the methods provided in Table 6. Samples were appropriately labeled at time of collection using pre-prepared, project-specific sample labels as described in Section 2.5 and prepared for shipment to the laboratory. Preservation and maximum holding time information for each of these methods is also provided in Table 6. All sample containers were immediately placed on gel ice after sampling. Samples remained chilled as required during shipment to the analytical laboratory.

2.2.2 Intertidal Bacterial Sampling

As part of the receiving water quality monitoring effort, intertidal sampling for fecal coliform bacteria was also performed at eight stations shown in Table 7 and depicted in Figure 3. Two

Figure 3. Asplund WPCF Outfall, ZID, and Locations of Intertidal Bacteriological Sampling.




Figure 4. Holey-Sock Drogue, Flotation, and Marker Buoy.

Table 5. Receiving Water Quality Monitoring Requirements.

Parameter	Sampling Depth		
	Surface (above 0.5 m)	Surface, Mid-, and Bottom	Profile (1- to 3-m intervals)
Fecal Coliform	all stations ^a , within the 15-30 cm layer		
Color	all stations, within the 15-30 cm layer		
Total Residual Chlorine (TRC)			
Field Observations: presence or absence of floating solids, visible foam (other than trace), oil wastes, and/or sheen	all stations where surface samples are collected		
Total Aqueous Hydrocarbons (TAqH)	first three stations along the first flood drogue track at both the outfall and control locations		
Total Aromatic Hydrocarbons (TAH)			
Metals and Cyanide ^b			
Total Suspended Solids (TSS)			
Turbidity		all stations	
pH			all stations
Temperature			
Dissolved Oxygen (DO)			
Salinity			

^a Non-fixed stations were sampled following the track of drogues released at the diffuser (outfall station) or at a fixed station having the same depth due north across Knik Arm from Point Woronzof near Point MacKenzie (control station). Three drogue tracks were made during each of a consecutive flood and ebb tide at the outfall station. Stations included the following along each outfall drogue track: above the diffuser; as close to the ZID boundary as practicable; one near-field station in the channel of Knik Arm; and a far-field station along the drogue path or in the shallow subtidal area before the drogue grounds. Three drogue tracks were also made during a flood tide at the control station in conjunction with or as soon as practicable as the sampling at the outfall station.

^b Metals include arsenic, cadmium, chromium, copper, lead, mercury, nickel, silver, and zinc; these were analyzed and reported as both total recoverable and dissolved metals.

Table 6. Methods, Preservation, and Maximum Holding Times for the Analysis of Receiving Water Quality Samples.

Parameter	Method ^a	Preservation	Maximum Holding Time
Fecal Coliform	SM 9221E	Cool, 6°C, dark	24 hours
Color	SM 2120B	Cool, 6°C, dark	48 hours
Total Residual Chlorine (TRC)	SM 4500-Cl G	None	Analyze immediately
Turbidity	SM 2130B	Cool, 6°C, dark	24 hours
Total Aqueous Hydrocarbons (TAqH)	EPA 602 plus xylenes	Cool, 6°C, HCl to pH<2, L- Ascorbic Acid in presence of chlorine	14 days
	EPA 610	Cool, 6°C, dark, L- Ascorbic Acid in presence of chlorine	7 days until extraction/ 40 days after extraction
Total Aromatic Hydrocarbons (TAH)	EPA 602	Cool, 6°C, HCl to pH<2 L- Ascorbic Acid in presence of chlorine	14 days
Metals (Total Recoverable and Dissolved)	See note ^b	Cool, 6°C, HNO ₃ to pH <2 (after filtration for dissolved)	90 days – Hg 180 days – all others
Cyanide	EPA 335.2	NaOH, 6°C	14 days
Total Suspended Solids (TSS)	EPA 160.2	Cool, 6°C	7 days
Dissolved Oxygen (DO)	SM 4500-O G (electrode)	None	<i>in situ</i>
pH	SM 4500-H ⁺ B	None	<i>in situ</i>
Temperature	SM 2550B ^c	None	<i>in situ</i>
Salinity	SM 2520B ^c	None	<i>in situ</i>

^a "EPA" refers to the EPA document *Methods for Chemical Analysis of Water and Wastes*, revised March 1983, Document No. EPA-600/4-79-020, or 40 CFR 136. "SM" refers to *Standard Methods for the Examination of Water and Wastewater*, 20th ed., 1998.

^b Dissolved metals were filtered before acidification; total recoverable metals were digested by ASTM Method D4309-91. Cadmium, chromium, copper, nickel, lead, silver and zinc were subject to pre-concentration by chelation following EPA Method 1640 prior to analysis by inductively coupled plasma mass spectroscopy. These metals, along with antimony, beryllium, selenium, and thallium, were analyzed as total recoverable and dissolved metals as appropriate for ICP/MS (EPA Method 1638). Mercury was analyzed using cold vapor atomic fluorescence following EPA Method 1631. Arsenic was determined by flame ionization atomic spectroscopy (SW846 Method 7062).

^c Modified for *in situ* measurements collected with the CTD.

Table 7. Approximate Locations of Intertidal Bacteria Sampling Stations.

Station	Station Location Relative to Diffuser	Latitude (N)	Longitude (W)
IT-1	2000 m east	61° 12' 10"	149° 58' 55"
IT-2	1200 m east	61° 12' 11"	149° 59' 50"
IT-3	750 m east	61° 12' 15"	150° 00' 20"
IT-4	250 m east	61° 12' 19"	150° 00' 52"
IT-5	250 m southwest	61° 12' 15"	150° 01' 10"
IT-6	750 m southwest	61° 12' 02"	150° 01' 28"
IT-7	2000 m southwest	61° 11' 22"	150° 02' 02"
IT-C	Across Knik Arm from the diffuser	61° 14' 26"	150° 01' 09"

replicate water samples were collected from each station at slack high water when the water depths were between 1 to 3 feet (ft). Additional quality control samples were collected as described in Section 4.2. Surface samples were collected by grabbing from 15 - 30 cm depths directly into the appropriate container. Samples were analyzed using the same procedures described previously and in Table 6.

In addition to the required intertidal samples, two replicated fecal coliform samples were also collected once during the water quality monitoring effort from three area streams that empty into Knik Arm: Ship, Chester, and Fish Creeks. Samples were analyzed using the same procedures described previously and in Table 6.

At time of collection, all fecal coliform samples were appropriately labeled using pre-prepared, project-specific sample labels as described in Section 2.5. All samples were collected in the appropriate precleaned sample containers, dechlorinated, and preserved, if necessary, as described by the method. Samples were placed on gel ice immediately after sampling and remained chilled during transport to the laboratory. Field notes, including navigational and sampling information, were recorded on project-specific field logs. As required by the permit, field observations taken at each station included the presence or absence of floating solids, visible foam in other than trace amounts, oily wastes, or sheen. Weather observations were also recorded. All field documentation was reviewed by the field leader at the completion of the survey for accuracy and completeness. Sample collection and shipment was documented using project-specific chain of custody forms as described in Section 2.5.

2.2.3 Vessel Support

The *NORTH FORTY*, a 26-ft KLI-owned survey vessel, was used for drogue tracking and water sampling in 2009. In addition, a 15-ft Zodiac[®] was used to retrieve grounded drogues and conduct intertidal bacteria sampling. The Zodiac[®] was also used to transport samples with short holding times (i.e., bacterial and turbidity samples) ashore.

2.3 SEDIMENT AND BIOACCUMULATION MONITORING

As stipulated in the NPDES permit, sediment and bioaccumulation monitoring was to be performed during the fourth year after the effective date of the permit. Accordingly, the intertidal and subtidal sediment sampling was performed in conjunction with the 2003 receiving water monitoring sampling and the bioaccumulation sampling was performed during 2004.

2.4 LABORATORY ANALYSIS

Laboratory analyses of all samples for this program followed preservation and analysis procedures described by EPA-accepted protocols as referenced in this document (Table 4 and Table 6). These procedures are fully described by the referenced documents and/or 40 CFR 136.

2.5 DOCUMENTATION PROCEDURES

All field and sampling data were recorded on appropriate pre-printed project-specific field data forms. Field data forms included drogue tracking forms, water sampling log forms, sample identification/chain of custody forms, and sample labels. These forms were tailored to the monitoring program to facilitate accurate and complete documentation of field activities. The field task leader was responsible for review and approval of all field documentation; this was completed as soon as possible after sampling.

Sampling logs included specific information such as station identification, sample identification numbers, navigational data, sampling or photographic observations, sampling depths, and collection date and time. Names of personnel performing the sampling were recorded on each log. Drogue tracking logs included station identification information along with navigational data to allow the track of each drogue to be later determined and plotted. Pre-printed labels included such information as station designation, analysis type, date of collection, sampling personnel, and a pre-assigned sample identification number to uniquely identify each sample. Quality control samples were labeled as were regular environmental samples so as to be blind to the laboratory analysts.

Sample identification and integrity was ensured by a rigidly-enforced chain of custody program. Sample identification/chain of custody (COC) forms provided specific information concerning the identification, handling, and shipment of samples.

Pertinent information from the sample label was transferred onto the COC, along with other information as required. COC forms were completed, signed by field personnel, and copied if needed. In some cases, where photocopying was not convenient or possible, two-part carbonless forms were used. The original of each COC form was packed with the samples in coolers for shipment to the laboratory. The field task leader retained a copy of each form for the field records and for tracking purposes should a shipment become lost or delayed. Upon receipt of the samples at the analytical laboratory, the laboratory sample custodian signed the samples in by checking all sample labels against the COC information and noting any discrepancies as well as sample condition (e.g., sample temperature, containers leaking or damaged during shipment). Internal sample tracking procedures at the laboratory were initiated immediately upon receipt of samples as described by each laboratory's standard operating procedures.

3.0 RESULTS

3.1 INFLUENT, EFFLUENT, AND SLUDGE MONITORING

3.1.1 Monthly Discharge Monitoring Data

Results of AWWU's daily, weekly, and monthly sampling of influent and effluent for non-metals are presented as monthly summaries in Table 8. Averages are based on the 12-month period from January through December 2009.

The removal of BOD₅ as determined by subtracting the effluent from the influent divided by the influent $[(\text{Inf}-\text{Eff})/\text{Inf} \times 100]$ averaged 47 %, and removal of TSS averaged 76 % for the 12-month reporting period. These averages exceed the minimum values required by the amendments to the CWA (40 CFR Part 125.60; Final Rule, 8/9/94), whereby dischargers with 301(h) variances are required to remove 30 % of BOD₅ and 30 % of the suspended solids. On a monthly average basis, the removal of BOD₅ ranged from 43 to 52 % removal with all values within permit limits in 2009. The highest monthly average effluent BOD₅ was 145 mg/L, substantially less than the permit limitation of 240 mg/L. All of the BOD₅ values (daily, weekly, and monthly averages) reported for the calendar year 2009 met the permit limitations. Total suspended solids concentrations in the effluent were low and typical of those seen historically at the Asplund WPCF with the highest monthly average effluent concentration of 63 mg/L compared to the permit limit of 170 mg/L. The yearly average effluent TSS was 56 mg/L. Weekly average and daily maximum TSS also met permit requirements.

The highest mean monthly fecal coliform bacteria count was 30 FC MPN/100 mL seen in April 2009. All of the months in 2009 met the permit limitation of 850 FC MPN/100 mL based on a geometric mean of at least five samples, which ranged from 5 to 30 FC MPN/100 mL, well below the permit limitation. The criterion of not more than 10 % of the samples analyzed should exceed 2,600 FC MPN/100 mL was also met for every month in 2009. Better plant performance was seen in 2009 in terms of affective chlorination and fecal coliform bacteria concentrations than in some prior years.

The TRC daily maximum concentration did not exceed the permit-required limitation of 1.2 mg/L for the entire year, with a maximum daily value of 1.05 mg/L and a monthly maximum range of 0.36 to 1.05 mg/L. The monthly averages of TRC concentrations ranged from 0.24 to 0.52 mg/L, with an overall annual average of 0.34 mg/L. The permit requirement that effluent pH remain between 6.5 and 8.5 standard units was always met, exhibiting a minimum and maximum range of 6.5 to 7.4 pH units for the year.

Although other parameters such as DO, temperature, and ammonia do not have permit limitations, ranges were typical of those seen historically. DO in the effluent exhibited monthly averages ranging from 1.3 to 4.3 mg/L, with a yearly average of 2.8 mg/L which was similar to that seen in 2008 where the yearly average was 2.9 mg/L. Temperature showed yearly averages of 11.7 and 12.2 °C in the influent and effluent, respectively. Monthly values for total ammonia in effluent ranged from 18.2 to 25.8 mg/L, with a yearly average of 21.6 mg/L, similar to that seen historically. Average Plant flow for the year was 28.1 million gallons per day (mgd) which is very similar to the average flow rate seen over the past five years.

Table 8. Discharge Monitoring Data for Influent and Effluent Non-Metals.

Month	Average EFF Flow Rate (MGD)	Temperature Average (°C)		pH Minimum/ Maximum (pH) ^a		TRC Average (mg/L)		DO Average (mg/L)		BOD ₅ Average (mg/L)			Total Susp. Solids Average (mg/L)			Fecal Coliform Average (MPN/100 mL)		Total Ammonia Average (mg/L)	
		INF	EFF	INF	EFF	INF	EFF	INF	EFF	INF	EFF	REM (%)	INF	EFF	REM (%)	INF	EFF	INF	EFF
01/09	30.5	9.5	9.9	6.9/7.6	6.7/7.2	NT	0.52	NT	3.4	202	115	43	187	50	73	NT	9	NT	20.4
02/09	27.8	9.2	9.6	6.6/7.5	6.7/7.4	NT	0.47	NT	3.6	220	117	47	212	53	75	NT	16	NT	19.2
03/09	27.3	9.0	9.4	6.8/7.6	6.7/7.2	NT	0.41	NT	3.6	220	115	48	225	58	74	NT	21	NT	22.5
04/09	30.8	8.9	9.4	6.7/7.7	6.6/7.4	NT	0.38	NT	4.3	172	83	52	242	60	75	NT	30	NT	18.2
05/09	28.4	10.3	10.8	6.6/7.8	6.7/7.2	NT	0.35	NT	3.7	237	131	45	252	63	75	NT	6	NT	22.2
06/09	27.4	12.3	12.5	6.7/7.9	6.5/7.4	NT	0.27	NT	2.3	262	141	46	267	60	78	NT	7	NT	21.8
07/09	27.8	14.6	15.0	7.0/7.6	7.0/7.2	NT	0.24	NT	1.3	263	145	45	261	55	79	NT	5	NT	20.8
08/09	29.3	14.7	15.4	7.1/7.6	6.9/7.3	NT	0.29	NT	1.7	274	143	48	269	59	78	NT	9	NT	21.7
09/09	28.1	14.6	15.2	7.0/7.9	6.9/7.4	NT	0.28	NT	2.6	234	118	50	252	48	81	NT	14	NT	25.8
10/09	27.7	13.8	13.9	7.0/7.8	6.7/7.2	NT	0.34	NT	3.1	244	123	50	246	52	79	NT	9	NT	22.1
11/09	26.1	12.6	13.0	6.7/7.4	6.7/7.2	NT	0.25	NT	1.4	242	133	45	233	57	76	NT	20	NT	20.3
12/09	25.7	11.1	11.7	7.1/7.9	6.7/7.3	NT	0.29	NT	2.8	248	138	44	225	56	75	NT	21	NT	23.6
Average	28.1	11.7	12.2	6.6/7.9	6.5/7.4	---	0.34	---	2.8	235	125	47	239	56	76	---	14	---	21.6

^a Monthly or Yearly (minimum-maximum)

NT Not tested (tested in effluent only)

REM Percent Removal

--- Not applicable

3.1.2 Toxic Pollutants and Pesticides Analyses

Toxic pollutant and pesticide monitoring for influent, effluent, and sludge was conducted on 23 - 24 June 2009 for summer-dry weather and 28 - 29 July 2009 for the summer-wet sampling. Sampling was performed over a 24-hr period by AWWU personnel.

Results of the toxic pollutant and pesticide analyses are provided in Table 9 (June 2009) and Table 10 (July 2009). For semi-volatile organic compounds (EPA Methods 625/8270C), volatile organic compounds (EPA Methods 624/8260B), and pesticides (EPA Methods 608/8081A/8082 and 614/8141A), only those pollutants that were detected in the influent, effluent, or sludge are listed. Refer to Appendices A and B for the laboratory reports and a complete listing of pollutants analyzed. Pollutants found in the influent were usually detected in the effluent, and vice versa. One constituent was only detected in the sludge. In general, pollutant concentrations were very low and many of the concentrations reported for the two samplings were so low that they had to be estimated and below method reporting limits (MRLs).

Percent removal shown in these tables were computed from influent and effluent concentration values. Percent removal was only calculated for compounds where a concentration in the influent and/or effluent was reported at a level above the MDL or MRL. Compounds with estimated concentrations (denoted with a "J" qualifier) were not used for percent removal calculations unless a detected concentration above MRL was reported for that compound in the other type of sample (influent or effluent). The reported MRL was used for calculations where necessary (where a compound was reported as non-detect [ND]). Where several laboratory duplicate analyses were performed for a parameter, a percent removal is provided for each duplicate. For summed values, such as BETX, the MRL was used for values reported as ND.

Calculation of percent removal for some contaminants may not truly be representative of treatment plant efficiency due to several factors that influence the removal values. Most notable is the fact that influent and effluent autosamplers do not produce parallel samples over the same required 24-hour time period due to the approximately 6-hour hydraulic residence time of the wastewater flowing through the treatment process prior to being discharged as final effluent. Also affecting the calculation of percent removal is the addition of more than 1 million gallons of fresh water from the city's drinking water supply and/or on-site well water to the treatment process after the influent autosampler. Additionally, incinerator scrubber water, filtrate from the belt filter presses, scum concentrator return water, and in-plant wash down water are added back into the treatment process which only impacts the effluent composite sample. Often the percent removal calculation is performed on data derived at or below the MDL. In some cases where a contaminant is not detected above the MDL, any comparison of that estimated value to a value that was detected above the MDL is statistically insignificant despite the requirement to report it. As such, calculation of negative removals is possible in spite of all evidence to support an efficient and effective treatment process.

The types and concentrations of measured volatile and semi-volatile organic compounds varied somewhat between the two sampling periods. Compounds that were detected in either the influent or effluent during at least one of the sampling events included: acetone, benzene, benzoic acid, benzyl alcohol, chloroform, 1,4-dichlorobenzene, ethylbenzene, methylene chloride, 3&4 methylphenol (p&m cresol), phenol, tetrachloroethene, toluene, and total xylenes. Many of these compounds were estimated values that were only detected below their reporting limits and therefore were qualified with a J but were generally seen in both the influent and

Table 9. Toxic Pollutants and Pesticides in the Influent, Effluent, and Sludge, Sampled 23 and 24 June 2009.

Pollutant	Influent^a (µg/L)	Effluent^a (µg/L)	Sludge^a (µg/g)	Percent Removal
DISSOLVED METALS				
Antimony	ND(4.55)	ND(1.0)	NT	---
Arsenic	ND(22.7)	ND(5.0)	NT	---
Beryllium	ND(1.82)	ND(0.40)	NT	---
Cadmium	ND(2.27)	ND(0.50)	NT	---
Chromium	ND(9.09)	ND(2.0)	NT	---
Copper	15.2	14.0	NT	8
Lead	ND(0.909)	ND(0.20)	NT	---
Mercury	ND(0.20)	ND(0.20)	NT	---
Molybdenum	ND(45.5)	ND(10.0)	NT	---
Nickel	ND(9.09)	2.94	NT	68
Selenium	ND(22.7)	ND(5.0)	NT	---
Silver	ND(4.55)	ND(1.0)	NT	---
Thallium	ND(4.55)	ND(1.0)	NT	---
Zinc	116	38.4	NT	67
TOTAL METALS				
Antimony	ND(1.0)	ND(1.0)	ND (0.325)	---
Arsenic	ND(5.0)	ND(5.0)	ND (3.25)	---
Beryllium	ND(0.40)	ND(0.40)	1.75	---
Cadmium	ND(0.50)	ND(0.50)	0.664	---
Chromium	3.25	ND(2.0)	122	38
Copper	65.5	48.9	163	25
Lead	5.38	2.35	19.4	56
Mercury	ND(0.20)	ND(0.20)	0.231 ^e	---
Molybdenum	ND(10.0)	ND(10.0)	ND (3.25)	---
Nickel	4.98	3.62	400	27
Selenium	ND(5.0)	ND(5.0)	ND (1.63)	---
Silver	1.85	1.56	0.353	16
Thallium	ND(1.0)	ND(1.0)	ND (0.0650)	---
Zinc	158	97.4	225	38

Table 9. Toxic Pollutants and Pesticides in the Influent, Effluent, and Sludge, Sampled 23 and 24 June 2009. (continued)

Pollutant	Influent^a (µg/L)	Effluent^a (µg/L)	Sludge^a (µg/g)	Percent Removal
VOLATILE ORGANICS– detected substances only				
Benzene	0.220 J	0.240 J	ND (3.43)	---
Chloroform	2.14	3.24	ND (4.17)	-51
Ethylbenzene	2.01	1.18	ND (4.06)	41
Methylene Chloride ^f	12.5	11.0	ND (5.17)	12
Toluene	13.0	8.84	ND (4.01)	32
Xylenes (total)	8.43	3.68	ND (8.60)	56
1,4- Dichlorobenzene	0.770 J	0.790 J	ND (4.17)	---
Tetrachloroethene	1.67	1.14	ND (3.64)	32
SEMI-VOLATILE ORGANICS – detected substances only				
Benzoic acid	510	241	ND (754)	53
Benzyl alcohol	ND (101)	28.4	ND (126)	72
3&4- Methylphenol (p&m-cresol)	ND (202)	119	ND (503)	41
Phenol	ND (101)	18.1	ND (126)	82
HYDROCARBONS				
Oil & Grease (EPA 1664-HEM)	66100	37600	NT	43
Total Aromatic Hydrocarbons as BETX from EPA Method 624	23.7	13.9	ND (16.67)	41

Table 9. Toxic Pollutants and Pesticides in the Influent, Effluent, and Sludge, Sampled 23 and 24 June 2009. (continued)

Pollutant	Influent ^{a,b} (µg/L)	Effluent ^{a,b} (µg/L)	Sludge ^a (µg/g)	Percent Removal
PESTICIDES – detected substances only				
4,4'-DDT	0.20 P / 0.21 P	0.25 P	0.280	-25 / -19
ENTEROCOCCI BACTERIA				
Enterococci ^c	NT	<2/<2/<2/<2	NT	---
OTHER COMPONENTS				
Asbestos ^d	ND (<1.395)	ND (<0.697)	ND	---
Cyanide	ND (5.0)	ND (5.0)	ND (0.72)	---
Dioxin (2,3,7,8-TCDD)	ND (0.00103)	ND (0.00102)	ND (0.000341)	---

- a* Detection limits or reporting limits are included in parentheses for non-detected (ND) values
b Duplicate field sample analysis or duplicate laboratory analysis provided (value/duplicate value)
c Enterococci reported in MPN/100 ml; two replicates- (sample and duplicate).
d Asbestos reported in million fibers/L (influent and effluent) and present or none detected (sludge).
e Result from May 503 metals sampling.
f Also present in trip blank.
P More than 40% RPD between primary and confirmation column results. The higher of the two results is reported.
J Estimated value (below MRL but above MDL)
--- Not applicable (not calculated)
ND None detected
NT Not tested

Table 10. Toxic Pollutants and Pesticides in the Influent, Effluent, and Sludge, Sampled 28 and 29 July 2009.

Pollutant	Influent^a (µg/L)	Effluent^a (µg/L)	Sludge^a (µg/g)	Percent Removal
DISSOLVED METALS				
Antimony	ND (1.0)	ND (1.0)	NT	---
Arsenic	ND (5.0)	ND (5.0)	NT	---
Beryllium	ND (0.40)	ND (0.40)	NT	---
Cadmium	ND (0.50)	ND (0.50)	NT	---
Chromium	ND (2.0)	ND (2.0)	NT	---
Copper	19.3	26.8	NT	-39
Lead	0.705	0.917	NT	-30
Mercury	ND (0.20)	ND (0.20)	NT	---
Molybdenum	ND (10.0)	ND (10.0)	NT	---
Nickel	2.72	2.77	NT	-2
Selenium	ND (5.0)	ND (5.0)	NT	---
Silver	ND (1.0)	ND (1.0)	NT	---
Thallium	ND (1.0)	ND (1.0)	NT	---
Zinc	24.3	58.4	NT	-140
TOTAL METALS				
Antimony	ND (1.0)	ND (1.0)	1.75	---
Arsenic	ND (5.0)	ND (5.0)	4.00	---
Beryllium	ND (0.40)	ND (0.40)	ND (0.326)	---
Cadmium	ND (0.50)	ND (0.50)	1.29	---
Chromium	ND (2.0)	ND (2.0)	12.2	---
Copper	32.6	34.9	231	-7
Lead	1.61	1.80	19.2 B	-12
Mercury	ND (0.20)	ND (0.20)	0.509 ^e	---
Molybdenum	ND (10.0)	ND (10.0)	5.97	---
Nickel	2.79	2.98	13.9	-7
Selenium	ND (5.0)	ND (5.0)	2.23	---
Silver	ND (1.0)	ND (1.0)	6.31	---
Thallium	ND (1.0)	ND (1.0)	ND (0.065)	---
Zinc	62.7	81.4	595 B	-30

Table 10. Toxic Pollutants and Pesticides in the Influent, Effluent, and Sludge, Sampled 28 and 29 July 2009. (continued)

Pollutant	Influent^a (µg/L)	Effluent^a (µg/L)	Sludge^a (µg/g)	Percent Removal
VOLATILE ORGANICS– detected substances only				
Acetone ^f	160	100	7.0	38
Benzene	ND (5.0)	ND (5.0)	ND (0.250)	---
Chloroform	3.2 J	2.0 J	ND (0.500)	---
1, 4-Dichlorobenzene	0.61 J	0.68 J	ND (0.250)	---
Ethylbenzene	ND (5.0)	ND (5.0)	ND (0.250)	---
Methylene chloride ^f	6.8	4.2 J	ND (0.250)	38
Tetrachloroethene	ND (5.0)	ND (5.0)	0.035 J	---
Toluene	6.6	5.5	0.350	17
Xylenes (total)	ND(10)	1.7 J	0.086 J	---
SEMI-VOLATILE ORGANICS– detected substances only				
Benzoic acid	148	141	ND (615)	5
Benzyl alcohol	25.5	25.8	ND (103)	-1
3&4-Methylphenol (p&m Cresol)	58.2	78.1	ND (410)	-34
Phenol	28.2	ND (10.2)	ND (103)	64
HYDROCARBONS				
Oil & Grease (EPA 1664-HEM)	85200	64900	NT	24
Total Aromatic Hydrocarbons as BETX from EPA Method 624	26.6	17.2	0.936	35

Table 10. Toxic Pollutants and Pesticides in the Influent, Effluent, and Sludge, Sampled 28 and 29 July 2009. (continued)

Pollutant	Influent ^a (µg/L)	Effluent ^{a,b} (µg/L)	Sludge ^a (µg/g)	Percent Removal
PESTICIDES – detected substances only				
beta-BHC	ND (0.010)	0.014 P	ND (0.0084)	---
Dieldrin	0.014 P	ND (0.010)	ND (0.0084)	---
4,4'-DDE	ND (0.010)	0.010	ND (0.0084)	0
ENTEROCOCCI BACTERIA				
Enterococci ^c	NT	<2/<2/<2/<2	NT	---
OTHER COMPONENTS				
Asbestos ^d	ND (<24.70)	ND (<12.30)	ND	---
Cyanide	ND (5.0)	16	1.2	-220
Dioxin (2,3,7,8-TCDD)	ND (0.00102)	ND (0.00102)	ND (0.000126)	---

a Detection or reporting limits are included where possible in parentheses for non-detected (ND) values

b Duplicate field sample analysis or duplicate laboratory analysis provided (value/duplicate value)

c Enterococci reported in MPN/100 mL

d Asbestos reported in million fibers/L (influent and effluent) and present or none detected (sludge)

e Result from August 503 metals sampling.

f Also present in trip blank.

--- Not applicable (not calculated)

J Estimated value (below MRL but above MDL)

B Method blank contamination.

P More than 40 % RPD between primary and confirmation columns results. [The higher of the two results is reported.]

ND None detected

NT Not tested

effluent samples. Although not detected in the laboratory method blanks, methylene chloride is a common laboratory contaminant that was also detected in the trip and field blanks during both June and July. Trace levels of bromodichloromethane, chloroform, toluene, and total xylenes were also seen in the June field blank. No organic compounds were seen in the sludge during the June 2009 sampling effort. In July 2009, of those compounds that were detected in either the Influent or effluent, acetone, toluene, and total xylenes were also seen in the sludge. The July sludge sample also had detected concentrations of tetrachloroethene. Several of the sludge concentrations were estimated and qualified with a J as they fell below MRLs.

Oil and grease concentrations measured in the influent and effluent in 2009 using EPA 1664A HEM were similar though slightly elevated to those seen in 2003 through 2008 with effluent concentrations of 38 and 65 mg/L during the June and July sampling, respectively. Oil and grease effluent values from 2003 and 2008 ranged from 15-35 mg/L. Effluent BETX values as measured by EPA 624 were 13.9 and 17.2 µg/L in the June and July 2009 samplings, respectively. Total aromatic hydrocarbons as BETX (EPA 602) were also sampled in the effluent as part of the receiving water program in June and were measured at 14.4 µg/L. Refer to Sections 5.1 and 5.2 for further discussion of the significance of the total hydrocarbon values.

The AWQS have site-specific criteria for the Point Woronzof area and also include State wide criteria that are based on dissolved metals. These AWQS were utilized to determine the MAEC (defined as the value specified as the receiving water limit and/or the permit limit multiplied by the initial dilution of 142:1 for conservative substances and 180:1 for non-conservative substances (TRC, ammonia, cyanide, TAH, and TAqH) after taking into account the natural background concentration). Both total and dissolved concentrations of metals in the effluent were then compared to the MAECs.

Total recoverable metals concentrations in both the influent and effluent were found to be low. Influent and effluent concentrations of total antimony, arsenic, beryllium, cadmium, mercury, molybdenum, selenium, and thallium were all below detection limits during both sampling periods. Other total recoverable metals such as, chromium, copper, lead, nickel, and zinc were seen in the influent or effluent during both sampling events and silver during one sampling event, but at very low levels when compared to their respective MAECs.

Dissolved metals concentrations were also found to be low. Dissolved antimony, arsenic, beryllium, cadmium, chromium, mercury, molybdenum, selenium, silver, and thallium were all below MRLs for both influent and effluent for both sampling periods. Dissolved copper, lead, nickel and zinc were above detection limits in either influent or effluent during at least one of the sampling events. The concentration for dissolved copper in effluent was found to be the highest of any of the metals with respect to its MAEC of 317 µg/L, with a level of 27 µg/L during the July sampling. While dissolved copper was found to be the highest metal detected in the effluent with respect to its MAEC, it was still over an order of magnitude less than the MAEC.

Few pesticides were detected in the influent, effluent, or sludge during the June or July 2009 sampling events. During the June sampling, 4,4'-DDT was detected in the influent, effluent and sludge. During the July sampling, dieldrin was detected in the influent sample, and beta-BHC was detected in the effluent. 4,4'-DDE was quantified at the detection limit in the July effluent sample. No pesticide compounds were detected in the July sludge. The source of these pesticides is unknown since DDTs and beta-BHC a by product produced in the manufacture of lindane have not been manufactured, used, or sold in U.S. for over 20 years. No PCBs were

detected in either the June or July sampling events. For a complete list of the various chlorinated organic and pesticide analytes, refer to Appendices A1 and B1.

The permit calls for the analysis of enterococci bacteria in effluent twice per year in conjunction with the summer dry and summer wet sampling. The enterococci in the effluent was reported as <2 most probable number (MPN)/100 mL in the four samples analyzed for the June 2009 sampling and <2 MPN/100 mL for both replicates and laboratory sample duplicates taken during the July 2009 sampling event.

Asbestos was not detected in influent, effluent, or sludge during either sampling event. The concentration of cyanide in the influent and effluent was below the detection limit of 5.0 µg/L during June 2009 sampling event. Cyanide was seen in the effluent and sludge during the July sampling event at 16.0 µg/L and 1.2 µg/g, respectively. The effluent cyanide concentration was still well below the MAEC of 181 µg/L. Dioxins (2,3,7,8-TCDD) were tested in influent, effluent, and sludge during both sampling events, but none were detected.

3.1.3 Pretreatment Monitoring Data

As part of the NPDES permit, AWWU is to conduct pretreatment monitoring twice per year in conjunction with the toxic pollutant and pesticide analyses. This monitoring includes three consecutive days of 24-hr composite sampling of the influent and effluent and one day of sludge sampling. Pretreatment analyses include cyanide and a suite of metals that are analyzed as both total and dissolved. Results of the pretreatment monitoring are presented in Table 11.

Collection of samples for trace metals analysis, as part of the toxic pollutant and pesticide sampling events in June and July 2009, coincided with the first day of the pretreatment monitoring for the Asplund WPCF during 2009, as discussed in Section 3.1.2. Individual metals concentrations for the 3-day pretreatment sampling event were generally found to be very similar with little variation between sampling days, particularly for the effluent. Zinc was the one metal that stood out as being the most variable between sampling days for both influent and effluent.

Of all the metals in the effluent, total copper and zinc concentrations were the highest. However, concentrations of these metals were still well below their respective MAECs. For example, dissolved copper in the effluent was reported at concentrations of 13 - 16 µg/L during the three days of pretreatment sampling in June 2009 and a range of 27 - 30 µg/L during the July sampling effort as compared to the MAEC of 317 µg/L. Total copper in the effluent was found to range from 35 to 128 µg/L for the six pretreatment samples compared to the MAEC of 317 µg/L. Influent values were generally more variable than those seen in effluent, as would be expected. Dissolved zinc in the effluent ranged from 38 - 66 µg/L during both pretreatment samplings, while total zinc ranged from 97 - 220 µg/L during these samplings as compared to an MAEC of 11,249 µg/L. Dissolved and total mercury were below reporting limits of 0.2 µg/L in all six effluent pretreatment samples, as compared to the MAEC of 2.73 µg/L. Other metals were also found to be substantially less than their respective MAECs. Total cyanide was detected in effluent in the range of 12 - 21 µg/L as compared to a MAEC of 181 µg/L.

3.1.4 Whole Effluent Toxicity Testing Results

Quarterly WET testing was conducted on 24-hr flow composite effluent samples as required under the permit during all four quarters of calendar year 2009. Echinoderm fertilization tests

Table 11. Pretreatment Monitoring Data for Influent and Effluent Metals and Cyanide.
Concentrations are in µg/L.

Parameter	June 2009						July 2009					
	Influent			Effluent			Influent			Effluent		
Sample Date	24	25	26	24	25	26	28	29	30	28	29	30
Dissolved Metals												
Antimony	<4.55	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Arsenic	<22.7	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0
Beryllium*	<1.82	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40
Cadmium	<2.27	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
Chromium	<9.09	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0
Copper	15.2	9.04	5.73	14.0	13.0	16.2	19.3	20.9	24.6	26.8	28.9	30.3
Lead	<0.909	<0.20	0.818	<0.20	0.277	0.227	0.705	0.575	0.537	0.917	0.692	0.749
Mercury	<0.20	<0.20	NT	<0.20	<0.20	NT	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20
Molybdenum	<45.5	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	10.0	13.0	<10.0	11.2	12.3
Nickel	<9.09	3.00	2.57	2.94	3.02	2.87	2.72	2.44	2.59	2.77	2.60	2.51
Selenium	<22.7	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0
Silver	<4.55	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Thallium	<4.55	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Zinc	116	11.8	8.84	38.4	42.6	57.5	24.3	23.6	32.8	58.4	66.0	64.8
Total Metals and Cyanide												
Antimony	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Arsenic	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0
Beryllium*	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40
Cadmium	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
Chromium	3.25	<2.0	<2.0	<2.0	2.83	<2.0	<2.0	2.81	2.65	<2.0	<2.0	<2.0
Copper	65.5	49.7	42.1	48.9	128	46.2	32.6	65.6	73.9	34.9	45.9	47.7
Cyanide	<5.0	<5.0	<5.0	<5.0	21	<5.0	<5.0	<5.0	<5.0	16	12	<5.0
Lead	5.38	2.49	8.70	2.35	6.94	8.36	1.61	5.42	3.58	1.80	2.14	1.98
Mercury	<0.20	<0.20	NT	<0.20	<0.20	NT	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20
Molybdenum	<10.00	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	10.6	12.2	<10.0	10.7	12.5
Nickel	4.98	3.51	2.96	3.62	5.53	3.08	2.79	4.45	4.14	2.98	3.09	2.89
Selenium	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0
Silver	1.85	1.44	<1.0	1.56	3.21	<1.0	<1.0	1.12	1.26	<1.0	<1.0	<1.0
Thallium	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Zinc	158	111	85.8	97.4	220	98.7	62.7	164	165	81.4	106	110

* Not required by permit for "Pretreatment" monitoring

NT Not tested

Values reported as "<" (less than), are reporting limits

were performed using the purple sea urchin, *Strongylocentrotus purpuratus*, during the first, second, and fourth quarters of 2009. Use of this test during the first, second, and fourth quarters was based on the screening test results from the fourth quarter of 2008 which had determined the sea urchin to be the most sensitive species tested (see Section 2.1.4). Annual re-screening for the most sensitive species in 2009 was performed during the third quarter. Based on interpretation of this and previous years detailed laboratory results, the laboratory recommended continuing with the sea urchin as the most sensitive species for the 2009 testing.

Results of all the tests performed in 2009 are summarized below and presented in Table 12 as the lowest observed effect concentration (LOEC), no observed effect concentration (NOEC), and in chronic toxicity units (TUc), where $TUc = 100/NOEC$. Detailed results in the form of descriptive laboratory reports that present all data in tabular form along with statistical analyses, QA/QC information, and reference toxicant test results have previously been submitted to ADEC and EPA with Asplund WPCF's monthly discharge monitoring reports (DMRs) and are not duplicated here in this report.

Table 12. Summary of WET Test Data from 2009.

Toxicity Test	LOEC (%)	NOEC (%)	TUc
1st Quarter 2009			
Echinoderm (fertilization)	2.8	1.4	71.4
2nd Quarter 2009			
Echinoderm (fertilization)	1.4	0.7	142.8
3rd Quarter 2009			
Bivalve (survival)	>2.8	2.8	35.7
Bivalve (development)	>2.8	2.8	35.7
Topsmelt (survival)	>2.8	2.8	35.7
Topsmelt (growth)	>2.8	2.8	35.7
Echinoderm (fertilization)	>2.8	2.8	35.7
4th Quarter 2009			
Echinoderm (fertilization)	1.4	0.7	142.8

First quarter 2009 echinoderm fertilization testing was performed on a single 24-hr composite sample collected on 21-22 January 2009. Results from this sample showed a significant decrease in egg fertilization at the 2.8 % effluent sample concentration with an LOEC of 2.8 % and a NOEC of 1.4 % effluent. The TUc was 71.4, which was well within the permit maximum allowable limit of 143 TUc.

The WET testing for the second quarter with echinoderms was performed on a sample collected 31 March - 1 April 2009. Results of the echinoderm fertilization test conducted during the second quarter showed a significant decrease in egg fertilization occurred at the 2.8 % and 1.4 % effluent concentrations when compared to the seawater-only controls. The NOEC for fertilization was therefore 0.7 % and the LOEC was 1.4 %, with a TUc of 142.8, meeting the allowable permit limit of not exceeding 143 TUc.

The three-species WET testing was performed during the third quarter of 2009. The test included: the bivalve larvae, *Mytilus galloprovincialis*, survival and development; topsmelt, *Atherinops affinis*, survival and growth; and echinoderm, *Strongylocentrotus purpuratus* fertilization. Two sampling events were needed to accomplish all bioassays within the third quarter time frame, due to season spawning difficulties with the urchins and bivalves. The first sampling was conducted between 23 and 28 August, 2009. The second sampling event was collected between 28 and 30 September, 2009.

Results of the bivalve test showed that no concentration of effluent that was tested produced any toxicity to the test organisms. The NOECs for both survival and development were 2.8 % effluent and both LOECs were > 2.8 % effluent. Chronic toxicity units were 35.7 TUC for both survival and development in the bivalves. Both reference toxicant tests were within laboratory control chart limits and indicated typical sensitivity of the test population.

The topsmelt bioassay showed no significant decrease in survival or growth at any concentration compared with seawater-only controls. The NOECs for survival and growth were 2.8 %, and the LOECs were both >2.8 %. The effluent therefore showed 35.7 TUC in the survival endpoint and in the growth endpoint. The concurrent reference toxicant test results were within laboratory control chart limits and indicated typical sensitivity of the test population. All test acceptability criteria (TAC) were met in both the effluent bioassay and the reference toxicant bioassay.

Results of the echinoderm fertilization test showed that no concentration of effluent that was tested produced any toxicity to the test organisms. The NOEC for fertilization was therefore 2.8 % and the LOEC was >2.8 %, with a TUC of 35.7, meeting the allowable permit limit of not exceeding 143 TUC. Based on the results of the three-species testing and past years' results, it was recommended to continue to use the urchin as the most sensitive species for the toxicity testing to be conducted in the fourth quarter of 2009 and until the three-species comparison is repeated in 2010.

The WET testing for the fourth quarter with echinoderms was performed on samples collected 27 – 28 October, 2009. Results of the echinoderm fertilization test conducted during the second quarter showed that significant decrease in egg fertilization occurred at the 2.8 % and 1.4 % effluent concentrations when compared to the seawater-only controls. The NOEC for fertilization was therefore 0.7 % and the LOEC was 1.4 %, with a TUC of 142.8, meeting the allowable permit limit of not exceeding 143 TUC.

3.1.5 Part 503 Sludge Monitoring Data

The AWWU operates a sludge incinerator at the Asplund WPCF for which the NPDES permit requires sludge monitoring twice per year as part of the "Toxic Pollutants and Pesticides/Pretreatment" sampling requirements. As described in Section 2.1.5, AWWU performed Part 503 sludge monitoring with a minimum frequency of once every 60 day period (6 times/year). These data will be submitted along with other incinerator operational information to EPA by 19 February 2010. This submittal will take the form of a separate report; however, for completeness and for comparison purposes, this information has been included here as well.

Results of the sludge monitoring for metals for the year are presented in Table 13. Metals concentrations were extremely low compared to allowable limits and very usually very similar to those seen historically. Exceptions to this included chromium and zinc which were found to be

Table 13. Part 503 Discharge Monitoring Data for Sludge Metals. Concentrations are in mg/kg dry weight. All metals are reported as total metals.

Parameter ^{1,6}	Arsenic	Beryllium ^{3,5}	Cadmium	Chromium	Lead	Nickel	Mercury ^{4,5}
Site Specific Limit 2009²	99	2014	88	1937	5045	6727	129
02/04/09	ND (<3.44)	ND (<0.344)	0.89	8.36	10.60	7.23	0.395
04/17/09	ND (<2.97)	ND(<0.297)	0.95	17.30	16.40	11.30	0.655
05/13/09	ND (<2.40)	ND (<0.240)	0.76	7.90	11.00	7.42	0.231
06/23/09	ND(<3.25)	1.75	0.66	122.00	19.40	400.00	NT ⁷
07/28/09	4.00	ND (<0.326)	1.29	12.20	19.20	13.90	NT ⁷
08/26/09	6.34	ND (<0.296)	1.77	16.80	25.80	14.60	0.509
10/07/09	5.11	ND (<0.347)	1.49	15.30	21.50	11.70	0.885
11/24/09	ND (<3.29)	ND (<0.345)	1.04	9.50	17.70	8.58	0.571
MINIMUM	ND	ND	0.66	7.90	10.60	7.23	0.231
MAXIMUM	6.34	1.75	1.77	122.00	25.80	400.00	0.88
AVERAGE ⁸	3.85	0.49	1.11	26.17	17.70	59.34	0.541

1) *Test Methods for Evaluating Solid Waste, Physical/Chemical Methods, SW-846, 3rd Edition*, EPA. Samples for total metals analysis, with the exception of mercury, were prepared (acid digestion) according to EPA method 3050, SW-846.

2) Site-specific sludge limits calculated by CH2MHill May 2008, based primarily on October 2007 Asplund Incinerator Source Test.

3) Beryllium emissions shall not exceed 10 grams per day. With a control efficiency of 0.9998 at the maximum sludge feed rate, a sludge concentration of 500 milligrams per dry kilogram of sludge will not result in a violation of the limit.

4) Mercury emissions shall not exceed 3,200 grams per day. With a control efficiency of 0.0 at the maximum sludge feed rate, a sludge concentration of 9.63 milligrams per dry kilogram of sludge will not result in a violation of the limit.

5) Monitoring frequencies required by 40 CFR Part 503 for incineration are once per 60 days for arsenic, cadmium, chromium, lead, and nickel. Mercury is at least once per year. Frequency for beryllium is not specified. AWWU has chosen to test mercury and beryllium more frequently than required to be consistent with the other metals.

6) Samples were analyzed by SGS - EPA 6020, Mercury by EPA 7471A and/or 7471B methods. Parentheses contain PQL values.

7) NT = not tested.

8) Average computed using detection limit where concentration is ND (non-detect).

elevated during the June sampling event. Chromium was 122 mg/kg about 10 times higher than the other sampling events and zinc was 400 mg/kg about 20 times higher than the other 2009 sampling events. The only metal that had historically been elevated for some sampling events was arsenic. In 2009, the highest concentration of arsenic in the sludge was 6.34 mg/kg compared to the allowable limit of 99 mg/kg. As mentioned above, no actual limits exist in the current NPDES permit. Allowable limits are site-specific and were calculated by the permittee per Part 503 regulations (CH2M Hill 2008). EPA plans to issue sludge only permits in the future; in the interim, 40 CFR Part 503 regulations are “self-implementing”.

3.2 RECEIVING WATER QUALITY MONITORING RESULTS

Water quality sampling of the receiving water was conducted on 23 - 24 June 2009, concurrent with the summer dry sampling. Sampling results are contained in the following subsections.

3.2.1 Plume Dispersion Sampling

Drogue Tracking Results

Drogues were released on 23 June 2009 at the ZID station for the ebb and flood tidal cycles and on 24 June 2009 at the control station for the flood tidal cycle. Three drogues were deployed during each tidal cycle and four stations sampled along each drogue track.

ZID Site

The Point Woronzof ebb drogue drop and tracking cycles were performed during the morning of 23 June 2009. The predicted tidal range during ebb stage was 35.8 feet (Figure 5 and Table 14; NOAA Tides and Currents, 2009). A composite of the ebb drogue deployments is depicted in Figure 6 and are very similar to that seen in previous years.

The ebb drogues traveled from approximately 2.0 to 3.5 nautical miles, all three traveling in a southwesterly direction. No eddies were observed during these drogue tracks, nor did any of the drogues become grounded during their tracks. The first ebb (E1) drogue was released at 08:26 Alaska Daylight Time (ADT), about 35 minutes after high tide. This drogue tracked southwest but north of the shoal that was evident at low tide. This drogue traveled at approximately 134 centimeters per second (cm/s) over its entire track of approximately 3.5 nautical miles. The second ebb drogue (E2) was released at 10:19 ADT and also tracked north of the shoal, traveling west southwest with an average speed of 183 cm/s over the entire track, traveling approximately 2.0 nautical miles. The third drogue (E3) was released at 12:21 ADT four and a half hours after high slack. The third drogue followed a similar path to the E1 and E2 drogues traveling in a west southwesterly direction. This drogue traveled approximately 2.5 nautical miles at 90 cm/s over its entire track. The relationship of drogue tracks with respect to the tide are shown in Figure 5.

Flood drogue tracks are depicted in Figure 7. The tidal range during flood stage was 33.6 feet (Figure 5 and Table 14; NOAA, 2009). The first flood drogue (F1) was deployed on 24 June at 15:24 ADT at low slack water at the outfall. This drogue traveled easterly along the shoreline on the east side of Point Woronzof for approximately 1.0 nautical mile at an average speed of 32 cm/s before looping back towards shore and entering the shallow intertidal area where it grounded and was retrieved. The fact that this drogue looped back along the shore is evidence of a small eddy in the lee of Point Woronzof. The second flood drogue (F2) was deployed at 16:55




Figure 5. Tidal Information for Receiving Water Sampling, Ebb and Flood Tides.

Table 14. 2009 Drogue Tracking Information.

DATE	STATION	TIDAL INFORMATION				DROGUE NO.	RELEASE TIME AFTER SLACK (HOURS:MINUTES)	DROGUE SPEED AVERAGE (CM/S)
		Slack Water (Alaska Daylight Time ^a ; Stage)		Direction	Range (Feet) ^b			
23 June 2009	ZID	0751	HIGH	EBB	35.8	E1	00:35	134
23 June 2009	ZID	0751	HIGH	EBB	35.8	E2	02:28	183
23 June 2009	ZID	0751	HIGH	EBB	35.8	E3	04:30	90
23 June 2009	ZID	1520	LOW	FLOOD	33.6	F1	00:04	32
23 June 2009	ZID	1520	LOW	FLOOD	33.6	F2	01:35	61
23 June 2009	ZID	1520	LOW	FLOOD	33.6	F3	02:49	162
24 June 2009	CONTROL	1606	LOW	FLOOD	34.7	C1	00:03	117
24 June 2009	CONTROL	1606	LOW	FLOOD	34.7	C2	02:06	282
24 June 2009	CONTROL	1606	LOW	FLOOD	34.7	C3	03:30	235

^a NOAA Tides and Currents 2009. (Port of Anchorage, Anchorage)

^b Observed water level variations during tide.




Figure 6. Summary of Ebb Drogue Tracks and Receiving Water Sampling Locations at Point Woronzof, 23 June 2009.




Figure 7. Summary of Flood Drogue Tracks and Receiving Water Sampling Locations at Point Woronzof, 23 June 2009.

ADT, approximately 1 hour 35 minutes after low slack. This drogue was transported initially to the northeast then easterly and further offshore than the first drogue and was tracked for about 1.5 nautical miles at an average speed of 61 cm/s before it was recovered. The third flood drogue (F3) was deployed at 18:09 ADT, almost 3 hours after low slack water, and tracked just under 1 hour when it was recovered. The third drogue traveled in a northeast direction as had the second drogue for more than a mile, then moved further out from the shoreline, where it continued moving northeast in the central Knik Arm Channel with an average speed of 162 cm/s. This drogue was tracked for approximately 2.5 nautical miles and was recovered 1.0 nautical mile offshore and to the northwest of Westchester Lagoon.

Control Site

The Point MacKenzie control drogues were deployed and tracked on 24 June 2009. The predicted tidal range during the flood tide was 34.7 ft. Tidal information is provided in **Figure 8** and Table 14 (NOAA, 2009). A composite of the three drogue trajectories at the control site is presented in Figure 9 which is very similar to prior years. The relationship of drogue tracks with respect to the tide and when sampling took place are shown in **Figure 8**.

All three control drogues had similar tracks with all three tracking into the center portion of the Knik Arm Channel. The first drogue was released at 16:09 ADT, right at low slack water, and traveled to the east and then to the northeast along the main channel. This drogue traveled over 4 nautical miles with an average speed of 117 cm/s over the entire track before being retrieved in mid channel. The second drogue (C2) was released at 18:12 ADT, 2 hours and 6 minutes into the flood tidal cycle, and tracked for one hour. This drogue had an average speed of 282 cm/s over the entire track and moved towards the northeast in mid-channel traveling almost 5.5 nautical miles. The third control drogue (C3) was released at 19:36 ADT, 3.5 hours after low slack water. The drogue traveled in a manner similar to the first and second drogues and slightly further offshore, moving northeast into the central channel with an average speed of 235 cm/s, traveling over 7 nautical miles in all.

Summary of Receiving Water Quality Data

The summer water quality sampling for all analysis types was conducted concurrently with the drogue tracking studies on 23 - 24 June 2009. As discussed previously, three drogues were released at the ZID for both ebb and flood tides and three were released at the control site for the flood tide. Water samples and CTD measurements were obtained at four stations along each drogue's track prior to their being retrieved. In the current NPDES permit, the ZID boundary is located 650 m distance from the outfall diffuser. To accomplish the ZID site sampling station, the vessel was positioned directly upcurrent from the diffuser and allowed to drift down across it. Upon reaching the outfall diffuser, the drogue was dropped and the within-ZID station sampled. The distance from the outfall diffuser was monitored with the DGPS, and upon reaching 650 m distance from the diffuser, the ZID-boundary station was sampled. The third and fourth stations were then sampled along the drogue's path. Due to high current speeds, anchoring the vessel and sampling at each station was not practical or desirable for this type of sampling due to the large wire angles of sampling gear and quickness needed in sampling.

In the field, samples were coded on their labels by location and depth to provide an easy summary of the water quality measurements obtained. The station designation is represented by: drogue drop location (C=control, E=ebb, and F=flood), the first number represents the drogue




Figure 8. Tidal Information for Receiving Water Sampling, Control Tide.




Figure 9. Summary of Control Drogue Tracks and Receiving Water Sampling Locations at Point MacKenzie, 24 June 2009.

number, and the second number represents the station along the drogue's path. The final character represents surface (S), mid-depth (M), or bottom (B) sample. The waters of the inlet are extremely well-mixed both vertically and horizontally, as indicated by the CTD data. During the survey, water temperatures ranged from a minimum of 11.80 °C to a maximum of 12.90 °C (Table 15). Salinities were found to vary from a minimum of 9.08 parts per thousand practical salinity units (psu) to a maximum of 15.18 psu. Salinities were generally found to increase slightly during the flood and decrease on the ebb, as is typical for estuaries. As has been seen often times in the past, the control stations were found to be slightly warmer and less saline due to a greater influence from river runoff from the Matanuska and Knik Rivers. Values for pH ranged from 7.87 to 8.01 with little to no vertical stratification and slightly higher levels at the control site. Values for DO collected in-situ by the CTD ranged from 9.47 to 10.19 mg/L with most concentrations being at or near 100 percent saturation (UNESCO, 1973).

Representative hydrographic profiles of water quality are presented for a ZID boundary station during ebb tide, Station E1-2, and a typical control station, Station C1-1 (Figure 10). The water column was found to be well mixed from the surface to the bottom at all stations. Refer to Appendix C7 for CTD profile plots and detailed data from each water quality station.

Surface samples were obtained at each station for the analysis of color, TRC, fecal coliform bacteria, and turbidity. Color values were found to range < 5 to 8 color units on the platinum-cobalt scale. In 2007, the highest color values ever observed over the 20-year history of the program were seen. These high values were believed to be the result of insufficient suspended sediment removal by the laboratory as high levels were seen at both the outfall and control sites and were not the result of AWWU's discharge. In 2008 and 2009, to circumvent the sediment removal problem, samples were allowed to settle and decanted prior to submission for analysis.

During 2009, most measured receiving water TRC concentrations were below the MDL of 0.010 mg/L. Three samples collected within the ZID displayed quantifiable levels of TRC: E3-1S = 0.031 mg/L, F1-1S = 0.062/0.86 mg/L, and F2-1S = 0.010 mg/L. The average TRC concentrations during the effluent sampling was 0.12 mg/L, which is much lower than the MAEC based on the AWQS. It should be noted that the lowest MDL that was achievable by analysts due to seawater matrix interferences for TRC analysis in 2009 is between the AWQS 1-hr average acute limit of 0.013 mg/L and the 4-day chronic limit of 0.0075 mg/L. This year the ion selective electrode method (SM4500 Cl-G) was used for the receiving water sampling to reduce interferences from common oxidizing agents, temperature, turbidity, or color; but all TRC methods are subject to positive interferences in estuarine or marine waters.

Fecal coliform values this year were quite low and ranged from < 2 to 34 FC MPN/100 mL. Most of the fecal coliform concentrations were reported ≤ 2; this included 18 out of 24 samples at the ebb and flood stations combined and 14 out of 15 samples at the control stations. The overall median for fecal coliform for all of the outfall stations (both ebb and flood) was 2 FC MPN/100 mL; the median at the control stations was <2 FC MPN/100 mL. Turbidity values for water samples collected during the monitoring ranged from a low of 39 Nephelometric Turbidity Units (NTU) to a high of 620 NTU with lower values seen near the surface and near slack tide.

In addition to routine monitoring conducted at each receiving water quality station, supplemental surface samples were collected at the first three stations (diffuser, ZID boundary, and nearfield) along the first flood drogue trajectory at both the outfall and control sites. A sample of final effluent was also obtained at the same time for comparison. These supplemental samples were

Table 15. Hydrographic and Water Quality Data, 23 and 24 June 2009.

Station Number	Time (ADT)	Latitude (North)	Longitude (West)	Depth (M)	Temp ^b (°C)	Salinity ^b (‰)	pH ^b (units)	D.O. ^b (mg/L)	Turbidity (NTU)	Color (units)	TRC (mg/L)	Fecal Coliform ^a
JUNE 23												
E1-1S	0826	61° 12.342'	150° 01.283'	0.5	12.36	12.53	7.94	9.68	315	ND/ND (5.0)	ND (0.010)	<2
-1M				6.0	12.34	13.17	7.95	9.68	513			
-1B				11.5	12.33	13.28	7.96	9.75	485			
E1-2S	0836	61° 12.247'	150° 01.975'	0.5	12.37	12.63	7.94	9.66	278	ND (5.0)	ND (0.010)	2
-2M				7.5	12.24	13.59	7.97	9.73	470			
-2B				15.0	11.95	14.99	7.96	9.79	353			
E1-3S	0846	61° 12.048'	150° 02.587'	0.5	12.35	12.73	7.95	9.68	224	ND (5.0)	ND (0.010)	<2
-3M				6.5	11.94	14.75	7.97	9.74	362			
-3B				13.0	11.84	15.10	7.96	9.79	288			
E1-4S	0912	61° 11.367'	150° 04.458'	0.5	12.22	13.42	7.95	9.67	213 / 220	5.0	ND (0.010)	<2
-4M				8.0	11.83	15.04	7.96	9.75	255			
-4B				16.0	11.80	15.18	7.96	9.82	332			
E2-1S	1019	61° 12.343'	150° 01.274'	0.5	12.34	13.17	7.95	9.66	397	ND (5.0)	ND (0.010)	<2
-1M				4.5	12.34	13.18	7.96	9.70	393			
-1B				9.0	12.34	13.19	7.96	9.74	403			
E2-2S	1023	61° 12.340'	150° 02.042'	0.5	12.35	13.18	7.96	9.47	386	ND (5.0)	ND (0.010)	2
-2M				6.0	12.34	13.19	7.96	9.66	434			
-2B				11.5	12.34	13.20	7.96	9.74	417			
E2-3S	1029	61° 12.168'	150° 03.049'	0.5	12.35	13.31	7.95	9.64	384	ND (5.0)	ND (0.010)	2
-3M				8.0	12.33	13.32	7.96	9.71	409			
-3B				15.5	12.33	13.31	7.96	9.77	412			

Table 15. Hydrographic and Water Quality Data, 23 and 24 June 2009. (continued)

Station Number	Time (ADT)	Latitude (North)	Longitude (West)	Depth (M)	Temp ^b (°C)	Salinity ^b (‰)	pH ^b (units)	D.O. ^b (mg/L)	Turbidity (NTU)	Color (units)	TRC (mg/L)	Fecal Coliform ^a
E2-4S	1044	61° 11.672'	150° 04.228'	0.5	12.35	13.27	7.96	9.65	396	ND (5.0)	ND (0.010)	<2
-4M				5.5	12.33	13.28	7.96	9.65	409			
-4B				10.5	12.32	13.33	7.96	9.72	394			
E3-1S	1221	61° 12.344'	150° 01.274'	0.5	12.48	12.52	7.96	9.69	365 / 375	ND (5.0)	0.0135	<2
-1M				2.5	12.48	12.51	7.96	9.71	383			
-1B				5.0	12.48	12.50	7.96	9.73	381			
E3-2S	1232	61° 12.241'	150° 01.977'	0.5	12.49	12.35	7.95	9.71	354	ND (5.0)	ND (0.010)	<2
-2M				4.0	12.49	12.36	7.96	9.73	385			
-2B				8.0	12.48	12.38	7.96	9.76	387			
E3-3S	1247	61° 12.016'	150° 02.613'	0.5	12.51	12.39	7.95	9.69	354	ND/ND (5.0)	ND (0.010)	2
-3M				3.0	12.49	12.39	7.95	9.72	391			
-3B				6.0	12.49	12.39	7.95	9.74	401			
E3-4S	1309	61° 11.662'	150° 03.367'	0.5	12.50	12.42	7.95	9.70	322	ND (5.0)	ND (0.010)	2
-4M				2.5	12.49	12.44	7.95	9.72	404			
-4B				5.0	12.49	12.45	7.95	9.74	410			
F1-1S	1524	61° 12.343'	150° 01.274'	0.5	12.65	11.20	7.97	9.78	237	8.0	0.0625/0.0864	30
-1M				1.0	12.65	11.21	7.97	9.78	278			
-1B				1.5	12.65	11.21	7.97	9.80	266			
F1-2S	1555	61° 12.360'	150° 00.355'	0.5	12.78	11.60	7.87	9.73	222	ND (5.0)	ND (0.010)	11
-2M				1.0	12.78	11.58	7.87	9.74	290			
-2B				2.0	12.78	11.56	7.88	9.75	294 / 291			
F1-3S	1610	61° 12.288'	150° 00.055'	0.5	12.81	11.52	7.89	9.75	226	ND (5.0)	ND (0.010)	8
-3M				1.0	12.80	11.50	7.89	9.76	292			
-3B				1.5	12.80	11.50	7.90	9.76	288			

Table 15. Hydrographic and Water Quality Data, 23 and 24 June 2009. (continued)

Station Number	Time (ADT)	Latitude (North)	Longitude (West)	Depth (M)	Temp ^b (°C)	Salinity ^b (‰)	pH ^b (units)	D.O. ^b (mg/L)	Turbidity (NTU)	Color (units)	TRC (mg/L)	Fecal Coliform ^a
F1-4S	1638	61° 12.167'	149° 59.795'	0.5	12.90	11.64	7.94	9.74	39	ND (5.0)	ND (0.010)	2
-4M				1.0	12.84	11.79	7.95	9.72	223			
-4B				2.0	12.88	12.03	7.95	9.68	228			
F2-1S	1655	61° 12.340'	150° 01.291'	0.5	12.78	12.26	7.95	9.70	465	ND (5.0)	0.010	34
-1M				2.5	12.77	12.25	7.95	9.73	509			
-1B				5.0	12.77	12.23	7.95	9.72	515			
F2-2S	1702	61° 12.525'	150° 00.628'	0.5	---	---	---	---	210	ND (5.0)	ND (0.010)	4
-2M				4.5	---	---	---	---	482			
-2B				8.5	---	---	---	---	491			
F2-3S	1714	61° 12.576'	149° 59.789'	0.5	12.81	12.16	7.95	9.70	440 / 442	ND (5.0)	ND (0.010)	2
-3M				4.5	12.80	12.08	7.95	9.73	525			
-3B				8.5	12.85	12.38	7.95	9.75	550			
F2-4S	1735	61° 12.528'	149° 59.230'	0.5	12.81	11.60	7.96	9.75	118	ND (5.0)	ND (0.010)	2
-4M				4.5	12.82	12.05	7.95	9.73	298			
-4B				8.5	12.80	12.10	7.95	9.77	509			
F3-1S	1809	61° 12.348'	150° 01.278'	0.5	12.48	12.48	7.96	9.68	406	ND/ND (5.0)	ND (0.010)	4
-1M				4.5	12.48	12.47	7.96	9.72	408			
-1B				9.0	12.49	12.44	7.96	9.77	430			
F3-2S	1815	61° 12.348'	150° 00.707'	0.5	12.50	12.29	7.96	9.72	435	ND (5.0)	ND (0.010)	2
-2M				6.0	12.50	12.30	7.96	9.76	439			
-2B				11.5	12.50	12.22	7.96	9.81	437			
F3-3S	1823	61° 12.724'	150° 00.085'	0.5	12.50	12.23	7.96	9.72	471	ND (5.0)	ND (0.010)	<2
-3M				7.5	12.42	12.80	7.97	9.74	495			
-3B				15.0	12.40	12.98	7.96	9.80	485			

Table 15. Hydrographic and Water Quality Data, 23 and 24 June 2009. (continued)

Station Number	Time (ADT)	Latitude (North)	Longitude (West)	Depth (M)	Temp ^b (°C)	Salinity ^b (‰)	pH ^b (units)	D.O. ^b (mg/L)	Turbidity (NTU)	Color (units)	TRC (mg/L)	Fecal Coliform ^a
F3-4S	1835	61° 13.081'	149° 59.124'	0.5	12.46	12.50	7.96	9.61	397 / 399	5.0	ND (0.010)	<2
-4M				18.5	12.47	12.57	7.96	9.75	431			
-4B				37.0	12.47	12.51	7.96	9.93	433			
JUNE 24												
C1-1S	1609	61° 13.715'	149° 59.729'	0.5	12.82	9.81	7.94	9.92	338	ND (5)	ND (0.010) / ND (0.010)	<2
-1M				7.0	12.26	9.52	7.98	9.95	612			
-1B				13.5	12.34	10.06	7.97	9.97	520			
C1-2S	1648	61° 13.757'	149° 59.124'	0.5	12.87	9.79	7.94	9.91	13	5	ND (0.010) / ND (0.010)	<2
-2M				10.0	12.22	9.20	8.01	10.03	591			
-2B				19.5	12.28	9.68	8.00	10.05	600			
C1-3S	1716	61° 14.384'	149° 55.520'	0.5	12.84	9.45	7.97	9.95	239	ND (5)	ND (0.010)	2
-3M				9.5	12.29	9.13	8.01	10.06	575			
-3B				19.0	12.23	9.10	8.01	10.14	590 / 600			
C1-4S	1742	61° 15.393'	149° 54.313'	0.5	12.27	8.58	7.96	9.97	525	ND (5)	ND (0.010)	<2
-4M				22.5	12.28	9.10	8.00	10.01	580			
-4B				45.0	12.28	9.08	8.00	10.19	620			
C2-1S	1812	61° 13.708'	149° 59.721'	0.5	12.66	10.90	7.95	9.76	422	5	ND (0.010)	<2
-1M				12.0	12.57	10.92	7.98	9.82	530			
-1B				23.5	12.48	11.33	7.97	9.76	545			
C2-2S(A)	1819	61° 13.832'	149° 58.557'	0.5	12.64	10.88	7.94	9.71	330	ND (5)	ND (0.010)	<2
-2S(B)				0.5	12.72	10.88	7.95	9.66	355	ND (5)	ND (0.010)	<2
-2S(C)				0.5	12.67	10.88	7.97	9.67	342	ND (5)	ND (0.010)	2
-2M				12.5	12.57	10.92	7.98	9.80	530			
-2B				25.0	12.51	11.24	7.97	9.92	573			

Table 15. Hydrographic and Water Quality Data, 23 and 24 June 2009. (continued)

Station Number	Time (ADT)	Latitude (North)	Longitude (West)	Depth (M)	Temp ^b (°C)	Salinity ^b (‰)	pH ^b (units)	D.O. ^b (mg/L)	Turbidity (NTU)	Color (units)	TRC (mg/L)	Fecal Coliform ^a
C2-3S	1844	61° 15.260'	149° 54.148'	0.5	12.57	10.80	7.95	9.70	480	ND (5)	ND (0.010)	<2
-3M				18.0	12.52	10.62	7.98	9.88	538 / 532			
-3B				35.5	12.48	10.30	7.98	10.05	532			
C2-4S	1855	61° 16.057'	149° 53.479'	0.5	12.47	9.57	7.98	9.83	468	ND (5)	ND (0.010)	4
-4M				16.0	12.55	10.68	7.98	9.82	510			
-4B				31.5	12.59	10.74	7.97	9.90	528			
C3-1S(A)	1936	61° 13.713'	149° 59.735'	0.5	12.80	11.82	7.96	9.59	295	ND (5)	ND (0.010)	<2
-1S(B)				---	---	---	---	---	300	ND (5)	---	<2
-1S(C)				---	---	---	---	---	290	ND (5)	---	<2
-1M				14.5	12.48	12.62	7.96	9.66	376			
-1B				28.5	12.49	12.41	7.96	9.78	513			
C3-2S	1948	61° 13.878'	149° 57.673'	0.5	12.87	11.68	7.96	9.66	159	ND (5)	ND (0.010)	2
-2M				12.5	12.48	12.43	7.97	9.72	414			
-2B				24.5	12.47	12.48	7.96	9.80	431			
C3-3S	2005	61° 14.571'	149° 54.919'	0.5	12.61	12.15	7.96	9.66	188	ND (5)	ND (0.010)	<2
-3M				15.0	12.46	12.31	7.97	9.75	450			
-3B				30.0	12.46	12.35	7.97	9.87	506			
C3-4S	2020	61° 15.512'	149° 53.701'	0.5	12.77	11.42	7.97	9.61	320	ND (5)	ND (0.010)	<2
-4M				23.5	12.58	11.86	7.97	9.72	300			
-4B				47.0	12.49	12.20	7.96	9.91	263			

a Fecal coliform reported as MPN/100 mL.

b Values from CTD for 0.5 m depth taken as close to surface as possible.

--- Samples not collected.

ND None detected (detection limit).

Outfall Station

Control Station




Figure 10. Sample Hydrographic Profiles from Outfall and Control Stations, June 2009.

analyzed for BETX, polycyclic aromatic hydrocarbons (PAHs), dissolved and total recoverable trace metals, cyanide, and TSS.

The maximum dissolved arsenic, cadmium, chromium, copper, mercury, nickel, silver, and zinc concentrations were seen at Station F1-1 located at low slack water above the diffuser, within the ZID (Table 16). The highest dissolved lead concentration was seen at the control station, C1-3. The higher dissolved concentrations seen at Station F1-1 were probably a discharge related effect; however, all dissolved metals concentrations except copper were less than AWQS and SSWQC for the Point Woronzof area. Dissolved copper reported at 4.01 µg/L at Station F1-1 was slightly higher than the AWQS of 3.1 µg/L, however this criterion does not apply to this station as it is located within the ZID mixing zone. All dissolved metals concentrations met AWQS at all ZID boundary, near field, and control stations.

Total metals concentrations were also quite variable with the highest levels for all metals except silver seen at the control site at Station C1-3 and most of the next highest levels seen at the control Station C1-1. These results can be directly attributed to high TSS levels. The TSS level at Station C1-3 (700 mg/L) being twice as high as any of the three outfall locations where TSS concentrations ranged from 180 to 330 mg/L. The differences between the outfall and control sites were the result of natural differences in TSS concentrations. Total suspended solid results ranged from 260 to 700 mg/L at the control stations compared to 180 to 330 mg/L at the outfall stations. The effluent sample had a TSS concentration of 51 mg/L. Total silver was found to be highest at Station F1-1.

Cyanide concentrations were all found to be below the method reporting limit of 1 µg/L at all receiving water stations including the control site stations. Estimated cyanide concentrations ranged from 0.12 to 0.18 µg/L. The AWQS of 1 µg/L was met for cyanide during the receiving water sampling at all locations. The cyanide concentrations in the effluent samples collected in conjunction with the receiving water sampling were 0.13 and 0.17 µg/L which are well below the MAEC of 181 µg/L.

Hydrocarbon analyses results are presented in Table 17. Total aromatic hydrocarbons (TAH) defined by the AWQS as BETX (EPA Method 602 samples from the concurrent summer dry sampling) was determined by summing benzene, ethylbenzene, toluene, and total xylenes. For values reported as ND, the reporting limit was used in the summation. Concentrations of TAH at the water quality stations were all ND (≤ 5.4 µg/L) with the exception of Station F1-1 which had a concentration of 6.5 µg/L. Concentrations of TAH were below the AWQS of 10 µg/L at all stations, including both outfall and control stations. Indeed with the exception of toluene at station F1-1 (2.14 µg/L) all BTEX constituents tested below method reporting limits across all stations. The effluent sample had a TAH concentration of 14.4 µg/L, similar to that seen in 2008 and significantly less than the MAEC of 1,810 µg/L.

All concentrations of individual PAHs were summed and reported as total PAHs (TPAH) in Table 17. TPAH concentrations were low with slightly higher concentrations seen at the outfall stations. The TPAH values ranged from 0.025 to 0.070 µg/L at the control stations and from 0.064 to 0.615 µg/L at the outfall stations. The TPAH concentration measured in the effluent sample was 2.767 µg/L. Total aqueous hydrocarbons (TAqH) as determined by the summation PAHs plus BETX were calculated for the six stations and effluent, with the contribution from BETX taken to be ≤ 5.4 µg/L for those stations with all NDs for the BETX contribution (Table 17). Concentrations of TAqH were below the AWQS of 15 µg/L at all stations, including both

Table 16. Concentrations of Dissolved Metals, Total Recoverable Metals, Cyanide, and Total Suspended Solids in Receiving Water and Effluent Samples. Values have not been blank corrected.

Station	Arsenic	Cadmium	Cyanide	Chromium	Copper	Mercury	Nickel	Lead	Silver	Zinc	TSS
	µg/L					ng/L	µg/L				mg/L
Dissolved Metals											
F1-1S (WITHIN ZID)	1.73	0.0758	NA	0.0805	4.08	0.502	1.01	0.0144	0.00676	3.37	NA
F1-2S (ZID BOUNDARY)	1.54	0.0682	NA	0.0693	1.42	0.337	0.996	0.00247	0.00314	0.887	NA
F1-3S (NEAR FIELD)	1.10	0.0649	NA	0.0733	1.69	0.440	1.01	0.00608	0.00160	0.769	NA
C1-1S (CONTROL)	1.36	0.0497	NA	0.0657	1.02	0.330	0.922	0.00445	0.00431	0.386	NA
C1-2S (CONTROL)	1.38	0.0505	NA	0.0652	0.930	0.232	0.864	0.00446	0.00170	0.299	NA
C1-3S (CONTROL)	1.34	0.0655	NA	0.0678	2.01	0.485	0.992	0.0324	0.00366	2.26	NA
EFFLUENT ^a	1.47/1.48	0.118	NA	2.63	27.2	12.5	3.40	0.358	0.141	42.4	NA
DETECTION LIMIT	0.027	0.002	NA	0.030	0.036	0.10	0.023	0.002	0.005	0.027	NA
Total Metals											
F1-1S (WITHIN ZID)	7.98	0.132	0.12 J	15.1	21.0	31.4	14.8	3.99	0.174	49.5	323
F1-2S (ZID BOUNDARY)	6.23	0.138	0.18 J	15.4	21.1	28.2	14.9	3.85	0.173	49.6	260
F1-3S (NEAR FIELD) ^a	5.92	0.112/0.107	NA	12.1/11.2	14.6/14.4	19.0	11.6/10.9	3.35/3.09	0.0699/ 0.0648	32.7/30.9	180
C1-1S (CONTROL) ^a	12.8	0.151	0.14 J	25.4	29.3	53.5/52.2	23.5	7.81	0.119	67.9	440
C1-2S (CONTROL) ^b	6.63	0.0959	0.12 J/ 0.16 J	12.4	14.8	20.8	11.9	3.65	0.0591	33.2	260/320
C1-3S (CONTROL)	14.7	0.165	0.18 J	28.6	33.6	80.2	26.2	10.0	0.143	82.1	700
EFFLUENT ^a	1.84	0.253	0.13 J/ 0.17 J	3.32	42.2	87.4	4.13	2.27	1.19	85.4	51
DETECTION LIMIT	0.027	0.002	1.0	0.030	0.036	0.10	0.023	0.002	0.005	0.027	3.3

^a Field sample value/lab duplicate value (where applicable)

^b Field sample value/field duplicate value (where applicable)

NA Not analyzed. J Estimated value.

Table 17. Supplemental Receiving Water and Effluent Hydrocarbon Analyses.

PARAMETER	CONTROL FLOOD SAMPLES			ZID FLOOD SAMPLES			EFFLUENT
	C1-1S	C1-2S	C1-3S	F1-1S	F1-2S ^a	F1-3S	
Volatile Organics (EPA 602) in µg/L with reporting limit in parenthesis if ND							
Benzene	< (0.400)/ <(0.400)	< (0.400)	< (0.400)	< (0.400)	< (0.400)/ <(0.400)	< (0.400)	< (0.400)
Toluene	< (1.00)/ < (1.00)	< (1.00)	< (1.00)	2.14	< (1.00)/ < (1.00)	< (1.00)	7.75
Ethylbenzene	< (1.00)/ < (1.00)	< (1.00)	< (1.00)	< (1.00)	< (1.00)/ < (1.00)	< (1.00)	1.06
Xylenes (Total)	< (3.00)/ < (3.00)	< (3.00)	< (3.00)	< (3.00)	< (3.00)/ < (3.00)	< (3.00)	5.18
TAH (as BETX)	5.4 / 5.4	5.4	5.4	6.5	5.4 / 5.4	5.4	14.39
Polynuclear Aromatic Hydrocarbons (PAH) by GC/MS in µg/L							
TPAH	0.070	0.025	0.057	0.615	0.066	0.064	2.767
Total Aqueous Hydrocarbons (TAqH) in µg/L							
TAqH ^b	5.5	5.4	5.5	7.1	5.5 / 5.5	5.5	17.2

^a Duplicate field sample or laboratory analysis provided (value/duplicate value)

^b Defined by the State of Alaska as BETX analytes plus PAH analytes from EPA Method 610 analysis; these calculated values include the full suite of PAH analyte values measured by from GERG.

< Below (detection limit).

outfall and control stations. Control stations ranged in TAqH from 5.4 to 5.5 µg/L, while outfall station TAqH concentrations ranged from 5.5 to 7.1 µg/L. The concentration of TAqH in the effluent was estimated at 17.2 µg/L, compared to the MAEC of 2,715 µg/L.

3.2.2 Intertidal Zone and Stream Bacterial Sampling

Intertidal zone and stream bacteriological sampling was performed on 23 June 2009 (Table 18). Refer to Figure 3 for a map of the intertidal station locations and Figure 11 for stream locations. Intertidal sampling began approximately 2 hours prior to high tide at 18:58 ADT and was completed at 19:29 ADT. Two replicates were taken at all intertidal stations. Stream sampling was conducted from 13:15 to 13:50 ADT on 23 June 2009. In addition, replicate effluent samples were collected at the plant at 14:00 ADT on this date for fecal coliform analysis.

Fecal coliform concentrations in the intertidal were very low again this year and ranged from <2.0 to 7 FC MPN/100 mL. The highest fecal concentrations (7 & 4 FC MPN/100 mL) were seen in the replicates at Station IT-4, 250 m east of the diffuser. Fecal coliform concentrations found in Fish, Chester, and Ship Creeks were higher than those seen in 2008 ranging from 7 FC MPN/100 mL in the second replicate at Ship Creek to 1600 FC MPN/100 in the second replicate collected from Fish Creek. The replicate plant effluent samples taken on the same day showed fecal concentrations of 17 and 13 FC MPN/100 mL.

Table 18. Summary of Bacterial Analyses, 23 June 2009.

Station and Replicate	Sample Time (ADT)	Fecal Coliform MPN/100 mL
IT-1 Replicate 1	1929	<2
IT-1 Replicate 2	1929	<2
IT-2 Replicate 1	1927	2
IT-2 Replicate 2	1927	2
IT-3 Replicate 1	1925	2
IT-3 Replicate 2	1925	2
IT-4 Replicate 1	1923	7
IT-4 Replicate 2	1923	4
IT-5 Replicate 1	1921	<2
IT-5 Replicate 2	1921	<2
IT-6 Replicate 1	1919	2
IT-6 Replicate 2	1919	<2
IT-7 Replicate 1	1916	<2
IT-7 Replicate 2	1916	<2
IT-C Replicate 1	1858	<2
IT-C Replicate 2	1858	2
Plant Effluent Rep. 1	1400	17
Plant Effluent Rep. 2	1400	13
Fish Creek Rep. 1	1350	900
Fish Creek Rep. 2	1350	1600
Chester Creek Rep.1	1337	22
Chester Creek Rep.2	1337	80
Ship Creek Rep. 1	1315	8
Ship Creek Rep. 2	1315	7




Figure 11. Stream and Intertidal Fecal Coliform Bacteria Sampling Locations.

4.0 QUALITY ASSURANCE/QUALITY CONTROL

4.1 OBJECTIVES

The monitoring program includes a comprehensive quality assurance/quality control (QA/QC) program that encompasses all aspects of the project, from initial sample collection and field observation recording through laboratory analysis and data analysis to reporting. The objectives of the QA/QC program were to fully document the field and laboratory data collected, to maintain and document data quality, and to ensure that the data collected are accurate, representative, and complete and are comparable with data collected through other EPA-regulated NPDES programs. The monitoring program was designed to allow the data to be assessed by the following parameters:

- Precision
- Accuracy
- Comparability
- Representativeness
- Completeness

Precision is a measure of agreement among repeated measurements of the same property which was assessed through duplicate and triplicate sampling and analysis. Accuracy is measure of the overall agreement of a measurement to a known value and includes a combination of random error (precision) and systematic error (bias) that are due to sampling and analytical operations. For this program these were assessed in field by comparing field instrumentation to known standards and in the laboratory by running standard reference material, performing blank spikes, matrix spikes, and comparing instrumentation to calibration standards. Comparability is a measure of the confidence with which one data set or method can be compared to another which was assured by utilizing standard EPA and other accepted sampling and laboratory protocols that could be traced back to known standards and using standard units of measure, such as navigational information that could be traced back to a know datum. Representativeness is the measure of the degree to which data accurately and precisely represent a characteristic of a population, parameter variations at a sampling point, or an environmental condition. This was assessed by determining sampling variability at a location by repeated sampling that then could be compared to laboratory variability. Completeness is a measure of the amount of valid data obtained that then can be compared to the amount of anticipated data as outlined in the project workplan.

These parameters were controlled by adhering to documented methods and procedures, by the analysis of quality control (QC) samples on a routine basis, the use of contract laboratories with existing QA/QC plans, accepted and defined data review and verification procedures, and a comprehensive sample documentation program. Throughout the program, KLI coordinated with the subcontracting laboratories to ensure that their in-house QA/QC programs were being implemented to meet the required standards.

Quality control activities in the field included adherence to documented procedures, including those in the program workplan, and the comprehensive documentation of sample collection and sample identification information. Sample integrity and identification were ensured by a rigidly-enforced chain of custody program. The chain of custody procedure documents the handling of each sample from the time the sample was collected to the arrival of the sample at the laboratory.

Analytical methods in use throughout the program have been approved and documented by EPA. These methods were used as project-specific protocols to document and guide analytical procedures. Adherence to these documented procedures ensures that analytical results are properly obtained and reported.

4.2 FIELD QUALITY CONTROL

Quality control activities in the field consisted of the following:

- adherence to documented procedures in the monitoring program workplan
- cross-checking of field identifications, measurements, and recording to ensure consistency, accuracy, and completeness of field logs.
- comprehensive documentation of field observations, sample collection, sample identification information, and navigation and drogue position information.

Sampling procedures proposed for this project have been successfully used for a number of years on the Asplund WPCF monitoring program. The use of documented and well-known procedures provides for greater likelihood of obtaining environmental samples uncontaminated by sampling procedures or apparatus. The use of project-specific field forms and data entry sheets also provide guidance to assure completeness of field data. Adherence to these procedures and use of these project documents helped ensure that data collected over the course of the project were complete, comparable, and accurate and that the study results are representative of conditions existing at the sampling sites.

4.2.1 Documentation

For observations made in the field, cross-checking between personnel was used as the primary method of quality control. These included, for example, review of navigational information recorded on the drogue field log. As described in Section 2.5, sample documentation began in the field using pre-printed log forms, labels, chain of custody (COC) forms, and pre-determined sample identification numbers that were designed specifically for use on this project. This extensive field documentation provided a paper trail that exists for each sample or field observation and ensures credibility of the data. All field records were reviewed by the field crew leader as soon as possible after sampling was completed. After review and verification, field logs were filed at the KLI Anchorage office upon return from the survey.

Sample integrity and identification were ensured by the COC program. The chain of custody procedure documented the handling of a sample from the time the sample was collected to the receipt of the sample at the analytical laboratory. At the time of shipment, the field personnel kept a copy of the completed chain of custody form, and the original accompanied the samples to the laboratory.

4.2.2 Sample Handling

Samples were frozen, chilled, and/or preserved as required by the appropriate methods in the field and until receipt at the laboratory. Samples were packed in coolers along with the completed COC forms for shipment to analytical facilities as described in Section 2.0. Coolers were securely packed with ice packs as required and custody sealed with signed and dated fiber

tape for shipment. Upon receipt by the laboratory the condition of the samples were noted on the COC form including; cooler temperature, broken or missing samples, etc.

4.2.3 Navigation

As described previously, navigation was accomplished with a DGPS system. The accuracy of the DGPS coordinates were verified by positioning the vessel over the diffuser during a low slack tide when the boil was evident and comparing DGPS readings with the known outfall location. Historical intertidal stations were re-acquired using a hand-held DGPS, distance and bearings, and visual sightings to temporary benchmarks and landmarks. All station information was entered on the appropriate field logs and reviewed by the field leader.

4.2.4 Field Instrumentation

Field equipment used for collection, measurement, and testing was subject to a strict program of control, calibration, adjustment, and maintenance. Care was taken to ensure that the instruments used for field measurements of temperature, salinity, DO, and pH were calibrated and checked with appropriate standards prior to and after each sampling event. The standards of calibration are in accordance with applicable criteria such as the U.S. Bureau of Standards, American Society of Testing and Materials (ASTM) Standards or National Institute of Standards and Technology (NIST), and follow the instrumentation manufacturer's recommended procedures.

Temperature calibration was ensured by pre-calibration at the factory with calibration checks of the electronic temperature sensor against a research grade NIST traceable thermometer reading taken from the same sample at the same time. The electronic sensor for salinity (conductivity) was also pre-calibrated at the factory and field checked against six ambient water samples which were collected for the analysis of salinity (SM 2520B) and compared to a certified Copenhagen Seawater Standard to verify the proper operation at the time of sampling. The DO probe was also pre-calibrated at the factory and field checked by comparison to saturated seawater. For pH, the probe was pre-calibrated using three known buffer solutions and checked in the field with a second field probe and three known buffer solutions.

4.2.5 Sampling Variability

Sampling variability was documented by sampling three replicates at one station for the water quality parameters. This included three replicate Niskin[®] bottle casts to obtain replicate turbidity samples and three replicate grabs at the surface for fecal coliform, color, and TRC analyses. In addition, triplicate casts of the CTD for pH, DO, temperature, and salinity were performed at one station in order to check reading variability from the probe's electronic sensors.

4.2.6 Field Check Samples

Field check samples include trip blanks for volatile organic analyses for EPA Methods 602 and 624, field blanks, field generated duplicates, standard reference materials (SRMs), or other samples of known concentration that may be sent to the laboratory. With the exception of the trip blanks which are initiated at the laboratory, field blanks and field duplicates samples were sent to the laboratory as blind samples to ensure unbiased reporting of results.

4.3 LABORATORY QUALITY CONTROL

Analytical quality control for this project included the following:

- adherence to documented and approved procedures, including EPA, Standard Methods, etc., internal laboratory protocols, and respective laboratory QA/QC programs
- calibration of analytical instruments
- ability of each analytical laboratory to meet analytical precision, accuracy, limits of detection, and limits of quantification that meet EPA requirements
- use of quality control samples, internal standards, and surrogate solutions

The analytical laboratories used on this project operate under the quality assurance (QA) programs described in their QA management plans. These programs involve the participation of qualified and trained personnel; the use of standard operating procedures for analytical methodology and procedures; a rigorous system of documenting and validating measurements; maintenance and calibration of instruments; and the analysis of quality control samples for precision and accuracy tracking. The pertinent methods descriptions the laboratories are following are comprehensive and provide information concerning proper sample collection, receipt and login, processing, storage, and preservation; required apparatus and materials; analytical procedure; standardization and calibration techniques; quality control samples required; methods of calculating values and assessing data quality; and reporting and performance criteria.

4.3.1 Documentation

Documentation in the laboratory included signing the original COC forms, documenting sample condition upon receipt, and generating the internal documents that track samples through the laboratory (e.g., sample control logs, refrigerator logs, etc.). Any deviations from the prescribed methods or internal laboratory standard operating procedures (SOPs) were documented by the laboratory and included in a case narrative with the analysis report. Data affected by such deviations were appropriately qualified, as was any data that did not meet acceptable quality criteria. Typical data qualifiers included those denoting estimated concentrations (J) or not detected (ND or U), and method blank contamination (B).

4.3.2 Calibration

Calibration is an integral part of any instrumental analysis. Calibration requirements for each type of analysis to be used on this project are described in the appropriate methods. Typically, instrument calibration was performed daily or on a per batch basis as required by the method.

4.3.3 Quality Control Procedures

Internal laboratory quality control checks included the use of surrogate solutions and quality control samples such as procedural (or method) blanks, matrix spike/spike duplicates, standard reference materials (SRMs), method required QC check samples, and duplicates as specified in the EPA approved analytical procedures. In addition contract laboratories took part in EPA's annual DMRQA program to verify accuracy of their data. Surrogate compounds were spiked into samples as appropriate to assess individual sample matrix effects on sample analysis. This included QC samples such as procedural blanks and matrix spike samples. Surrogate compound

analyses were reported in percent recovery. Results from quality control samples allowed the laboratory to assess quality assurance parameters such as accuracy and precision of the data. Any data falling outside the acceptable criteria as defined in the methods were appropriately investigated by the laboratory, qualified, and described in the sample case narrative.

Method blanks are pure, organic- and/or metal-free reagent water that are run through the analysis process and used to verify that analyte concentrations are accurate and do not reflect contamination. Method blanks were analyzed as called for by each method, typically one per sample batch.

Laboratory accuracy was assessed by routine spiking of environmental samples with a standard addition as called for by the appropriate method. These sample matrix spikes and matrix spike duplicates (MS/MSD) were run on the organic analyses collected as part of both the in-Plant and receiving water monitoring components of the program. These spike samples are fortified with components of interest as required by the method following the initial analysis to check the ability of the method to recover acceptable levels and to determine accuracy of the data. Quality control charts are prepared and maintained by the laboratories where applicable to show the range of individual measurements encountered by following procedures such as those outlined EPA method guidance documents or in *Design of 301(h) Monitoring Programs for Municipal Wastewater Discharges to Marine Waters* (EPA, 1982b) and other guidance documents (e.g. EPA, 1994a and 1994b).

Trace metals analyses for the monitoring were supported through the use of certified standard reference materials (SRMs), which are quality control reference materials with known metals values that are obtained from the National Bureau of Standards and other sources. These SRMs were analyzed by the laboratory at the same time as the program samples in order to ensure laboratory accuracy. Results of the analyses of SRMs should fall within acceptable limits and can be expressed as percent recovery.

For receiving water quality samples, analytical and instrument variability was checked by laboratory splitting of one larger-volume field sample per sampling event into triplicates and analyzing the subsamples for the various water quality parameters. The individual measurements and concentration ranges were reported for each parameter of each split. In addition, duplicate analyses of samples split in the laboratory were used as a means to assess laboratory precision.

For other water quality parameters, the following summary of QA/QC procedures apply:

- Fecal Coliform Bacteria: *Escherichia coli* was used as a positive control for each analytical run. *Pseudomonas aeruginosa* was used as a negative control, and buffered dilution water was used as a blank. In addition, 10 % of the samples were run in duplicate.
- Enterococci Bacteria: *Streptococcus faecalis* was used as a positive control for each analytical run. *Escherichia coli* was used as a negative control, and buffered dilution water was used as a blank.

- Color: Fresh color standards were made prior to the beginning of the program. Samples were allowed to settle and decanted in the field and either pre-treated with paper filtration or centrifuged to remove turbidity and reported as "true color".
- Turbidity: The instrument was calibrated with a 20.0 NTU standard provided by the manufacturer. Due to the high turbidity in Cook Inlet, all samples were run at either the 10X or 100X scale on the nephelometer to ensure that the measured turbidities were within the range of the instrumentation. In addition, select samples were run in duplicate.
- Total Residual Chlorine: TRC was quantified with an ion selective electrode probe (SM4500 Cl-G) which requires a blank, blank spikes, and a series of laboratory calibration standards. To account for seawater matrix interference issues, the method blank and calibration standards were prepared with Cook Inlet background seawater.
- Salinity: Sensor is factory calibrated at a minimum of once per year and field checked with either a refractometer or salinometer.

4.3.4 Method Detection Limits

Depending on each laboratory's adopted terminology, the method detection limits (MDLs), practical quantitation limits (PQLs), or method reporting limits (MRLs) for the various analytes were determined using the appropriate method as described in the protocols. These MDLs, PQLs, and MRLs were reported with the data (see appendices) and are included in summary data tables as appropriate. Concentrations below the PQL, or MRL were typically qualified with the "ND" code for non-detect or "J" when reported as an estimated value.

4.4 DATA REVIEW AND VALIDATION

Data were verified by performing comparisons of final data against the original documentation, including the workplan, field logs and data sheets, and analytical reports. Any discrepancies were fully documented in the program files and described where necessary in the annual report. Data were validated according to accuracy, precision, and completeness for both the field sample collection and analytical laboratory components of the program. Qualitative evaluation and statistical procedures were used to check the quality of the field and chemical data as appropriate. The primary goals of these review and validation procedures are to ensure that the data:

- are representative of conditions in the study area
- are accurate
- demonstrate the required level of precision
- are comparable with data from other NPDES programs
- are acceptable for use as a tool to evaluate permit compliance
- allow independent technical appraisal of the program's ability to meet the monitoring program objectives.

Analytical data were subjected to review upon receipt from the laboratory following guidelines such as those published in *U.S. EPA Contract Laboratory Program National Functional Guidelines for Inorganic Data Review* (EPA 1994a), or *U.S. EPA Contract Laboratory Program National Functional Guidelines for Organic Data Review* (EPA 1994b). Items reviewed during

data validation included sample holding times, results for laboratory method blanks, matrix spike/spike duplicates (MS/SD), check standards or SRMs, field and laboratory duplicates, field and trip blanks, report completeness, and laboratory performance (i.e., ability to achieve method detection limits and adherence to QA/QC criteria established for this program). Items failing to meet such validation and review procedures were noted and corrected, if possible. Items that could not be corrected and fell outside of acceptable limits (e.g., a sample analyzed outside holding time) have been noted in data tables and in the appendices of this annual report if they occurred.

4.5 QUALITY ASSURANCE/QUALITY CONTROL RESULTS

4.5.1 Field Instrumentation and Sampling Quality Control Results

For influent, effluent, and sludge monitoring, field-generated duplicate influent and/or effluent samples were collected for the analysis of pesticides and enterococci bacteria during the June 2009 sampling. Results for these duplicate analyses are provided in Table 9 and the appendices, and were found to be within acceptance limits. Results from duplicate field samples collected for certain parameters during the receiving water sampling such as volatile organics, metals, cyanide, turbidity, and TSS are reported in the appropriate tables (Table 15, Table 16, and Table 17), and were found to be within acceptance limits.

Field blanks were collected for several parameters during each sampling event by pouring HPLC-grade deionized (DI) water into the appropriate sampling containers with the correct preservative. Trip blanks consisted of DI blank samples prepared at the laboratory that went through the same shipping and handling procedures as all the other sample containers of each analytical type; these remained unopened in the field. The field blanks, trip blanks and method blanks analyzed using EPA Method 602 showed no measurable levels of the target compounds during the receiving water monitoring (Appendix C2).

The trip blank analyzed in conjunction with the EPA 624 analyses for June showed trace levels of methylene chloride. The field generated blank prepared with the Asplund laboratory DI water analyzed in conjunction with the EPA 624 analyses for June showed quantifiable levels of benzene, bromodichloromethane, chloroform, methylene chloride, toluene, and xylenes. The associated method blank was a non-detect for all tested compounds (Appendix A1). During the July sampling, the EPA 624 trip and field blanks showed trace levels of methylene chloride and the trip blank showed trace levels of acetone. The associated method blank showed no quantifiable level for tested compounds. (Appendix B1) Methylene chloride was detected in the influent and effluent for both June and July sampling events. The source of contamination in the trip and field generated blanks is unknown, although acetone and methylene chloride are common laboratory contaminants that often shows up in both field samples and laboratory blanks. The toluene and xylenes in the blanks may have been introduced during transport if the samples were exposed to fuel or combustion fumes. Additional field generated check samples will be utilized for the 2010 monitoring effort to investigate the source of contamination.

Sampling variability for water quality parameters (fecal coliform, color, turbidity, and TRC) was determined by analyzing three discrete surface samples taken at Station C2-2S (Table 19). Where appropriate, the mean, standard deviation, and coefficient of variation are included in Table 19 to provide a measure of variability for parameters. The coefficient of variation for the various sample types was found to be 0 % for color, 0 % for TRC and 3.6 % for turbidity.

Table 19. Sampling and Laboratory Variability for Water Quality Samples, 23 and 24 June 2009.

Station	Subsample Designation	Fecal Coliform* (MPN/100 mL)	Color (units)	Turbidity (NTU)	TRC (mg/L)
SAMPLING VARIABILITY					
C2-2S	A	<2 [---]	<5	330	<0.010
	B	<2 [---]	<5	355	<0.010
	C	2 [1.0-10]	<5	342	<0.010
Mean	---	---	<5	342	<0.010
Standard Deviation	---	---	0	12.5	0
Coefficient of Variation (%)	---	---	0	3.6	0
LABORATORY VARIABILITY					
C3-1S	A	<2	<5	295	<0.010
	B	<2	<5	300	<0.010
	C	<2	<5	290	<0.010
Mean	---	---	<5	295	<0.010
Standard Deviation	---	---	0	5	0
Coefficient of Variation (%)	---	---	0	1.7	0
E1-1S	A	NA	<5	NA	NA
	B	NA	<5	NA	NA
Relative % Difference	---	---	0	---	---
E1-4S	A	NA	NA	213	NA
	B	NA	NA	220	NA
Relative % Difference	---	---	---	3.2	---
E3-1S	A	NA	NA	365	NA
	B	NA	NA	375	NA
Relative % Difference	---	---	---	2.7	---
E3-3S	A	NA	<5	NA	NA
	B	NA	<5	NA	NA
Relative % Difference	---	---	0	---	---
F1-1S	A	NA	NA	NA	0.0625
	B	NA	NA	NA	0.0864
Relative % Difference	---	---	---	---	32.1
F1-2B	A	NA	NA	294	NA
	B	NA	NA	291	NA
Relative % Difference	---	---	---	1.0	---
F2-3S	A	NA	NA	440	NA
	B	NA	NA	442	NA
Relative % Difference	---	---	---	0.5	---
F3-1S	A	NA	<5	NA	NA
	B	NA	<5	NA	NA
Relative % Difference	---	---	0	---	---
F3-4S	A	NA	NA	397	NA
	B	NA	NA	399	NA
Relative % Difference	---	---	---	0.5	---

Table 19. Sampling and Laboratory Variability for Water Quality Samples, 23 and 24 June 2008. (continued)

Station	Subsample Designation	Fecal Coliform* (MPN/100 mL)	Color (units)	Turbidity (NTU)	TRC (mg/L)
C1-1S	A	NA	NA	NA	<0.010
	B	NA	NA	NA	<0.010
Relative % Difference	---	---	---	---	0
C1-2S	A	NA	NA	NA	<0.010
	B	NA	NA	NA	<0.010
Relative % Difference	---	---	---	---	0
C1-3B	A	NA	NA	590	NA
	B	NA	NA	600	NA
Relative % Difference	---	---	---	1.7	---
C2-3M	A	NA	NA	538	NA
	B	NA	NA	532	NA
Relative % Difference	---	---	---	1.1	---

* 95% confidence intervals indicated in brackets (American Public Health Association, 1998. Standard Methods for the Examination of Water and Wastewater. 20th Edition. Washington, D.C. Table 9221.IV.)

NA Not analyzed

--- Not applicable

Three replicate fecal coliform samples were also collected at Station C2-2. Two of the three samples yielded the same result (<2 FC MPN/100 mL) while the third yielded a result of 2 FC MPN/100 mL. Mean, standard deviation, and coefficient of variation are not determined for fecal coliform due to the nature of the analysis which yields only a most probable number of bacteria per 100 mL. Instead, the ± 95 % confidence limits for each sample are typically provided. Fecal coliform values were within the confidence limits.

Variability and calibration checks of the electronics probe were done by performing repeated profiles of temperature, pH, DO, and salinity at one station (C2-2). Results of these calibration checks for the Seabird CTD show that probe variability for temperature, pH, and DO was extremely low in all cases with a coefficient of variation of ≤ 0.39 % (Table 20). Probe variability for salinity was only slightly higher with a maximum coefficient of variation of ≤ 1.13 %; seen at the bottom, with lower variability seen at shallower depths in the water column. In addition, a precision thermometer was used to verify CTD temperature readings, and all of the CTD sensors were factory-calibrated prior to field deployment. The salinity, temperature, DO, and pH probes were found to be accurate and within calibration during the survey.

4.5.2 Laboratory Quality Control Results

Full analytical data and laboratory case narratives are provided by most laboratories and are included in the appendices. Laboratory duplicate analyses, where performed, were found to have a high degree of precision and were within the acceptance criteria for relative percent difference (RPD). Laboratory duplicates were performed for a number of organic analyses and were found to be within acceptance limits. The compound 4,4-DDT exceeded 40 % RPD between the primary and confirmation columns in the June 2009 influent and effluent samples. During the July 2009 sampling event, one pesticide in the influent and one in the effluent also exceeded RPD criteria. All data were appropriately qualified and full laboratory case narratives appear in Appendices A1 and B1.

In addition to the standard laboratory QC procedures, color and turbidity samples collected at Station C3-1 during the receiving water sampling were split in the laboratory and analyzed in triplicate. Mean, standard deviation, and coefficient of variation are reported in Table 19 for these samples. Coefficient of variation was shown to be 0 % for color and 1.7 % for turbidity. For analyses where samples were run in duplicate, such as TRC, turbidity, and color, the relative percent difference between duplicates was calculated. The RPDs for laboratory duplicate analyses were found to generally be very low and within acceptable limits. Duplicate results for turbidity ranged from 0.5 to 3.2 % RPD. Color duplicate results showed 0 % difference between duplicates. Duplicate TRC analyses ranged from 0 to 32.1 % RPD.

Laboratory accuracy was assessed through the use of surrogate recoveries, sample and control spikes and duplicates, and SRMs. Detailed QA/QC results for all contract laboratory analyses are provided in the appendices corresponding to each analysis. Surrogates are compounds that were added to each sample and QC sample that were analyzed by GC methodology, such as volatile organic compounds (EPA 602 and 624/8260B), semi-volatile organic compounds (EPA 625/8270C), pesticides (EPA 608/8081A/8082 and 614/8141A), and dioxins (EPA 8280A). Some instances of surrogate recoveries outside QC recovery limits were found during the 2009 influent, effluent, and sludge monitoring effort. These deviations are discussed in the case

Table 20. Seabird SEACAT SBE-19 CTD Probe Variability Check, 24 June 2009.

Depth (m)	Temperature (°C)			Salinity (ppt)			pH (units)			DO (mg/l)			Mean (units)				Standard Deviation				Coeff. of Variation (%)			
C2-	2A	2B	2C	2A	2B	2C	2A	2B	2C	2A	2B	2C	Temp	Sal	pH	DO	Temp	Sal	pH	DO	Temp	Sal	pH	DO
0.5	12.64	12.71	12.67	10.87	10.87	10.88	7.94	7.95	7.97	9.71	9.66	9.67	12.68	10.88	7.95	9.68	0.038	0.005	0.011	0.026	0.30	0.04	0.14	0.27
1.0	12.58	12.67	12.66	10.86	10.87	10.89	7.95	7.96	7.96	9.70	9.67	9.69	12.64	10.87	7.96	9.69	0.048	0.013	0.010	0.014	0.38	0.12	0.12	0.14
1.5	12.57	12.64	12.64	10.86	10.86	10.90	7.95	7.97	7.96	9.69	9.68	9.68	12.62	10.87	7.96	9.68	0.038	0.021	0.011	0.006	0.30	0.20	0.14	0.06
2.0	12.57	12.61	12.61	10.86	10.86	10.91	7.95	7.97	7.97	9.71	9.68	9.67	12.60	10.88	7.96	9.69	0.026	0.028	0.009	0.022	0.20	0.25	0.11	0.23
2.5	12.56	12.59	12.58	10.86	10.87	10.92	7.96	7.97	7.97	9.72	9.68	9.68	12.58	10.88	7.96	9.69	0.015	0.033	0.006	0.022	0.12	0.30	0.07	0.23
3.0	12.55	12.58	12.57	10.86	10.87	10.93	7.96	7.97	7.97	9.72	9.69	9.69	12.57	10.89	7.97	9.70	0.012	0.036	0.004	0.018	0.09	0.33	0.05	0.19
3.5	12.55	12.57	12.57	10.86	10.88	10.93	7.96	7.97	7.97	9.72	9.69	9.68	12.57	10.89	7.97	9.70	0.012	0.038	0.005	0.023	0.09	0.35	0.06	0.24
4.0	12.55	12.57	12.57	10.86	10.89	10.94	7.97	7.97	7.97	9.73	9.69	9.68	12.56	10.90	7.97	9.70	0.011	0.038	0.004	0.026	0.09	0.35	0.05	0.27
4.5	12.55	12.57	12.57	10.86	10.90	10.94	7.97	7.97	7.97	9.73	9.69	9.67	12.56	10.90	7.97	9.70	0.010	0.039	0.003	0.028	0.08	0.36	0.04	0.29
5.0	12.56	12.57	12.57	10.87	10.90	10.94	7.97	7.97	7.97	9.74	9.69	9.69	12.57	10.90	7.97	9.70	0.008	0.039	0.002	0.027	0.07	0.36	0.02	0.28
5.5	12.56	12.57	12.57	10.87	10.91	10.95	7.97	7.97	7.97	9.74	9.69	9.70	12.57	10.91	7.97	9.71	0.006	0.040	0.003	0.025	0.05	0.36	0.03	0.26
6.0	12.56	12.57	12.57	10.87	10.91	10.96	7.97	7.97	7.98	9.74	9.70	9.71	12.57	10.91	7.97	9.71	0.006	0.040	0.004	0.021	0.04	0.37	0.05	0.22
6.5	12.56	12.57	12.57	10.88	10.91	10.97	7.97	7.97	7.97	9.74	9.69	9.72	12.57	10.92	7.97	9.71	0.005	0.047	0.002	0.023	0.04	0.43	0.02	0.24
7.0	12.57	12.57	12.57	10.88	10.91	10.99	7.97	7.97	7.98	9.75	9.68	9.70	12.57	10.93	7.97	9.71	0.003	0.057	0.001	0.033	0.02	0.52	0.01	0.34
7.5	12.57	12.57	12.57	10.90	10.91	11.01	7.97	7.97	7.97	9.75	9.71	9.69	12.57	10.94	7.97	9.72	0.003	0.062	0.003	0.031	0.02	0.57	0.04	0.32
8.0	12.57	12.57	12.57	10.92	10.91	11.02	7.97	7.97	7.97	9.74	9.72	9.71	12.57	10.95	7.97	9.72	0.003	0.064	0.002	0.018	0.02	0.58	0.02	0.18
8.5	12.57	12.57	12.57	10.92	10.91	11.04	7.97	7.97	7.97	9.76	9.72	9.73	12.57	10.96	7.97	9.73	0.004	0.068	0.002	0.019	0.03	0.62	0.02	0.19
9.0	12.57	12.57	12.56	10.93	10.92	11.06	7.98	7.97	7.97	9.77	9.72	9.73	12.57	10.97	7.97	9.74	0.004	0.078	0.003	0.028	0.04	0.71	0.04	0.29
9.5	12.57	12.57	12.56	10.93	10.92	11.07	7.98	7.97	7.97	9.76	9.72	9.74	12.57	10.97	7.97	9.74	0.005	0.084	0.002	0.017	0.04	0.76	0.03	0.17
10.0	12.57	12.57	12.56	10.93	10.92	11.07	7.97	7.97	7.97	9.75	9.75	9.74	12.57	10.97	7.97	9.74	0.005	0.084	0.001	0.008	0.04	0.77	0.01	0.08
10.5	12.57	12.57	12.56	10.93	10.92	11.06	7.98	7.97	7.97	9.76	9.75	9.74	12.57	10.97	7.97	9.75	0.005	0.079	0.003	0.013	0.04	0.72	0.03	0.13
11.0	12.57	12.57	12.56	10.93	10.92	11.08	7.97	7.97	7.97	9.78	9.74	9.75	12.57	10.98	7.97	9.76	0.005	0.092	0.000	0.017	0.04	0.84	0.00	0.18
11.5	12.57	12.57	12.56	10.92	10.92	11.08	7.98	7.97	7.97	9.80	9.74	9.76	12.57	10.98	7.97	9.77	0.005	0.093	0.003	0.032	0.04	0.85	0.03	0.33
12.0	12.57	12.57	12.56	10.92	10.92	11.08	7.97	7.97	7.97	9.80	9.73	9.76	12.57	10.97	7.97	9.76	0.005	0.091	0.001	0.033	0.04	0.83	0.01	0.34
12.5	12.57	12.57	12.56	10.92	10.92	11.10	7.98	7.98	7.97	9.80	9.74	9.75	12.57	10.98	7.97	9.76	0.005	0.104	0.002	0.031	0.04	0.95	0.02	0.32
13.0	12.57	12.57	12.56	10.92	10.93	11.12	7.97	7.97	7.97	9.81	9.75	9.75	12.57	10.99	7.97	9.77	0.006	0.113	0.002	0.031	0.04	1.03	0.02	0.32
13.5	12.57	12.57	12.56	10.92	10.97	11.14	7.97	7.97	7.97	9.81	9.76	9.76	12.57	11.01	7.97	9.78	0.007	0.118	0.001	0.028	0.06	1.07	0.01	0.29
14.0	12.57	12.56	12.56	10.92	11.04	11.13	7.98	7.97	7.97	9.82	9.74	9.78	12.57	11.03	7.97	9.78	0.006	0.105	0.004	0.039	0.05	0.95	0.05	0.39
14.5	12.57	12.56	12.56	10.92	11.11	11.13	7.98	7.97	7.97	9.80	9.74	9.78	12.56	11.05	7.97	9.77	0.008	0.116	0.006	0.032	0.07	1.05	0.07	0.33
15.0	12.57	12.56	12.56	10.92	11.13	11.13	7.98	7.97	7.97	9.81	9.76	9.78	12.56	11.06	7.97	9.78	0.008	0.121	0.005	0.026	0.06	1.10	0.06	0.27
15.5	12.57	12.56	12.56	10.92	11.15	11.12	7.98	7.97	7.97	9.82	9.76	9.80	12.56	11.06	7.97	9.79	0.009	0.125	0.005	0.029	0.07	1.13	0.07	0.29

narratives that were provided by each laboratory which fully detail all QC issues for both sampling events and explain any QC deviations; these are provided in the appendices. As indicated by the laboratories, the data were not significantly affected by any QC issue.

Matrix spike (MS), matrix spike duplicate (MSD), laboratory control spike (LCS), and duplicate control spike (DCS) are samples and blanks that are spiked with target compounds of interest to determine percent recovery and relative percent difference between duplicates. The QC criteria include an acceptable recovery range and an RPD that should not be exceeded. Total metals, dissolved metals, cyanide, volatile organic compounds, and semi-volatile organic compounds met QC criteria for MS, MSD, LCS, and DSC with few exceptions for all analyses on the program. Detailed case narratives were provided by each laboratory which fully detail all QC issues for both sampling events and explain any QC deviations; these are provided in Appendices A1, A2, B1, B2, C1, C2, C3, and C4.

Trace metals analyses for the influent, effluent, sludge, and receiving water testing were supported through the use of SRMs, which are quality control reference materials with known metals values that are obtained from the National Bureau of Standards, National Institute of Standards and Technology, or other certified standards. These SRMs were analyzed by the laboratories at the same time as the project samples in order to ensure laboratory accuracy. Results of the analyses of SRMs should fall within acceptable limits and can be expressed as percent recovery. All metals SRM results were within acceptance limits (Appendix C4).

Method blanks (or procedural blanks) were also analyzed for most analyses on the program. Method blanks consist of pure, organic- or metal-free reagent grade water that is run through the analysis process and used to verify that analyte concentrations are accurate and do not reflect contamination. With the exception of the laboratory method blank for July 2009 sludge trace metals, all method blank results for the program showed no contamination during 2009. The sludge blank showed trace levels of lead, and zinc in July; associated data is qualified with a B. (Table 10). A detailed case narrative for these samples provided by the laboratory which fully details all QC issues is provided in Appendix A1 and B1.

During the receiving water program, trace levels of metals were detected at their MDLs in the method blanks for the ultra-low level metals analyses that were performed by Battelle. This is typical for ultra-low level metals analyses, in that trace levels are seen in method blanks in the low parts per trillion range and is not an indication of contamination. Metals concentrations seen in the receiving water were 2-3 orders of magnitude higher than that seen in these method blanks and all other QC criteria were within acceptance limits, therefore no further action was necessary or taken.

The method blank analyses performed with the TSS analyses showed no results above method detection limits. In addition to the typical method blanks, buffered dilution water was used as a blank for fecal coliform and enterococci bacteriological analyses. All blanks run for fecal coliform and enterococci showed no growth. In accordance with the laboratories QA/QC policy, all sample results less than twenty times the level found in the method blank were flagged as estimated concentrations.

5.0 DISCUSSION

5.1 INFLUENT, EFFLUENT, AND SLUDGE MONITORING

The NPDES permit for the Asplund WPCF requires compliance with applicable State water quality standards as promulgated in Chapter 70 of the Alaska Administrative Code entitled "Water Quality Standards" (18 AAC 70; ADEC, 1999). This chapter requires that criteria outlined in "EPA Quality Criteria for Water" (also known as "The Red Book"; EPA, 1976), the revised quality criteria for water (EPA 1986b), and other applicable criteria as referenced in the AWQS be met in applicable receiving waters at every point outside of the ZID boundary. Also, as noted in Section 1.1.1, the State of Alaska water quality regulations include SSWQC for the Point Woronzof area of Cook Inlet for turbidity and the dissolved fraction of arsenic, cadmium, hexavalent chromium, copper, lead, mercury, nickel, selenium, silver, and zinc. Since the issuance of the current permit, EPA has approved ADEC's proposed use of dissolved metals for all of the State's marine water quality criteria, approved all of ADEC's proposed SSWQC for Upper Cook Inlet, and removed Alaska from the National Toxics Rule list (EPA 2006; Sept. 15, 2006 letter to ADEC). Except for cadmium and mercury, where the dissolved standard changed from 9.3 to 8.8 µg/L for cadmium and from 0.025 to 0.94 µg/L for mercury, all other AWQS metals criteria are the same as those in the SSWQC. Even though EPA has approved the use of dissolved metals criteria for the AWQS, the current SSWQC will most likely remain in affect for the Point Woronzof area for permit renewal as those are also listed in the current AWQS. To be conservative, we have used the more restrictive criteria for dissolved cadmium and mercury to evaluate the data in this report. For other parameters such as TRC we have utilized the current AWQS (ADEC 2009), since those criteria will be utilized for the permit renewal process. Finally, the permit itself includes some effluent limitations that must be met. The following sections discuss the parameters of concern in regards to the requirements of the NPDES permit or the AWQS as well as historical data from the WPCF, other POTWs, and other EPA data.

5.1.1 Influent and Effluent Monitoring

Table 21 lists permit effluent limitations and water quality criteria that are applicable to the current NPDES permit; it includes each of the parameters required to be monitored by the permit. Most of the values shown are the chronic toxicity criteria for salt water aquatic life. Chronic toxicity criteria concentrations are lower than acute toxicity criteria concentrations; therefore, the more stringent of the two values were used here for comparison. The MAEC for each constituent was calculated from the outfall design dilution factor of 142:1 (conservative substances) or 180:1 (non-conservative; TRC, ammonia, etc.), the water quality criteria, and the natural background concentrations as determined historically at the control site near Point MacKenzie. It was assumed that the final effluent would be diluted by a minimum factor of 142 by the time it reached the boundary of the ZID. For most metals, the MAECs were calculated from the SSWQC for dissolved metals contained in the AWQS for the Point Woronzof area.

To determine compliance with State water quality standards, Table 21 values have been compared with effluent values found in Table 8 through Table 11 as well as those in Table 16 and Table 17. The AWWU 2009 maximum effluent concentrations shown in Table 21 were the maximum encountered during the calendar year either during AWWU's in-plant monitoring, the toxic pollutant and pesticide monitoring events, pretreatment monitoring, or the supplemental effluent monitoring that was performed as part of the receiving water sampling. For metals, both total and dissolved concentrations in the effluent were compared against their MAEC, since it is

Table 21. NPDES Requirements, State of Alaska Water Quality Standards, and AWWU 2009 Maximum Concentrations for Effluent Comparisons.

Parameter	Receiving Water Quality Standard ^a		Maximum Allowable Effluent Concentration ^b (MAEC)	AWWU 2009 Maximum Effluent Concentration ^c
Antimony (µg/L)	146	Human health, not listed for saltwater aquatic life	20,607	ND (1.00) ^{d,e}
Arsenic (µg/L)	36	Chronic toxicity, measured as dissolved	4,882	1.84 ^f
Beryllium (µg/L)	11	For the protection of aquatic life in soft fresh water	1,513	ND (0.400) ^{d,e}
Cadmium (µg/L)	9.3 (8.8) ^k	Chronic toxicity, measured as dissolved	1,322 (1,250)	0.253 ^f
Chromium (VI) ^h (µg/L)	50	Chronic toxicity, measured as dissolved	7,038	3.32 ^f
Copper (µg/L)	3.1	Chronic toxicity, measured as dissolved	317	128 ^e
Lead (µg/L)	8.1	Chronic toxicity, measured as dissolved	1,140	8.36 ^e
Mercury (µg/L)	0.025	Chronic toxicity, measured as dissolved	2.73	0.0874 ^f
Nickel (µg/L)	8.2	Chronic toxicity, measured as dissolved	978	5.53 ^e
Selenium (µg/L)	71	Chronic toxicity, measured as dissolved	10,136	ND (5.00) ^e
Silver (µg/L)	1.9	Acute toxicity, measured as dissolved	257	3.21 ^e
Thallium (µg/L)	2,130	Acute toxicity to saltwater aquatic life	306,567	ND (0.100) ^{d,e}
Zinc (µg/L)	81	Chronic toxicity, measured as dissolved	11,249	220 ^e

Table 21. NPDES Requirements, State of Alaska Water Quality Standards, and AWWU 2009 Maximum Concentrations for Effluent Comparisons. (continued)

Parameter	Receiving Water Quality Standard ^a		Maximum Allowable Effluent Concentration ^b (MAEC)	AWWU 2009 Maximum Effluent Concentration ^c
Cyanide (µg/L)	1	For marine aquatic life	181	21 ^e
Total Aqueous Hydrocarbons (TAQH) (µg/L)	15	Growth and propagation of fish, shellfish, aquatic life, and wildlife including seabirds, waterfowl, and furbearers	2,715	17.2 ^f
Total Aromatic Hydrocarbons as BETX (µg/L)	10	Same as above	1,810	17.2 ^d
pH (pH units)		g	6.5 - 8.5	6.5 – 7.4 ⁱ
Total Residual Chlorine (TRC) (mg/L)		g	Daily Max. 1.2	Daily Max 1.05 ⁱ
BOD ₅ (mg/L)		g	Monthly Avg. 240 Weekly Avg. 250 Daily Max. 300 Monthly Removal ≥30 %	Monthly Avg. 145 ⁱ Weekly Avg. 157 ⁱ Daily Max. 175 ⁱ (Monthly Average 43 – 52%) ⁱ Annual Avg. Removal (47% in 2009) ⁱ

Table 21. NPDES Requirements, State of Alaska Water Quality Standards, and AWWU 2009 Maximum Concentrations for Effluent Comparisons. (continued)

Parameter	Receiving Water Quality Standard ^a	Maximum Allowable Effluent Concentration ^b (MAEC)	AWWU 2009 Maximum Effluent Concentration ^c
Total Suspended Solids (TSS) (mg/L)	<i>g</i>	Monthly Avg. 170 Weekly Avg. 180 Daily Max. 190 Monthly Removal $\geq 30\%$	Monthly Avg. 63 ⁱ Weekly Avg. 68 ⁱ Daily Max. 84 ⁱ Monthly Avg. Removal 73 – 81% ⁱ , Annual Avg. Removal 76% ⁱ
Total Ammonia (mg/L) ^j	8.1 Acute 1.2 Chronic ^j	1466 217	Monthly Max. 25.8 ⁱ
Fecal Coliform (FC MPN/100 mL)	<i>g</i>	Monthly geometric mean of at least five samples shall not exceed 850. Not more than 10% of samples shall exceed 2600.	Monthly mean maximum was 30 ⁱ The criterion of not more than 10% of samples exceeding 2600 was met in 2009. ⁱ

^a Alaska Administrative Code, 2003. Water Quality Standards, Chapter 70, 18 AAC 70.020(b)

^b For conservative substances, the maximum allowable effluent criteria (MAEC) were determined by assuming a dilution of 142:1 at the ZID boundary, where: $MAEC = 142 * (Criteria - Natural Background Concentration) + Criteria$; pollutant concentrations in the effluent should not exceed these values. For non-conservative substances (ammonia, cyanide, TAH, TAqH, and TRC) a dilution of 180:1 was utilized in the MAEC calculation. Background concentrations for dissolved metal utilized Table 4.2 in the SSWQC request documented for Point Woronzof Area that was submitted by AWWU (1998).

^c For metals, the maximum effluent concentration was determined from both total and dissolved concentrations.

^d Values from June 2009 or July 2009 toxic pollutant and pesticide samplings.

^e Values from AWWU's pretreatment program.

^f Values from effluent tested during receiving water sampling event.

^g MAECs are not based on water quality criteria but instead are specified in MOA's 2000 NPDES permit.

^h All samples tested as total chromium.

ⁱ Values from AWWU's in-plant monitoring.

^j Ammonia receiving water criteria based on pH of 8.0, temperature of 15.0°C, and salinity of 20psu.

^k Cadmium standard based on revised EPA level that was approved for State of Alaska (2001).

assumed that all of the metals contained in the effluent are potentially bioavailable upon entering the receiving water. All effluent concentrations were found to be much lower than the MAECs from the permit or computed from the water quality standards provided for in the AWQS. In addition, the permit limitations for all parameters were met for the 2009 program year. When the MAECs in Table 21 were compared to all of the 2009 data including; AWWU's self-monitoring effluent data, the toxic pollutant and pesticides sampling events (June and July 2009), the pretreatment monitoring data, and the effluent data from the receiving water sampling, no metals or cyanide values exceeded their MAECs. The highest concentrations of either total or dissolved metals seen in 2009 were all well below their respective MAECs.

The one metal that most closely approached its MAEC at any time was copper, and this was considerably below its MAEC. The maximum concentration of total copper was 128 µg/L compared to a MAEC of 317 µg/L. The highest dissolved copper concentration that was seen was 30 µg/L. All other effluent dissolved metals concentrations were found to be much less than their respective MAECs.

Those metals without AWQS, while analyzed as both total and dissolved metals as called for by the permit, are compared to total recoverable metal MAECs as provided by EPA criteria and include antimony, beryllium and thallium. Total metals concentrations for antimony, beryllium, and thallium were below detection limits, and thus well below their MAECs. As in past years, total recoverable metals detected in the influent and final effluent were compared with data from an EPA study of 40 Publicly Owned Treatment Works (POTWs) in Table 22 (EPA, 1982a). Without exception, metals and cyanide values were lower than or within the range of those detected in other POTWs from across the nation, even though the Asplund WPCF provides only primary treatment as compared to secondary treatment provided at the other plants that were examined in this study.

Historic influent and effluent total recoverable metals and cyanide concentrations collected as part of AWWU's self-monitoring program are presented in Table 23 and Table 24. It should be noted that prior to 2000 when the permit requirements changed, dissolved metals had only been analyzed in a single sample of effluent collected each year during the receiving water sampling. Beginning in August 2000, dissolved metals from the effluent have been analyzed in both the summer wet and summer dry sampling events and as part of the pretreatment monitoring. Concentrations are low and fairly consistent over time. Concentrations of total recoverable metals concentrations seen in the influent and effluent during 2009 generally fell within the range of concentrations seen during prior years. Concentrations of dissolved metals were generally found to fall within range of concentrations seen over the prior five years as seen in Table 23. In 2009 and 2008, cyanide concentrations were typical of the long term average whereas in 2007 cyanide appeared to be slightly elevated although barely outside the historic range.

Total arsenic concentrations in the final effluent had remained fairly steady over the last five years, and 2009 values remained well within the historic range. The maximum total arsenic concentration in final effluent seen during 2009 was 1.84 µg/L, compared to an MAEC of 4,882 µg/L (Table 21). Arsenic values are not a serious concern for this permit in terms of effluent concentrations, since the concentration in the final effluent is so much lower than the MAEC.

Table 22. Comparison Between Influent/Effluent Analysis Results for Anchorage and 40 POTWs.^a

Parameter	Anchorage Values				40 POTW Study Values				
	2009 Concentration ^b (µg/L)				Frequency of Detection (%)		Range Detected (µg/L)		Influent Median
	Summer-Dry		Summer-Wet		Influent	Secondary Effluent	Influent	Secondary Effluent	(µg/L)
	INF	EFF	INF	EFF					
VOLATILES ^c									
Benzene	0.22 J	0.24 J	ND	ND	61	23	1-1560	1-72	2
Chloroform	2.14	3.24	3.2 J	2.0 J	91	82	1-430	1-87	7
1,4-Dichlorobenzene	0.77 J	0.79 J	0.61 J	0.68 J	17	3	2-200	3-9	NA
Ethylbenzene	2.01	1.18	ND	ND	80	24	1-730	1-49	8
Methylene chloride	12.5	11.0	6.8	4.2 J	92	86	1-49000	1-62000	38
Tetrachloroethene	1.67	1.14	ND	ND	95	79	1-5700	1-1200	23
Toluene	13.0	8.84	6.6	5.5	96	53	1-13000	1-1100	27
Xylene (Total)	8.43	3.68	ND	1.7 J	NA	NA	NA	NA	NA
SEMI-VOLATILES ^c									
Phenol	ND	18.1	28.2	ND	79	29	1-1400	1-89	7
TOTAL METALS & OTHER COMPONENTS									
Antimony	ND	ND	ND	ND	14	13	1-192	1-69	NA
Arsenic	ND	ND	ND	ND	15	12	2-80	1-72	NA
Beryllium	ND	ND	ND	ND	3	1	1-4	1-12	NA
Cadmium	ND	ND	ND	ND	56	28	1-1800	2-82	3
Chromium	3.25	ND	ND	ND	95	85	8-2380	2-759	105
Copper	65.5	48.9	32.6	34.9	100	91	7-2300	3-255	132
Lead	5.38	2.35	1.61	1.80	62	21	16-2540	20-217	53
Mercury	ND	ND	ND	ND	70	31	0.2-4	0.2-1.2	0.517
Molybdenum	ND	ND	ND	ND	NA	NA	NA	NA	NA
Nickel	4.98	3.62	2.79	2.98	79	75	5-5970	7-679	54
Selenium	ND	ND	ND	ND	9	10	1-10	1-150	NA
Silver	1.85	1.56	ND	ND	71	25	2-320	1-30	8
Thallium	ND	ND	ND	ND	3	2	1-19	1-2	NA
Zinc	158	97.4	62.7	81.4	100	94	22-9250	18-3150	273
Cyanide	ND	ND	ND	16	100	97	3-7580	2-2140	249

^a Source: EPA, 1982. *Fate of Priority Pollutants in POTWs*. Final Report, Volume I, Effluent Guidelines Division, WH-552, EPA 440/1-82/303

^b Data from NPDES 2009 toxic pollutant and pesticide monitoring

^c Only analytes detected in either the influent or effluent and in the 40 POTW study are included.

J Estimated value

NA Not available

ND Not detected

Table 23. Comparison of Toxic Pollutants and Pesticides in Anchorage's Final Effluent to the Previous Five Years. Values in brackets are from EPA Method 602 where available.

Pollutant	2004		2005		2006	
	Dry	Wet	Dry	Wet	Dry	Wet
	6/23-24	8/23-24	5/23-24	8/1-2	6/27-28	8/15-16
ORGANICS (µg/L)						
Acetone	ND	ND	ND	ND	ND	ND
Benzene	ND[0.24 J]	ND	ND [ND]	3.3 J	ND [0.43J]	0.59 J
Benzoic acid	ND	ND	ND	ND	ND	ND
Benzyl alcohol	ND	ND	ND	ND	ND	ND
Bis-(2-ethylhexyl) phthalate	16	15	15	14 B	18	10
Butyl benzyl phthalate	ND	4.2 J	7.4 J	2.7 J	ND	ND
Chloroform	3.2 J	3.6 J	2.6 J	4.1 J	3.6 J	3.8 J
Chloromethane	ND	ND	ND	1.4 J	ND	1.1 J
*1,3-Dichlorobenzene	ND	ND	ND	ND	ND	ND
*1,4-Dichlorobenzene	ND	ND	ND	ND	1.0 J	1.1 J
Diethyl phthalate	ND/ND/8.5 J	7.4 J	8.5 J	10	7.7 J	7.9 J
Di-n-butyl phthalate	1.7 J	ND	ND	ND	ND	ND
Ethylbenzene	ND[0.37J,COL]	ND	ND/ND	ND	ND [3.8]	0.62 J
3&4 Methylphenol	ND	ND	ND	ND	ND	ND
Methylene Chloride	4.4 J	4.7 J,B	2.6 J,B	5.0 B	4.5 J	3.3 J,B
Phenol	19	19	19	21	18	13
Tetrachloroethene	ND	ND	ND	ND	4.0 J	1.4 J
1,1,2,2-Tetrachloroethane	ND	ND	ND	ND	ND	ND
Toluene	5.9[6.4]	7.2	4.0 J [5.6]	10	8.7 [11]	8.7
* Total Xylenes	ND[1.3COL]	ND	1.5 J [0.93]	2.4 J	6.7 J [17]	3.1 J
Total Hydrocarbons as Oil and Grease ^a	26300	25400	21400	17600	19900	19400
Total Aromatic Hydrocarbons as BETX	25.9[8.31]	27.2	1.5 J [0.93]	20.7	25.4 [32.23]	13.0
OTHER						
Cyanide (µg/L)	ND	ND	ND	ND	5	ND
Asbestos (million fibers/L)	ND	ND	ND	ND	ND	ND

Table 23. Comparison of Toxic Pollutants and Pesticides in Anchorage's Final Effluent to the Previous Five Years. (continued) Values in brackets are from EPA Method 602 where available.

Pollutant	2007		2008		2009	
	Dry	Wet	Dry	Wet	Dry	Wet
	6/19-20	8/7-8	6/17-18	8/13-14	6/23-24	7/28-29
ORGANICS (µg/L)						
Acetone	ND	ND	ND	ND	ND	100
Benzene	0.58 J[ND]	0.27 J	ND[ND]	ND	0.240 J	ND
Benzoic acid	ND	ND	ND	ND	241	141
Benzyl alcohol	ND	ND	ND	ND	28.4	25.8
Bis-(2-ethylhexyl) phthalate	20 J	0.20 J	33 J,B	14 J	ND	ND
Butyl benzyl phthalate	ND	ND	ND	ND	ND	ND
Chloroform	3.4 J	3.8 J	3.0 J	3.0 J	3.24	2.0 J
Chloromethane	ND	1.7 J	ND	ND	ND	ND
* 1,3-Dichlorobenzene	9.5	0.98 J	ND	ND	ND	ND
* 1,4-Dichlorobenzene	9.5	0.98 J	ND	0.96 J	0.790 J	0.68 J
Diethyl phthalate	10 J	ND	7.7 J	7.8 J	ND	ND
Di-n-butyl phthalate	ND	ND	ND	ND	ND	ND
Ethylbenzene	2.9 J[ND]	0.62 J	0.76 J [0.86]	ND	1.18	ND
Methylene Chloride	3.1 J	3.5 J, B	3.4 J, B	7.7 B	11.0	4.2 J
3&4 Methylphenol	ND	ND	ND	ND	119	78.1
Phenol	24 J	25 J	23 J	25 J	18.1	ND
Tetrachloroethene	6.4	2.5 J	0.94 J	ND	1.14	ND
1,1,2,2-Tetrachloroethane	3.3 J	ND	ND	ND	ND	ND
Toluene	21[4.9]	8.1	6.8[6.4]	6.4	8.84	5.5
* Total Xylenes	23 [2.6]	3.1 J	4.5 J [2.5 COL]	2.6 J	3.68	1.7 J
Total Hydrocarbons as Oil and Grease ^a	14900	34500	28000	32000 B	37600	64900
Total Aromatic Hydrocarbons as BETX	47.5 [8.5]	12.1	17.1	19.0	13.9	17.2
OTHER						
Cyanide (µg/L)	9J/9J/10	59	9.0 J (0.19 / 0.25)	6.9 J	ND	16
Asbestos (million fibers/L)	ND	ND	ND	ND	ND	ND

Table 23. Comparison of Toxic Pollutants and Pesticides in Anchorage's Final Effluent to the Previous Five Years. (cont.) Values in brackets from EPA Method 602 where available.

Pollutant	2004		2005		2006	
	Dry	Wet ^b	Dry	Wet ^b	Dry	Wet
	6/23-24	8/23-24	5/23-24	8/1-2	6/27-28	8/15-16
TOTAL METALS (µg/L)						
Antimony	ND	ND/ND	0.65	ND/ND	0.65	0.58/0.60
Arsenic	ND	ND	3	2	2.4	2.6/2.8
Beryllium	0.2	0.1	0.1	ND	ND	ND/ND
Cadmium	ND	ND	0.3	ND	0.27	0.24/0.25
Chromium	4	ND	5	3	2.2	2.8/2.7
Copper	63	65	52	54	51	49/48
Lead	12	4	6	2	2.7	2.9/2.9
Mercury	0.11	0.70	0.10	0.11	0.13	0.10
Molybdenum	NT	NT	NT	NT	NT	NT
Nickel	5	ND	4	4	2.8	4.2/4.3
Selenium	ND	ND/ND	0.47	ND/ND	1.4	1.4/ND
Silver	3.9	ND	1.7	1.4	3.1	2.3/2.4
Thallium	ND	ND/ND	ND	ND/ND	ND	ND/ND
Zinc	140	76	90	90	100	97/96
DISSOLVED METALS (µg/L)						
Antimony	ND	ND/ND	0.45	ND/ND	ND	ND
Arsenic	ND	ND	2	2	1.2	1.9
Beryllium	ND	0.1	0.1	ND	ND	ND
Cadmium	0.6	ND	ND	ND	ND	ND
Chromium	ND	ND	4	2	0.79	0.55
Copper	27	49	37	42	1.4	26
Lead	4	8	6	2	0.064	0.42
Mercury	ND	ND	ND	ND	0.035	0.027
Molybdenum	NT	NT	NT	NT	NT	NT
Nickel	6	ND	ND	ND	3.7	2.9
Selenium	ND	ND/ND	ND	ND/ND	9.6	1.1
Silver	ND	0.6	ND	0.9	ND	ND
Thallium	ND	ND/ND	ND	ND/ND	ND	ND
Zinc	40	12	40	40	3.3	35
PESTICIDES (µg/L)						
alpha-BHC	ND	ND	ND	ND	ND	0.023 J
beta-BHC	ND	ND	ND	0.037 J	ND	ND
Dieldrin	ND	ND	ND	ND	0.010 J,COL	0.021 J
Endosulfan II	ND	ND	0.075 J	ND	ND	0.042 J
Endrin	ND	ND	ND	ND	ND	ND
Endrin ketone	ND	ND	ND	ND	0.012 J,COL	ND
Heptachlor	ND	ND	0.17 J	0.99	ND	0.54
4,4'-DDD	ND	ND	ND	ND	ND	ND
4,4'-DDE	ND/ND/ND	ND	ND	ND	0.0080 J,COL	ND
4,4'-DDT	ND	ND	ND	ND	ND	ND
Malathion	ND	ND	0.49 J, CHI	ND	ND	ND

Table 23. Comparison of Toxic Pollutants and Pesticides in Anchorage's Final Effluent to the Previous Five Years. (cont.) Values in brackets from EPA Method 602 where available.

Pollutant	2007		2008		2009	
	Dry	Wet	Dry	Wet	Dry	Wet
	6/19-20	8/7-8	6/17-18	8/13-14	6/23-24	7/28-29
TOTAL METALS (µg/L)						
Antimony	ND	ND	0.57 J	0.47 J	ND	ND
Arsenic	2.18	1.83	2.5 J	2.2 J	ND	ND
Beryllium	ND	ND	ND	ND	ND	ND
Cadmium	ND	ND	0.51 J	0.60 J	ND	ND
Chromium	2.09	1.90	2.3 B,J	2.2 B,J	ND	ND
Copper	40.7	34.8	36	37	48.9	34.9
Lead	2.08	3.57	2.8	2.3	2.35	1.8
Mercury	ND	ND	0.047 J	0.041 J	ND	ND
Molybdenum	10.8	6.81	6.4 B	4.5	ND	ND
Nickel	3.91	4.05	2.5	3.2	3.62	2.98
Selenium	ND	ND	1.3 J	ND	ND	ND
Silver	2.22	1.26	1.3	1.4	1.56	ND
Thallium	ND	ND	ND	ND	ND	ND
Zinc	83.8	84.8	120	110 B	97.4	81.4
DISSOLVED METALS (µg/L)						
Antimony	ND/ND	ND	0.39 J	0.33 J	ND	ND
Arsenic	1.93/1.95	1.69	ND	2.2 J	ND	ND
Beryllium	ND/ND	ND	ND	ND	ND	ND
Cadmium	ND/ND	ND	ND	ND	ND	ND
Chromium	1.32/1.50	1.33	1.1 J	3.5	ND	ND
Copper	25.4/25.2	26.9	14	15	14.0	26.8
Lead	ND/ND	2.34	0.78 J	0.64 J	ND	0.917
Mercury	ND	ND	ND	ND	ND	ND
Molybdenum	9.95/10.2	6.19	6.4	4.2	ND	ND
Nickel	3.24/3.33	3.54	2.7	2.8	2.94	2.77
Selenium	ND/ND	ND	ND	2.5 J	ND	ND
Silver	1.01/1.07	ND	0.51 J	0.59 J	ND	ND
Thallium	ND/ND	ND	ND	ND	ND	ND
Zinc	48.7/48.0	49.5	20	27	38.4	58.4
PESTICIDES (µg/L)						
alpha-BHC	ND	ND	ND	0.0082 J,COL	ND	ND
beta-BHC	ND	ND	ND	0.036 J,COL	ND	0.014 CHI
Dieldrin	ND	ND	ND	ND	ND	ND
Endosulfan II	ND	ND	ND	ND	ND	ND
Endrin	ND	0.011 J, COL	ND	ND	ND	ND
Endrin ketone	ND	ND	ND	ND	ND	ND
Heptachlor	0.015 J, COL	0.58	ND	ND	ND	ND
4,4'-DDD	ND	0.047 J	ND	ND	ND	ND
4,4'-DDE	ND	0.016 J, COL	ND	ND	ND	0.010
4,4'-DDT	ND	ND	ND	ND	0.25 CHI	ND
Malathion	ND	ND	ND	ND	ND	ND

a EPA method 1664 HEM b Duplicate effluent collected (field duplicate) or analyzed (lab duplicate) shown as value/duplicate value

* Non-priority pollutants J Estimated value

CHI More than 40% RPD between primary and confirmation results. The higher of the two results is reported.

COL More than 40% RPD between primary and confirmation results. The lower of the two results is reported.

B Compound also detected in method blank ND Not detected NT Not tested

Table 24. Historical Discharge Monitoring Data (1986 - Present) for Influent and Effluent Total Metals and Cyanide. Concentrations are rounded values in µg/L. Values represent a range of minimum (Min) and maximum (Max) results for 1986-2003 as available. Results for 2004-2009 are from pretreatment monitoring (Avg of six results from both the wet and dry sampling events).

Year	Average Flow (mgd)	Arsenic		Beryllium		Cadmium		Copper		Lead		Mercury		Nickel		Silver		Zinc		Chromium		Cyanide	
		Inf.	Eff.	Inf.	Eff.	Inf.	Eff.	Inf.	Eff.	Inf.	Eff.	Inf.	Eff.	Inf.	Eff.	Inf.	Eff.	Inf.	Eff.	Inf.	Eff.	Inf.	Eff.
1986-2003 Min	23	<1	<1	<0.03	<0.03	0.4	0.2	36	10	<1	<1	<0.1	<0.1	<1	<1	2.1	1	54	38	<1	<1	<0.4	1
1986-2003 Max	40	26	16	0.6	0.2	20	30	280	150	149	50	3.0	1.5	77	60	30.4	98	260	407	112	120	85	50
2004 Avg	29	3	2	0.2	0.2	0.4	<0.3	83	58	10	6	0.4	0.2	7	5	5.9	3.2	169	120	5	4	<10	<10
2004 Min	26	<2	<2	0.1	0.1	<0.3	<0.3	71	46	6	4	0.1	0.1	<6.2	<6.2	<1.5	<1.5	140	76	<6.2	<6.2	<10	<10
2004 Max	34	4	2	0.2	0.3	<6.2	<6.2	99	68	12	12	0.9	0.7	8	<6.2	7.2	3.9	192	150	<6.2	<6.2	<10	10
2005 Avg	28	3	3	0.1	0.1	0.4	0.3	90	53	7	4	0.3	0.1	9	5	3.3	1.7	155	92	6	4	<0.9	<0.9
2005 Min	24	2	<2	<0.1	<0.1	<0.3	<0.3	78	47	4	2	0.1	0.1	6	4	2.8	1.3	140	80	4	1	<0.9	<0.9
2005 Max	30	4	4	0.1	0.1	0.4	0.3	116	57	10	6	0.5	0.1	17	8	4.3	2.2	180	110	7	7	<0.9	<0.9
2006 Avg	28	3	3	0.5	0.5	0.4	0.3	84	57	5	3	0.1	0.1	7	4	4	3	190	99	7	3	1.0	1.7
2006 Min	26	3	2	<0.5	<0.5	0.3	0.2	75	48	2	2	0.1	0.1	4	3	2	2	180	94	4	2	<1.0	<1.0
2006 Max	32	3	3	<0.5	<0.5	0.5	0.4	93	77	8	4	0.2	0.1	11	6	6	3	200	110	15	7	<1.0	5
2007 Avg	28	2	2	<1.0	<1.0	<1.0	<1.0	63	39	4	2	0.3	<0.2	5	4	3	2	156	90	4	2	14	22
2007 Min	25	1	2	<1.0	<1.0	<1.0	<1.0	30	34	2	2	<0.2	<0.2	4	4	1	1	55	79	2	2	6	9
2007 Max	32	3	3	<1.0	<1.0	<1.0	<1.0	94	43	10	4	0.9	<0.2	9	4	3	2	299	105	7	3	25	59
2008 Avg	29	2	2	<1.0	<1.0	1.7	1.2	66	37	6	2	0.1	0.1	5	3	2	1	187	104	5	3	6	7
2008 Min	27	2	2	<1.0	<1.0	0.3	0.2	55	35	4	2	0.1	0.04	4	2	2	1	160	79	4	2	2	3
2008 Max	30	3	3	<1.0	<1.0	6.8	4.9	92	41	13	3	0.2	0.1	6	3	3	2	290	120	8	3	10	10
2009 Avg	28	<5	<5	<0.4	<0.4	<0.5	<0.5	55	59	4	4	<0.2	<0.2	4	4	1.3	1.5	124	119	2	2	<5	11
2009 Min	26	<5	<5	<0.4	<0.4	<0.5	<0.5	33	35	2	2	<0.2	<0.2	3	3	<1	<1	63	81	<2	<2	<5	<5
2009 Max	31	<5	<5	<0.4	<0.4	<0.5	<0.5	74	128	9	8	<0.2	<0.2	5	6	1.8	3.2	165	220	3	3	<5	21

Inf. Influent
Eff. Effluent
mgd million gallons per day

During 2009, cyanide concentrations in the effluent ranged from <5.0 to 21 µg/L, well below the MAEC of 181 µg/L. Cyanide had been a constituent of concern in the prior permit because it approached or even exceeded the prior MAEC of 50 µg/L in some years. In 1986 it was observed that the effluent cyanide concentrations often exceeded the influent concentrations by an order of magnitude. This trend continued during subsequent years of sampling and was the subject of a special investigation conducted by the AWWU (CH2M Hill, 1987; CH2M Hill in association with Loren Leman, P.E., 1988). The conclusion of this investigation was that the measured increase in cyanide between the influent and effluent was the result of the treatment plant's incinerator. Cyanide formed in the incinerator during sludge incineration was returned to the plant during the stack scrubbing process. Subsequently, cyanide decreased and this was believed to be due to the change in the scrubber water source from recirculated primary effluent to well water.

The most restrictive criteria of growth and propagation of fish, shellfish, other aquatic life, and wildlife was used for the hydrocarbon limits presented in Table 21. The MAECs for TAqH and TAH as BETX were met again this year, with maximum levels in the effluent well below the AWQS. The parameter of TAqH was analyzed in effluent only during the receiving water quality sampling, and the TAqH concentration was 17.2 µg/L as compared to the MAEC of 2,715 µg/L. The maximum BETX (TAH) value of 17.2 µg/L (measured by EPA method 624) was seen during the toxic pollutant and pesticide July 2009 sampling, and this value fell well below the MAEC of 1,810 µg/L.

The MAEC for total ammonia was met again this year, with effluent values exhibiting a maximum of 25.8 mg/L as compared to the MAEC of 217 mg/L for the chronic limit and a MAEC of 1,466 mg/L for the acute limit. These MAECs are based on saltwater acute criteria of 1.2 mg/L and saltwater chronic criteria of 8.1 mg/L, which are a function of temperature, salinity, and pH as presented in the AWQS. For comparison in this report the criteria were based on a salinity of 20 psu, temperature of 15 °C, and a pH of 8.0 units.

In addition to the MAECs that are based on the State and Federal water quality criteria, a number of other effluent limitations are specified in the NPDES permit. These daily, weekly, and monthly limitations include pH, TRC, BOD₅, TSS, and fecal coliform (Table 21). All of these parameters met all permit limitations for 2009.

For fecal coliform, the permit limitation of a monthly geometric mean (of at least five samples) that shall not exceed 850 FC MPN/100 mL was not exceeded this year, with the maximum monthly geometric mean of 30 FC MPN/100mL. Fecal coliform also met the monthly criteria "that not more than 10 % of the effluent samples shall exceed 2600 FC MPN/100 mL during any month" for all of 2009.

The permit limitations for monthly and weekly averages and daily maximum were met for BOD₅ and TSS. Amendments to the Clean Water Act (40 CFR; Final Rule, 8/9/94), require at least 30 % average monthly removal for both of these parameters. BOD₅ and TSS met this requirement on both an average monthly and annual basis with the lowest monthly removal of 43% for BOD and 73% for TSS. Removal of BOD₅ averaged 47 % for the 2009 calendar year which is higher than was seen during the previous five years where average annual removals ranged from 33 to 39 %. The monthly removal for TSS ranged from 73 to 81 % with an annual average of 76 %,

about the same as reported for the last ten years and well above the average monthly criteria of 30 %.

Concentrations of other toxic pollutants and pesticides detected in the influent and final effluent were generally lower than or within the range of those detected in other POTWs from across the nation, even though the Asplund WPCF provides only primary treatment as compared to secondary treatment provided at the other plants (Table 22). Toxic pollutants and pesticides also generally fell within the historical range of values seen in past years; levels of toxic pollutants and pesticides detected in the Anchorage effluent this year and over the previous five years are shown in Table 23. These data indicated some variability over time, but a generally similar pattern overall. Levels were low and often below reporting limits. As in the past, the types and concentrations of measured organic compounds varied between the two sampling periods. Also, in some instances, large differences in pollutant concentrations occurred between the influent and effluent. Inconsistencies can be explained by looking at sampling methodology and plant operation in the case of point-source contaminants. If spikes of contaminants are occurring in the influent, these might be hit or missed during sampling. On the other hand, an effluent sample could still contain the contaminant because of mixing in the clarifiers. Differences in concentrations in influent and effluent samples could also be due to lower suspended solids in the effluent samples. This can be seen in Table 9 and Table 10, where greater variability usually occurs in the influent concentrations as compared to the effluent.

Historic discharge monitoring data (1986 - 2009) for other parameters of concern measured in the influent and effluent are presented in Table 25. Most parameters have remained fairly steady over time. Dissolved oxygen levels increased from 1986 with a peak in 1992, and then generally decreased over the next ten years. Levels of DO over the past six years including 2009 have been fairly consistent and generally in the range of 2 to 6 mg/L. Other constituents of potential concern such as TSS have remained fairly steady in both the influent and effluent over the past six years and within the range of that seen historically. The BOD₅ effluent average during 2009 (125 mg/L) is slightly lower than that seen during the prior five years and well within the range seen historically. Average BOD₅ levels in the influent in 2009 were slightly higher than that seen over the prior five years yet still within the range seen historically.

The yearly average effluent fecal coliform bacteria concentration, reported at 14 MPN/100 mL for 2009, was similar to that seen in 2007 and 2008 and considerably lower than the prior four years. Elevated levels seen in 2004 were the highest yearly average seen on the program to date and were most likely the result of a program to optimize chlorine usage as described below. Lower fecal coliform values for 2006 through 2009 showing a downward trend are more in line with prior data, indicating that the disinfection efficacy at the WPCF has been improving.

As described in earlier reports, a project to improve the efficiency of the Asplund WPCF effluent disinfection system was implemented during 2001-2002. The chlorine injection process was improved by installation of rapid mixing equipment (the "Water Champ", installed in November 2001) to mix chlorine gas directly with the effluent. Oxidation Reduction Potential (ORP) technology using a *Strantrol 890 Controller* was installed in December 2001 to control the chlorine dosage rate by adjusting it in response to both flow and oxidation reduction potential of the wastewater. Prior to this improvement, it was never possible to determine an exact correlation between TRC and coliform kill. Dosage control by the ORP has resulted in adequate coliform kills with far lower residuals and has substantially reduced the annual chlorine usage, but optimizing the disinfection process continues to be an on-going focus.

Table 25. Historical Mean Monthly Discharge Monitoring Data (1986-Present) for Influent and Effluent Non-Metals.

Year	Temperature (°C)		pH ^a		TRC (mg/L)		DO (mg/L)		BOD ₅ (mg/L)		TSS (mg/L)		Fecal Coliform (MPN/100 mL)		Ammonia (mg/L)	
	Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent
1986-2003 Min	9	9	6.4	6.4	NT	0.07	NT	2.1	98	69	117	37	NT	5	NT	13.8
1986-2003 Max	17	18	8.2	8.5	NT	1.0	NT	8.6	296	174	307	86	NT	1141	NT	29.3
2004 Avg	12.9	13.6	NA	NA	NT	0.26	NT	3.9	226	148	229	49	NT	325	NT	20.9
2004 Min	10.6	11.2	6.7	6.6	NT	0.1	NT	2.1	205	133	204	45	NT	57	NT	17.2
2004 Max	16.2	17.2	8.0	8.1	NT	0.49	NT	5.2	259	168	280	51	NT	1213	NT	24.2
2005 Avg	12.7	13.2	NA	NA	NT	0.30	NT	4.6	205	148	235	54	NT	175	NT	20.0
2005 Min	10.7	11.1	7.4	7.2	NT	0.17	NT	3.1	194	131	216	45	NT	19	NT	18.5
2005 Max	15.6	16.1	7.9	7.5	NT	0.55	NT	6.2	284	174	273	58	NT	484	NT	22.0
2006 Avg	12.0	12.3	NA	NA	NT	0.34	NT	4.0	220	146	229	54	NT	44	NT	19.4
2006 Min	9.8	10.0	6.7	6.5	NT	0.18	NT	2.6	199	132	196	50	NT	4	NT	17.0
2006 Max	14.8	15.1	7.8	8.1	NT	0.56	NT	5.3	237	165	268	59	NT	229	NT	21.5
2007 Avg	11.8	11.9	NA	NA	NT	0.38	NT	3.7	229	148	231	57	NT	18	NT	19.3
2007 Min	9.4	9.9	6.6	6.5	NT	0.25	NT	1.5	180	124	195	48	NT	3	NT	17.2
2007 Max	14.6	15.4	8.0	7.9	NT	0.57	NT	6.1	279	174	284	66	NT	76	NT	22.9
2008 Avg	12.0	11.9	NA	NA	NT	0.35	NT	2.9	211	131	223	51	NT	20	NT	19.9
2008 Min	10.0	9.3	6.8	6.6	NT	0.20	NT	2.2	189	119	194	46	NT	6	NT	16.1
2008 Max	14.2	15.1	8.5	7.7	NT	0.49	NT	3.8	244	149	265	56	NT	63	NT	22.5
2009 Avg	11.7	12.2	NA	NA	NT	0.34	NT	2.8	235	125	239	56	NT	14	NT	21.6
2009 Min	8.9	9.4	6.6	6.5	NT	0.24	NT	1.3	172	83	187	48	NT	5	NT	18.2
2009 Max	14.7	15.4	7.9	7.4	NT	0.52	NT	4.3	274	145	269	63	NT	30	NT	25.8

^a Values represent monthly pH minimum and maximum

NA Not applicable

NT Not tested

The average TRC had dropped from 0.8 mg/L in 2001 to 0.4 mg/L in 2002, and TRC levels fell even lower in 2003 and 2004, with average TRC values of 0.26 mg/L for both of these years. The average TRC in 2009 concentration of 0.34 mg/L was within the range seen in 2005 through 2008. The average fecal coliform monthly average rose from 39 FC MPN/100 mL in 2001 to a high of 325 FC MPN/100 mL in 2004, and in 2009 has dropped back even further to 14 FC MPN/100 mL. As noted above, there were no exceedances of fecal coliform permit limits in 2009.

Quarterly WET testing was conducted on 24-hr flow composite effluent samples during all four quarters of calendar year 2009. Echinoderm fertilization tests were performed during the first, second, and fourth quarters of 2009. Use of this test during the first and second quarters was based on the screening test results from the fourth quarter of 2008, which had determined the sea urchin to be the most sensitive species tested. Annual three-species re-screening for the most sensitive species in 2009 was performed during the third quarter, and the sea urchin was again found to be the most sensitive species. Although a toxic response was seen from the effluent during three of the four quarters of WET testing, all results were found to be acceptable and within the permit specified limit of TUC < 143 and required no additional testing.

In summary, effluent chemistry monitoring indicated that with no exceptions, effluent concentrations of toxic pollutants and pesticides, metals and cyanide, and conventional parameters were much lower than their applicable permit limits and their MAECs. Fecal coliform also met all permit specified criterion in 2009. All toxic pollutants and pesticides concentrations including metals and cyanide were lower than or within the range of those detected at secondary treatment plants from across the nation.

5.1.2 Sludge Monitoring

The current permit requires sludge monitoring twice per year, once each during the dry and wet conditions in summer as part of the toxic pollutant/pretreatment monitoring. There are no Part 503 monitoring requirements included in the permit, but sludge monitoring is required because the Part 503 regulations are self-implementing as described in Section 2.1.5. Part 503 monitoring of sludge at Asplund WPCF has been included in this report (Table 13) and will also be reported separately to EPA as required by the regulations by 19 February 2010.

While limits for levels of toxic pollutants and pesticides in sludge are not part of the current permit, comparisons can be made for these data based on other treatment facilities' monitoring results and to the site specific allowable limits for metals that were determined for the facility. In all cases, sludge metals were found to be substantially lower than the site specific allowable limits (Table 13). Again, data indicate that average concentrations of toxic pollutants and pesticides in Anchorage's sludge are generally lower than "typical" concentrations seen at other treatment facilities (Table 26)(EPA 1985c). In 2009, arsenic ranged from <2.40 to 6.34 µg/g with an average concentration of 3.85 µg/g compared to a typical concentration of 4.6 µg/g and a 95th percentile value of 20.77 µg/g. Beryllium ranged from <0.24 to 1.75 µg/g with an average concentration of 0.49 µg/g in 2009 (Table 13). These values exceed the "typical" result from other municipal sludges of 0.313 µg/g; but the average concentration was well within the 95th percentile value reported from other treatment works of 1.168 µg/g. The concentration of nickel in the June sludge sampling was found to be elevated at 400 µg/g compared to historic Asplund

Table 26. Comparison Between Sludge Analysis Results for Anchorage and Typical and Worse Case Concentrations Used by EPA in Developing Median or Mean Environmental Profiles^a. All concentrations are in µg/g dry weight.

Pollutant	2009 Anchorage Values			Typical Concentration	95 th Percentile "Worse Case"
	June ^b	July ^b	2009 AVG ^c		
Aldrin/Dieldrin	ND	ND	---	0.07	0.81
Arsenic	ND	4.0	3.8	4.6	20.77
Benzene	ND	ND	---	0.326	6.58
Benzo(a)anthracene	ND	ND	---	0.68	4.8
Benzo(a)pyrene	ND	ND	---	0.14	1.94
Beryllium	1.75	ND	0.5	0.313	1.168
Bis(2-ethylhexyl)phthalate	ND	ND	---	94.28	459.25
Cadmium	0.664	1.29	1.1	8.15	88.13
Carbon Tetrachloride	ND	ND	---	0.048	8.006
Chlordane (α,γ)	ND	ND	---	3.2	12
Chloroform	ND	ND	---	0.049	1.177
Chromium	122	12.2	26.2	230.1	1499.7
Copper	163	231	---	409.6	1427
Cyanide	ND	1.2	---	476.2	2686.6
DDT/DDE/DDD	0.280	ND	---	0.28	0.93
3,3-Dichlorobenzidine	ND	ND	---	1.64	2.29
Methylene chloride	ND	ND	---	1.6	19
Endrin	ND	ND	---	0.14	0.17
Hexachlorobenzene	ND	ND	---	0.38	2.18
Hexachlorobutadiene	ND	ND	---	0.3	8
Lead	19.4	19.2 B	17.7	248.2	1070.8
gamma-BHC (Lindane)	ND	ND	---	0.11	0.22
Malathion	ND	ND	---	0.045	0.63
Mercury	NT	NT	0.5	1.49	5.84
Nickel	400	13.9	59.3	44.7	662.7
PCBs	ND	ND	---	0.99	2.9
Pentachlorophenol	ND	ND	---	0.0865	30.434
Phenanthrene	ND	ND	---	3.71	20.69
Phenol	ND	ND	---	4.884	82.06
Selenium	ND	2.23	---	1.11	4.848
Tetrachloroethene	ND	0.035 J	---	0.181	13.707
Trichloroethene	ND	ND	---	0.46	17.85
2,4,6-Trichlorophenol	ND	ND	---	2.3	4.6
Vinyl Chloride	ND	ND	---	0.43	311.942
Zinc	225	595 B	---	677.6	4580

^a Source: EPA 1985c. *Summary of Environmental Profiles and Hazard Indices for Constituents of Municipal Sludge: Methods and Results*. Office of Water Regulations and Standards, Appendix F.

^b Data from NPDES 2009 toxic pollutant and pesticide monitoring

^c Average from 2009 Part 503 sludge monitoring results

Not monitored in-plant for Part 503

ND

Not detected

B

Method blank contamination.

J

Estimated value (below MDL or MRL)

NT

Not tested

WPCF values and also exceeded the typical concentration of 44.7 µg/g but was less than 95th percentile value reported from other treatment works of 662.7 µg/g. Chromium was also found to be elevated during the June sampling event compared to historic Asplund WPCF concentrations, but was below the typical concentration seen at other POTWs. The average mercury concentration measured during the Part 503 sampling was 0.541 µg/g, well below the typical concentration of 1.49 µg/g. The other Part 503 metals tested, cadmium and lead, both fell below typical concentrations.

Other metals that were monitored but not a requirement of the Part 503 regulations were copper, selenium, and zinc. Copper and zinc concentrations were below typical concentrations during both the June and July sampling. The selenium value reported for the July 2009 sampling event was 2.23 µg/g, compared to the typical concentration of 1.11 µg/g and a 95th percentile concentration of 4.848 µg/g.

Table 27 provides an overview of historical sludge data for total metals. In general, year 2009 data indicated similar concentrations of arsenic, cadmium, lead, and mercury compared to historical data over the last few years. As discussed previously, both chromium and nickel were found to be elevated during the June 2009 monitoring but were similar to the historic range for the other seven sampling events that took place during 2009.

5.2 WATER QUALITY MONITORING

5.2.1 Plume Dispersion Sampling

To test the hypothesis that the water quality at the ZID boundary was not degraded with respect to the water quality at the nearfield and control stations, the non-parametric Kruskal-Wallis Test (Zar, 1984) was employed which determined whether significant differences occurred within the sample group. If significant differences were observed, Dunn's test, a test that performs pairwise tests of significance ($\alpha = 0.05$), was employed (Dunn, 1964). The results of these tests for the June survey period as a function of water quality parameters are presented in Table 28. Non-detect values were replaced with half the detection limit value for statistical testing.

Data from the receiving water survey showed statistically significant differences between the three outfall groupings (within-ZID, ZID boundary, and nearfield stations) and the control station grouping for salinity at the surface and between the nearfield and control stations for the mid and bottom depths. These differences were the result of the control stations being slightly less saline; however, though significant differences were found, these differences were very small. In the past the control stations have often been found to be less saline as a result of increased river influence on the north side of Knik Arm from the Matanuska and Knik Rivers. Statistically significant differences for dissolved oxygen, pH, and turbidity were also seen for the mid and bottom depths between the control stations and the nearfield stations with both of these groups found similar to the within-ZID and/or ZID boundary stations. These differences were the result of the natural oceanographic differences from the north side to the south side of Knik Arm and were not attributed to the Asplund discharge. No statistical differences were seen for any of these parameters that could be attributed to the Asplund WPCF discharge since the within-ZID station grouping were not found to be different from either the other outfall or control station groupings.

Table 27. Historical Discharge Monitoring Data (1986 - Present) for Metals in Sludge.
Concentrations are in mg/kg dry weight. Results for years 1986-2003 represent the range of the results for monthly minimum (Min) and maximum (Max) as available. Results for 2004-2009 represent Part 503 sludge monitoring values.

Year	Arsenic	Beryllium	Cadmium	Chromium	Lead	Mercury	Nickel
1986-2003 Min	1.7	<0.02	0.7	3.38	19	<0.1	7
1986-2003 Max	151	0.23	10.0	55	468	7.3	53
2004 Avg	3.0	0.14	2.0	16	25	1.3	14
2004 Min	2.5	0.11	1.3	11	20	0.7	9
2004 Max	3.8	0.18	3.0	21	30	2.1	17
2005 Avg	2.4	0.21	2.0	14	25	1.5	16
2005 Min	1.8	0.13	1.69	12	10	<0.02	11
2005 Max	2.7	0.37	3.0	19	33	3.1	20
2006 Avg	3.8	0.06	2	17	26	0.86	15
2006 Min	1.9	ND	1.23	13	18.2	0.390	11.9
2006 Max	5.94	0.15	3	25	39.3	1.70	19
2007 Avg	5.00	N/A	1.56	14.5	18.9	0.818	11.0
2007 Min	ND(<3.2)	ND(<0.307)	0.986	12.8	9.8	0.576	9.43
2007 Max	7.85	ND(<3.38)	2.37	15.8	25.1	1.04	13.4
2008 Avg	4.73	N/A	1.35	13.7	21.4	0.812	11.5
2008 Min	ND	0.08 J	1.02	9.77	15.4	0.357	8.34
2008 Max	5.40	ND< (0.42)	1.80	24.0	31.2	1.93	13.6
2009 Avg	3.85	0.49	1.11	26.17	17.70	0.541	59.34
2009 Min	ND (<2.4)	ND(<0.24)	0.66	7.90	10.60	0.231	7.23
2009 Max	6.34	1.75	1.77	122.0	25.80	0.885	400.0

N/A – Not applicable ND – Not Detected

For TRC, statistically significant differences were seen between the within-ZID stations versus the control and nearfield locations. These differences were an outfall related affect due to the three stations within the ZID where detectable levels of TRC were measured. However, no TRC was detected at the ZID boundary or at any location outside of the ZID. No significant differences were seen for temperature, color, or fecal coliform.

Although statistical differences were seen, all pH values fell well within the AWQS of 6.5 - 8.5 and values did not vary more than 0.2 pH units that would be attributed to the outfall, as required by the AWQS. For color, concentrations were found to be all between the detection limit of 5 and 8 color units. In 2007, color was found to be elevated at all locations compared to most prior years, and was believed to be due to the naturally high suspended sediment levels in the samples from Knik Arm that were not completely removed from the samples during the laboratory analysis. During 2008 and 2009, an additional preparation step was added where color samples were allowed to settle and decanted in the field prior to submittal to the laboratory. Upon reaching the laboratory the samples were processed by either filtration or centrifuging which resulted in much more representative sample analysis results. It is anticipated that this procedure will be continued in future years.

Table 28. 2009 Station Group Differences at the 5 Percent Significance Level ($p \leq 0.05$) as determined by the Nonparametric Kruskal-Wallis (ANOVA) and Dunn's (ad hoc multiple comparison) Statistical Analysis Tests.

Water Quality Parameter	Water Column Depth		
	Surface	Middle	Bottom
<u>Conventional Analyses*</u>			
Temperature	NS	NS	NS
Salinity	<u>1 2 3 vs. 4</u>	<u>1 2 3 vs. 1 2 4</u>	<u>1 2 3 vs. 1 2 4</u>
Dissolved Oxygen	NS	<i>SIG</i> ^{NSD}	<u>1 2 3 vs. 2 4</u>
pH	NS	<u>1 2 3 vs. 4</u>	<u>1 2 3 vs. 1 4</u>
Turbidity	NS	<u>1 2 3 vs. 1 2 4</u>	<u>1 2 3 vs. 1 2 4</u>
Color Units ^{HV}	NS	----	----
Fecal Coliform ^{HV}	NS	----	----
Total Residual Chlorine ^{HV}	<u>2 3 4 vs. 1 2</u>	----	----
<u>Metal and Hydrocarbon Analyses**</u>			
Arsenic	NS ^D , NS ^{TR}	----	----
Cadmium	NS ^D , NS ^{TR}	----	----
Chromium	<i>SIG</i> ^D , NS ^{TR}	----	----
Copper	NS ^D , NS ^{TR}	----	----
Mercury	NS ^D , NS ^{TR}	----	----
Nickel	<i>SIG</i> ^D , NS ^{TR}	----	----
Lead	NS ^D , NS ^{TR}	----	----
Silver	NS ^D , NS ^{TR}	----	----
Zinc	NS ^D , NS ^{TR}	----	----
Cyanide	NS ^{TR}	----	----
Total Suspended Solids	NS ^{TR}	----	----
Total Aromatic Hydrocarbons (BETX)	NS ^{TR}	----	----
Total Aqueous Hydrocarbons (TAqH)	NS ^{TR}	----	----

* Tests were performed on four Station Groups (Group 1: Within-ZID Sites; Group 2: ZID Boundary Sites; Group 3: Nearfield Sites; and Group 4: Control Sites). Bolded Groups signify *SIG* result. Underlined Groups are not significantly different from each other (Dunn's Test result, $p > 0.05$).

** Tests performed on stations located between the outfall (Drogue F1 sites) and the control (Drogue C1 sites).

---- Not Applicable (surface samples only)

NS Not Significant K-W Test Result ($p > 0.05$)

SIG Significant K-W Test Result ($p \leq 0.05$)

^D Dissolved

^{TR} Total Recoverable

^{NSD} Dunn's Test could not discriminate among groups.

^{HV} Half the detection limit used in place of data with "<" and NDs.

In addition to the standard water quality sampling, concentrations of total aromatic hydrocarbons (TAH) as BETX and TAqH were measured at the surface at six stations (three at the control site and three at the flood tide outfall site, along the first drogue track). No statistically significant differences in TAH or TAqH concentrations were detected between the control and outfall stations. There were no BTEX concentrations above MRLs seen at the Control Stations. One ZID Station, F1-1 within the ZID, had a BTEX value slightly above the MRL, however, it was well below, the AWQS of 10 µg/L. TAqH concentrations were calculated for all six stations using the MDL as the value for all non-detects yielding a maximum of 7.1 µg/L, significantly less than the AWQS of 15 µg/L at all locations. In addition, comparison of TPAH concentrations indicate that levels were elevated only at the outfall station during low slack water (F1-1), as has sometimes been seen in the past. All TPAH levels were relatively low.

Total suspended solids, cyanide, and total recoverable and dissolved metals samples collected at the outfall and control sites were also subject to statistical testing. No statistically significant differences were noted for TSS, cyanide and all of the total recoverable metals tested.

Statistically significant differences were seen for the dissolved metals chromium and nickel due to slightly higher concentrations at the outfall site. Although not statistically significant, dissolved levels of all tested metals were found to be slightly higher at Station F1-1 that is located within the ZID. This probably is an outfall related effect, although all concentrations (except copper as noted previously) were still well below AWQS, even within the ZID.

A comparison of the water quality data listed in Table 15 with the marine receiving water quality criteria for the State of Alaska (Table 21 and Table 29) indicates that none of the parameters listed in Table 15 exceeded AWQS outside ZID. All of the TRC concentrations were below the PQL of 0.01 mg/L for all locations outside of the ZID. It should be noted that the lowest achievable method detection limit in 2009 for the analysis of TRC in seawater (0.01 mg/L) is higher than the State-specified limit of 0.0075 mg/L for chronic 4-day average and below the 0.013 mg/L limit for acute 1-hr average for marine water use. As previously noted, all TRC methods are subject to positive interferences in estuarine or marine waters. However, based on the maximum daily effluent TRC concentration (1.05 mg/L) measured during 2009 and a dilution credit of 180:1 in the NPDES permit, the highest potential TRC concentration at the ZID boundary would be < 0.006 mg/L which meet AWQS at all receiving water locations outside of the ZID.

The State's receiving water quality standard for the "growth and propagation of fish, shellfish, aquatic life, and wildlife including seabirds, waterfowl, and furbearers" is 15 µg/L for TAqH and 10 µg/L for TAH. As seen in Table 17, these standards were not exceeded during the receiving water sampling. For all control stations, TAH as BETX was below the method reporting limit and well below the AWQS. One outfall station (F1-1) had a measurable toluene value of 2.14 µg/L pushing the total BTEX value (which uses the detection limit of constituents as integers to calculate a conservative estimate of potential total BTEX) to 6.5 µg/L; still well below the AWQS while at the other two outfall stations TAH was below the level of detection. In addition, for "contact recreation", the AWQS for hydrocarbons is as follows: "Shall not cause a film, sheen, or discoloration on the surface or floor of the water body or adjoining shorelines. Surface waters shall be virtually free from floating oils." No film, sheen, or discoloration was observed during the receiving water sampling program during 2009.

Table 29. State of Alaska Water Quality Standards for Receiving Water.

Parameter	Most Restrictive Marine Water Quality Standards								
Fecal Coliform	Based on a 5-tube decimal dilution test the fecal coliform median MPN shall not exceed 14 FC/100 mL (harvesting for consumption of raw shellfish); a geometric mean of 20 FC/100 mL (for aquaculture of products not normally cooked and seafood processing); and not more than ten percent (10%) of the samples shall exceed 40 FC/100 mL (aquaculture of products not normally cooked and seafood processing).								
Dissolved Oxygen	Dissolved oxygen concentrations in estuaries and tidal tributaries shall not be less than 5.0 mg/L except where natural conditions cause this value to be depressed.								
pH	pH shall not be less than 6.5 or greater than 8.5, and shall not vary more than 0.2 pH unit from natural condition.								
Turbidity	Turbidity may not exceed the natural condition.								
Temperature	Temperature shall not cause the weekly average temperature to increase more than 1° C. The maximum rate of change shall not exceed 0.5° C per hour. Normal daily temperature cycles shall not be altered in amplitude or frequency.								
Salinity	Maximum allowable variation above natural salinity: <table> <tr> <th>Natural Salinity (‰)</th><th>Man-induced Salinity (‰)</th></tr> <tr> <td>0 to 3.5</td><td>1</td></tr> <tr> <td>3.5 to 13.5</td><td>2</td></tr> <tr> <td>13.5 to 35.0</td><td>4</td></tr> </table>	Natural Salinity (‰)	Man-induced Salinity (‰)	0 to 3.5	1	3.5 to 13.5	2	13.5 to 35.0	4
Natural Salinity (‰)	Man-induced Salinity (‰)								
0 to 3.5	1								
3.5 to 13.5	2								
13.5 to 35.0	4								
Sediment	No measurable increase in concentrations above natural conditions.								
Color	Color shall not exceed 15 color units or the natural conditions, whichever is greater.								
Petroleum Hydrocarbons, Oils and Grease	Total aqueous hydrocarbons (TAqH) in the water column shall not exceed 15 µg/L. Total aromatic hydrocarbons (TAH) in the water column shall not exceed 10 µg/L. Shall not cause a film, sheen, or discoloration on the surface or floor of the water body or adjoining shorelines. Surface waters shall be virtually free from floating oils.								
Total Residual Chlorine	Shall not exceed 13 µg/L (one hour average) acute, and 7.5 µg/L (four day average) chronic; for marine aquatic life.								
Toxic and Other Deleterious Substances	See Table 21.								

All the dissolved metals tested in receiving water (Table 16) as part of this program met the AWQS as shown in Table 21 at all locations on the ZID boundary and outside of the ZID including the control stations. These included: arsenic, cadmium, copper, chromium, lead, mercury, nickel, silver, and zinc. One copper sample taken at Station F1-1 was found to be higher (4.08 µg/L) than the AWQS of 3.1 µg/L, but this sample was taken from within the NPDES permit specified ZID and therefore is not a violation of AWQS. Testing of antimony, beryllium, selenium, and thallium in receiving water is not required by the permit and was not performed in 2009. Previous years of monitoring showed exceedances of water quality criteria for total recoverable metals due to the specified test methods in conjunction with high amounts of suspended particulates in Cook Inlet. Since the adoption of the more-appropriate SSWQC for dissolved metals in May 1999 and the adoption of dissolved metals in the AWQS, the receiving waters of Cook Inlet near the Asplund WPCF discharge have been in compliance with the AWQS.

All cyanide samples collected during the receiving water sampling were below the State-specified criteria of 1 µg/L for marine aquatic life. The highest cyanide concentration that was seen in 2009 was at Station F1-2 with an estimated value of 0.18 µg/L that was below the MRL. The cyanide concentrations in the effluent samples, that were measured as part of the receiving water sampling, were reported at estimated concentrations of 0.13 and 0.17 µg/L, well below the MAEC of 181 µg/L.

In summation, statistical analyses of the 2009 receiving water quality data indicated that water quality outside the ZID was not degraded with respect to control stations for any parameters. Differences that were noted in some parameters such as dissolved oxygen, salinity, turbidity, and pH were unlikely to be influenced by the Asplund WPCF outfall. All AWQS were met in 2009 for the Asplund WPCF receiving water quality program. Although dissolved metal parameters appeared to be slightly elevated at the within ZID station as compared to control stations, statistically significant increases at the outfall stations were only seen for chromium and nickel and all parameters were well below AWQS at all locations at or outside of the mixing zone. No statistically significant differences between the outfall and control site were seen for total metals. No statistically significant differences were seen for cyanide, TAH, or TAqH hydrocarbon concentrations between the outfall and control locations and all cyanide and hydrocarbon concentrations were below AWQS.

5.2.2 Fecal Coliform Bacteria

In the past, the ADEC has indicated that one of their primary concerns is bacterial contamination of the shoreline by the Asplund WPCF discharge, indicated by fecal coliform bacteria concentrations. Because the Knik Arm's water uses have not been classified, regulations provide that the most restrictive standard must apply. State marine water quality standards for contact recreation require that the geometric mean fecal coliform concentration taken within a 30-day period not exceed 100 FC MPN/100 mL and that not more than one sample, or more than 10 % of the samples if there are more than 10, exceed 200 FC MPN/100 mL. Criteria for secondary recreation and for industrial water supply require that the mean fecal coliform concentration not exceed 200 FC MPN/100 mL and that not more than 10 % of the samples exceed 400 FC MPN/100 mL. State marine water quality criteria for the harvesting for consumption of raw mollusks and other raw aquatic life require that, based on a 5-tube decimal dilution test, the median shall not exceed 14 FC MPN/100 mL, and that not more than 10 % of the samples shall

exceed 43 FC MPN/100 mL. For seafood processing water supply for products not normally cooked, criteria are that the geometric mean may not exceed 20 FC MPN/100 mL, and not more than 10 % of the samples shall exceed 40 FC MPN/100 mL. For seafood processing water supply for products normally cooked, criteria are that the geometric mean may not exceed 200 FC MPN/100 mL, and not more than 10 % of the samples shall exceed 400 FC MPN/100 mL. For aquaculture water supply, criteria are that the geometric mean may not exceed 20 FC MPN/100 mL and not more than 10 % of the samples may exceed 40 FC MPN/100 mL.

Since the harvesting of shellfish and other raw aquatic life is not performed in these waters, and there is no aquaculture or seafood processing, it seems that the criteria for secondary recreation is most applicable; however, these criteria are not the most restrictive. Therefore, the most restrictive criteria used were that the median shall not exceed 14 FC MPN/100 mL (consumption of raw shellfish and other aquatic life), the geometric mean shall not exceed 20 FC MPN/100 mL (seafood processing and aquaculture for raw consumption), and not more than 10 % shall exceed 40 FC MPN/100 mL (seafood processing and aquaculture for raw consumption; Table 29).

Statistical tests indicated that fecal coliform concentrations were not significantly different between the within-ZID, ZID boundary, and the nearfield outfall station groups as compared to the control stations (refer to Table 28). Fecal coliform concentrations were very low again this year, and values ranged from <2 to 34 FC MPN/100 mL at the outfall stations (including the ZID stations) and a range of <2 to 4 FC MPN/100 mL at the control stations. The median at the control stations was <2 FC MPN/100 mL, and the median at the all outfall stations was 2 including stations both within and outside the ZID for both ebb and flood tides, well within the 14 FC MPN/100 mL criterion. The control site had a geometric mean of 3 FC MPN/100 mL, while that at the all the outfall stations (inside and outside the ZID) was 4 FC MPN/100 mL, both well below the criterion of 20 FC MPN/100 mL. No measurements (0 %) at the outfall stations either within or outside the ZID exceeded 40 FC MPN/100 mL, compared to the criteria of not more than 10 % of the measurements may exceed 40 FC MPN/100 mL. No samples collected at the control stations exceeded this criterion. The highest fecal coliform concentration (34 FC MPN/100 mL) was seen this year at a within-ZID outfall station (F2-1) near low tide.

Relatively low fecal coliform bacterial concentrations were seen in all three creeks sampled as compared to historical data, although all creek concentrations were still higher than most receiving water or any intertidal samples that were collected. The two replicate fecal coliform concentrations measured in Fish Creek were 900 and 1600 FC MPN/100 mL. Replicate concentrations measured in Ship Creek were much lower at 8 and 7 FC MPN/100 mL, while those at Chester Creek were 22 and 80 FC MPN/100 mL.

The range of fecal coliform concentrations for all intertidal samples collected during 2009 was quite low at <2 to 7 FC MPN/100 mL, with a median of 2 FC MPN/100 mL and a geometric mean of 3 FC MPN/100 mL. These values met the most restrictive water quality criterion of a median of 14 FC MPN/100 mL and a geometric mean of 20 FC MPN/100 mL. The highest coliform concentrations were seen at Station IT-4, 250 m east of the outfall. Due to the very low values encountered in 2009 throughout the study area, it is clear that the outfall was not affecting the intertidal zone during this sampling event. The criterion of not more than 10 % of the samples exceeding 40 FC 100/mL was met, as none of the intertidal measurements exceeded this value. Although not seen in this year's data, in the past the slightly elevated fecal concentrations seen intertidally were attributed to heavy waterfowl use of the area.

Area stream samples for fecal coliform bacteria ranged from a low at Ship Creek (7 and 8 FC MPN/100 mL) to a high at Fish Creek (900 and 1600 FC MPN/100 mL) with intermediate values seen at Chester Creek (22 and 80 FC MPN/100 mL). These fecal coliform concentrations from area streams that discharge into Knik Arm were much greater than that seen in the receiving water at the intertidal, outfall, or control locations.

Fecal coliform concentrations in the effluent samples collected in conjunction with the receiving water, intertidal sampling, and stream sampling were also low at 17 and 13 FC MPN/100 mL for the two replicates. These values were within the range of average monthly effluent values reported for the Asplund WPCF, which in 2009 ranged from 5 to 30 FC MPN/100 mL (Table 8).

In summary, fecal coliform concentrations in 2009 were found be very low in both the receiving water and intertidal areas. No statistically significant differences were seen between station groupings for the ZID, ZID-boundary, or nearfield stations as compared to the control location. Fecal coliform samples collected during the receiving water sampling program met all AWQS criteria, including all outfall stations both within and outside the ZID. All fecal coliform samples collected from intertidal areas also met all AWQS. Area creeks in 2009 were again found to be elevated and within the historical range for fecal coliform stream concentrations seen in prior years. It is clear from both this data and historic data that area streams are an important source of fecal coliform loading to the receiving waters of Knik Arm.

6.0 CONCLUSIONS

The following conclusions were based on results from the 2009 monitoring effort as compared to the current NPDES permit and State of Alaska water quality standards:

- The influent, effluent, and sludge monitoring showed, that with no exceptions, the Asplund WPCF met the NPDES permit requirements and complied with all applicable AWQS. AWWU's self-monitoring of TRC, pH, fecal coliform bacteria, BOD₅, and TSS showed compliance with all permit effluent limitations throughout 2009.
- AWWU's self-monitoring of TRC and pH showed that the permit limit for daily maximum TRC levels in the effluent was never exceeded and pH was within permit limits throughout 2009.
- The permit limit for the monthly maximum geometric mean of 850 fecal coliform colonies per 100 mL by most probable number (FC MPN/100 mL) technique was not exceeded in 2009. The fecal coliform monthly criteria "that not more than 10 % of the effluent samples shall exceed 2600 FC MPN/100 mL" was also not exceeded in any month during 2009.
- AWWU's self-monitoring of TSS and BOD₅ showed compliance with both regulatory and permit effluent limitations. TSS and BOD₅ were well within the daily, weekly, and monthly criteria for the entire year. Average monthly removals for BOD₅ and TSS of greater than 30 % are required by the amendment to the CWA (40 CFR Part 125; Final Rule, 8/9/94). The removal rate for both TSS and BOD₅ met the 30 % minimum removal requirement for all months during 2009. Annual removals were 76 % for TSS and 47 % for BOD₅ which indicate an exceptional level of primary treatment.
- Total aromatic hydrocarbons (TAH), total aqueous hydrocarbons (TAqH), and total ammonia concentrations in the effluent were all found to be below their maximum allowable effluent concentrations (MAECs) throughout 2009.
- Concentrations of metals and cyanide in the effluent never exceeded their MAECs at any time during any of the 2009 monitoring events.
- Concentrations of toxic pollutants and pesticides, including metals and cyanide, in the influent and effluent were all within the established range or lower than values from a national study of secondary treatment plants (EPA 1982a).
- Toxic pollutant sludge concentrations were found to be very low compared to the limits established under 40 CFR Part 503 and most were either not-detected or within the established range or lower than values from a national study of secondary treatment plants. Most metals fell at or below the typical concentrations and all metals, except one beryllium sample, were below 95th percentile worst case values (EPA 1985c).
- Whole effluent toxicity testing conducted quarterly met all permit limitations for toxicity for all tested species and all monitoring events in 2009.
- Little variation among stations was observed for most hydrographic parameters indicating that the receiving water environment is uniform and well mixed near the outfall.

- To test the hypothesis that the water quality at the ZID boundary was not degraded with respect to the water quality at the nearfield and control stations, statistical comparisons were employed. Conventional parameters such as dissolved oxygen, pH, salinity, and turbidity did show significant differences between sites, however, these were not ascribed to the outfall but rather to the different water mass properties at the control stations. No statistically significant differences were seen for temperature, TRC, TSS, color, or fecal coliform at the ZID boundary when compared to nearfield and control stations.
- Fecal coliform concentrations in receiving water and intertidal samples were found to be very low at all stations. AWQS criteria of a median of not more than 14 FC MPN/100 mL, a geometric mean of not more than 20 FC MPN/100 mL, and of not more than 10 % of the samples exceeding 40 FC MPN/100 mL were met at all receiving water locations.
- Supplemental receiving water quality samples obtained as part of the plume dispersion monitoring indicated that dissolved metals were all below the AWQS at all locations on the ZID boundary and outside of the ZID including the control stations. Statistically significant differences between the outfall and control station groupings were seen for dissolved chromium and nickel but all concentrations were well within AWQS. Total metals were elevated compared to the dissolved as a result of the naturally high suspended sediment load. No statistically significant differences were seen between the outfall and control stations for any of the total recoverable metals.
- All cyanide concentrations in the receiving waters (outfall and control stations) were found to be below the receiving water quality criterion limit of 1.0 µg/L and no statistically significant differences were detected between concentrations at the control and outfall stations.
- Supplemental receiving water samples also demonstrated that TAH and TAqH met the AWQS at all locations. No statistically significant differences were detected between the control and outfall stations for either TAH or TAqH.
- Turbidity and color met the AWQS at all stations. TRC was at or below the detection limit of 10 µg/L at all locations except for three samples taken from within the ZID, as compared to the AWQS of 7.5 µg/L for chronic and 13.0 µg/L for acute marine water use. Based on the highest maximum daily effluent TRC concentration of 1050 µg/L seen during 2009 and a 180:1 effluent dilution credit, it is expected that TRC in the receiving water would be <6 µg/L before reaching the ZID boundary and would always meet all AWQS for TRC.

CONCLUSIONS

Results from the past year of the monitoring program confirm previous studies, data in the NPDES permit and 301(h) variance renewal application, and the decision by the EPA to reissue the NPDES permit with 301(h) variance. The Asplund WPCF is operating within regulatory requirements with no exceptions seen in 2009 and is showing no measurable impacts to the marine environment.

7.0 REFERENCES

- Alaska Department of Environmental Conservation, 1999. Alaska Administrative Code. Water Quality Standards, Chapter 70, (18 AAC 70).
- Alaska Department of Environmental Conservation, 2003. Alaska Administrative Code. Water Quality Standards, Chapter 70, (18 AAC 70).
- Alaska Department of Environmental Conservation, 2009. Alaska Administrative Code. Water Quality Standards, Chapter 70, (18 AAC 70).
- American Public Health Association, 1998. Standard Methods for the Examination of Water and Wastewater. 20th Edition. Washington, D.C. Various pagings.
- AWWU, 1998. Request for Site Specific Water Quality Criteria for Point Woronzof Area of Cook Inlet. Submitted to ADEC by Municipality of Anchorage, AWWU.
- AWWU, 2000. 2000 Monitoring Program Plan. Prepared by the Anchorage Water & Wastewater Utility, Treatment Division, Laboratory Services Section.
- CH2M Hill, in association with Ott Water Engineers, Inc., 1984. Application for Modification of Secondary Treatment Requirements, Section 301(h), Clean Water Act. Prepared for Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- CH2M Hill, in association with Ott Water Engineers, Inc., 1985. Amendment to Wastewater Facilities Plan for Anchorage, Alaska. Outfall Improvements. Prepared for Anchorage Water and Wastewater Utilities, Anchorage, Alaska.
- CH2M Hill, 1987. Industrial Waste Pre-treatment Program, Annual Report. Point Woronzof Wastewater Treatment Facility. Prepared for the AWWU, Anchorage, Alaska.
- CH2M Hill, in association with Loren Leman, P.E., 1988. Industrial Waste Pretreatment Program, Annual Report. Point Woronzof Wastewater Treatment Facility. Prepared for the Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- CH2M Hill, 1988. In situ Measurement of Dilution of John M. Asplund Water Pollution Control Facility Effluent in the Cook Inlet at Point Woronzof, Anchorage, Alaska. Prepared for the Municipality of Anchorage.
- CH2M Hill, 1998. NPDES Permit Application for NPDES Permit and 301(h) Variance from Secondary Treatment. John M. Asplund Water Pollution Control Facility. Prepared for the Anchorage Water and Wastewater Utility, Municipality of Anchorage, Alaska.
- CH2M Hill, 2008. 40 CFR Part 503 - Site Specific Sludge Limit Calculations Based on Asplund Water Pollution Control Facility Incinerator Source Testing. Prepared for the Anchorage Water and Wastewater Utility, Municipality of Anchorage, Alaska.
- Code of Federal Regulations, 1999. 40 CFR Parts 104; 125; 136; 401; and 503. Title 40. Protection of Environment, U.S. Government Printing Office, Washington, D.C.

- Dunn, Olive Jean, 1964. Multiple Comparisons Using Rank Sums. *Technometrics*, Vol. 6, No. 3:241.
- Dzombak, D.A., R.S. Ghosh, and G.M. Wong-Chong. 2005. *Cyanide in Water and Soil – Chemistry, Risk, and Management*. CRC Press, Taylor & Francis.
- EPA, 1976. *Quality Criteria for Water*. U.S. Environmental Protection Agency, Washington, D.C. U.S. Government Printing Office: 1977, 0-222-904.
- EPA, 1978. *Microbiological Methods for Monitoring the Environment*. U.S. Environmental Protection Agency, EPA 600/18-78-017.
- EPA, 1980. *Ambient Water Quality Criteria listed under Section 304(a)(1) of the Clean Water Act*, October 1980, EPA 440/5-90-015 through EPA 440/5-90-079, Office of Water Regulations and Standards, Criteria and Standards Division, Washington, D.C.
- EPA, 1982a. *Fate of Priority Pollutants in Publicly Owned Treatment Works. Final Report*, Volume 1, EPA 440/1-82/303, Effluent Guidelines Division, WH-552.
- EPA, 1982b. *Design of 301(h) Monitoring Programs for Municipal Wastewater Discharges to Marine Waters*. EPA 430/9-82-010.
- EPA, 1983. *Methods for Chemical Analysis of Water and Wastes*. U. S. Environmental Protection Agency, EPA 600/4-79/020, revised March 1983.
- EPA, 1985a. *Final NPDES Permit No. AK-002255-1 and attached Response to Comments on the Tentative Decision Document and Draft Permit for the John M. Asplund Water Pollution Control Facility*. Prepared by the EPA 301(h) Review Team, Region 10. September 1985.
- EPA, 1985b. *Analysis of the Section 301(h), Secondary Treatment Variance Application for the John M. Asplund Water Pollution Control Facility*. Prepared by the EPA 301(h) Review Team, Region 10. September, 1985.
- EPA, 1985c. *Summary of Environmental Profiles and Hazard Indices for Constituents of Municipal Sludge: Methods and Results*. EPA 822/S-85-001. Office of Water Regulations and Standards, Wastewater Criteria Branch, U.S. Environmental Protection Agency, Washington, D.C.
- EPA, 1986a. *Test Methods for Evaluating Solid Waste*. U.S. Environmental Protection Agency, Office of Solid Waste and Emergency Response, Washington, D.C. EPA SW 846.
- EPA, 1986b. *Quality Criteria for Water*, U.S. Environmental Protection Agency, Office of Water Regulations and Standards, Washington, D.C. EPA 440/5-86-001.
- EPA, 1988. *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms*. EPA 600/4-87/028.

- EPA, 1989. Ambient Aquatic Life Water Quality Criteria for Ammonia (Saltwater). EPA 440/5-88-004.
- EPA, 1992. Interim Guidance on Interpretation and Implementation of Aquatic Life Criteria for Metals. Health and Ecological Criteria Division, Office of Science and Technology. U.S. Environmental Protection Agency, Washington, D.C.
- EPA, 1993. Office of Water Policy and Technical Guidance on Interpretation and Implementation of Aquatic Life Metals Criteria. October 1, 1993 Memorandum from Martha G. Prothro, Acting Assistant Administrator for Water to EPA Regions I-X.
- EPA, 1994a. U.S. EPA Contract Laboratory Program National Functional Guidelines for Inorganic Data Review. U. S. Environmental Protection Agency, Office of Emergency and Remedial Response. EPA 540/R-94/013.
- EPA, 1994b. U.S. EPA Contract Laboratory Program National Functional Guidelines for Organic Data Review. U. S. Environmental Protection Agency, Office of Emergency and Remedial Response. EPA 540/R-94/012.
- EPA, 1994c. Water Quality Standards Handbook: Second Edition. Office of Water (4305). EPA-823-B-94-005a. U.S. Environmental Protection Agency, Water Quality Standards Branch, Office of Science and Technology, Washington, D.C.
- EPA, 1995. Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to West Coast Marine and Estuarine Organisms. First Edition. U. S. Environmental Protection Agency, National Exposure Research Laboratory, Cincinnati, OH. EPA 600/R-95-136.
- EPA, 1999a. Method 1664, Revision A. n-Hexane Extractable Material (HEM; Oil and Grease) and Silica Gel Treated n-Hexane Extractable Material (SGT-HEM; Non-polar Material) by Extraction and Gravimetry. February 1999. EPA-821-R-98-002.
- EPA, 1999b. Toxicity Reduction Evaluation Guidance for Municipal Wastewater Treatment Plants. EPA 833-B-99-002.
- EPA, 2000. Final NPDES Permit No. AK-002255-1 and attached Response to Comments on the Tentative Decision Document and Draft Permit for the John M. Asplund Water Pollution Control Facility. Prepared by the EPA 301(h) Review Team, Region 10. June 2000.
- EPA, 2001. September 28, 2001; Letter to Michele Brown, Commissioner, ADEC, from Randall Smith, Director, Office of Water, Environmental Protection Agency.
- EPA, 2006. September 15, 2006; Letter to Lynn J. Tomich Kent, Director, Division of Water, ADEC, from Michael F. Gearheard, Director, Office of Water, Environmental Protection Agency.
- EPA and Jones & Stokes Associates, Inc., 1982. Draft Environmental Impact Statement. Municipality of Anchorage Sewage Facilities Plan, Anchorage, Alaska. November 1982.

- Long, E.R., D.D. Macdonald, S.L. Smith, and F.D. Calder. 1995. Incidence of Adverse Biological Effects within Ranges of Chemical Concentrations in Marine and Estuarine Sediments. *Environ. Management*. 19: 81-97.
- Kinnetic Laboratories, Inc., 1979. Supplemental Studies of Anchorage Wastewater Discharge off Point Woronzof in Upper Cook Inlet. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska, R-79-13.
- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, in association with R.W. Hoffman, Ph.D., 1987a. Point Woronzof Monitoring Program, Annual Report, October 1985-1986. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, in association with R. W. Hoffman, Ph.D., 1987b. Point Woronzof Monitoring Program, Annual Report, November 1986-October 1987. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, 1988. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, November 1987-October 1988. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, 1989. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, November 1988-October 1989. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, 1991. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, November 1989-October 1990. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, 1992. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, November 1990-October 1991. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, 1993. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, November 1991-October 1992. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, 1994. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, November 1992-October 1993. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.

- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, 1995. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, November 1993-October 1994. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, 1996. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, November 1994-October 1995. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, 1997. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, November 1995-October 1996. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, 1998. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, November 1996-October 1997. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, 1999. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, November 1997-October 1998. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., 2000a. Point Woronzof Wastewater Treatment Facility, Monitoring Program Workplan, October 2000. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., 2000b. Point Woronzof Wastewater Treatment Facility, Initial Investigation - Toxicity Reduction Evaluation (TRE) Workplan, October 2000. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, 2000c. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, November 1998-October 1999. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc., with Technical Review by CH2M Hill, 2001. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, January – December 2000. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc. 2002. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, January – December 2001. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.

- Kinnetic Laboratories, Inc. 2003. Point Woronzof Wastewater Treatment Facility, Monitoring Program Annual Report, January – December 2002. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc. 2004. Anchorage Water and Wastewater Utility, John M. Asplund Water Pollution Control Facility at Point Woronzof. Monitoring Program Annual Report, January – December 2003. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc. 2005. Anchorage Water and Wastewater Utility, John M. Asplund Water Pollution Control Facility at Point Woronzof. Monitoring Program Annual Report, January – December 2004. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc. 2006. Anchorage Water and Wastewater Utility, John M. Asplund Water Pollution Control Facility at Point Woronzof. Monitoring Program Annual Report, January – December 2005. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc. 2007. Anchorage Water and Wastewater Utility, John M. Asplund Water Pollution Control Facility at Point Woronzof. Monitoring Program Annual Report, January – December 2006. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc. 2008. Anchorage Water and Wastewater Utility, John M. Asplund Water Pollution Control Facility at Point Woronzof. Monitoring Program Annual Report, January – December 2007. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- Kinnetic Laboratories, Inc. 2009. Anchorage Water and Wastewater Utility, John M. Asplund Water Pollution Control Facility at Point Woronzof. Monitoring Program Annual Report, January – December 2008. Prepared for the Municipality of Anchorage Water and Wastewater Utility, Anchorage, Alaska.
- NOAA/NOS, 2009. Tides and Currents, High and Low Water Predictions, West Coast of North and South America - Anchorage, Alaska. U.S. Department of Commerce.
- Ott Water Engineers, Inc., Quadra Engineering, Inc., and Black and Veatch Consulting Engineers, 1982. Wastewater Facilities Plan for Anchorage, Alaska. Prepared for Anchorage Water and Wastewater Utilities, Anchorage, Alaska.
- Sombardier, L. and P.P. Niiler, 1994. Global Surface Circulation Measured by Lagrangian Drifters. Sea Technology, October 1994. pp. 21-24.
- UNESCO and National Institute of Great Britain, 1973. International Oceanographic Tables, Volume 2 (82 pp.)
- Zar, J.H. 1984. Biostatistical Analysis. Second Addition. Prentice-Hall, Inc., Englewood Cliffs, NJ. 718 pp.